

CATEGORY 1

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9707220148 DOC. DATE: 97/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 NORTON, B.A. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 VISSING, G.S.

SUBJECT: Monthly operating rept for June 1997 for RE Ginna NPP.
 W/970711 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 5
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-1 PD	1 1	VISSING, G.	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	NRR/DRPM/PECB	1 1	OG/DBA/PAD	1 1
	RGN1	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE
AREA CODE 716 546-2700

July 11, 1997

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for June, 1997
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of June, 1997.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

9707220148 970630
PDR ADOCK 05000244
R PDR



920030



IE241/

OPERATING DATA REPORT

-1-

50-244

July 11, 1997

COMPLETED BY:

Benjamin A. Norton

Benjamin A. Norton

TELEPHONE (716) 771-3653

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT

Notes:

2. Reporting Period: June, 1997

3. Licensed Thermal Power (MW): 1520

4. Nameplate Rating (Gross MWe): 517

5. Design Electric Rating (Net MWe): 470

6. Maximum Dependable Capacity (Gross MWe): 490

7. Maximum Dependable Capacity (Net MWe): 480

8. If Changes Occur in Capacity Rating (Items Number 3 Through 7) Since Last Report, Give Reason:

9. Power Level to Which Restricted, If Any (Net MWe):

10. Reason For Restrictions, If Any:

	This Month	Yr.-to-Date	Cumulative**
11. Hours in Reported Period	<u>720.0</u>	<u>4343.0</u>	<u>241895.0</u>
12. Number of hours Reactor Was Critical	<u>720.0</u>	<u>4343.0</u>	<u>194257.3</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>1687.6 *</u>
14. Hours Generator On-line	<u>720.0</u>	<u>4343.0</u>	<u>191269.5</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
16. Gross Thermal Energy Generated (MWH)	<u>1091810.0</u>	<u>6549988.0</u>	<u>272426258.0</u>
17. Gross Electrical Energy Generated (MWH)	<u>372553.0</u>	<u>2240694.0</u>	<u>90351003.0</u>
18. Net Electrical Energy Generated (MWH)	<u>355010.0</u>	<u>2134283.0</u>	<u>85780149.8</u>
19. Unit Service Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>79.1</u>
20. Unit Availability Factor (%)	<u>100.0</u>	<u>100.0</u>	<u>79.1</u>
21. Unit Capacity Factor (using MDC Net) (%)	<u>102.7</u>	<u>102.4</u>	<u>76.4</u>
22. Unit Capacity Factor (using DER Net) (%)	<u>104.9</u>	<u>104.6</u>	<u>76.5</u>
23. Unit Forced Outage Rate (%)	<u>0.0</u>	<u>0.0</u>	<u>5.6</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each):

The refueling and maintenance outage is scheduled for October 20, 1997. The planned duration is 22 days.

25. If Shutdown At End of Report Period, Estimate Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

* CUMULATIVE TOTAL COMMENCING JANUARY 1, 1975

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: July 11, 1997

COMPLETED BY: Benjamin A. Norton
Benjamin A. Norton

TELEPHONE: (716) 771-3653

MONTH June, 1997

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	<u>498</u>
2.	<u>498</u>
3.	<u>498</u>
4.	<u>498</u>
5.	<u>498</u>
6.	<u>498</u>
7.	<u>498</u>
8.	<u>498</u>
9.	<u>498</u>
10.	<u>496</u>
11.	<u>493</u>
12.	<u>493</u>
13.	<u>494</u>
14.	<u>494</u>
15.	<u>494</u>
16.	<u>495</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	<u>494</u>
18.	<u>494</u>
19.	<u>492</u>
20.	<u>494</u>
21.	<u>492</u>
22.	<u>490</u>
23.	<u>490</u>
24.	<u>490</u>
25.	<u>490</u>
26.	<u>488</u>
27.	<u>487</u>
28.	<u>488</u>
29.	<u>487</u>
30.	<u>486</u>
31.	<u>---</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in reporting month. Compute to the nearest whole megawatt.

DOCKET NO: 50-244
 UNIT: R.E. GINNA NUCLEAR POWER PLANT
 DATE: July 11, 1997
 COMPLETED BY: Benjamin A. Norton
 Benjamin A. Norton,
 TELEPHONE: (716) 771-3653

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH June, 1997

No.	Date	Type ¹	Duration (hours)	Reason ²	Method of shuting down reactors ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
---	-----	-----	-----	-----	-----	-----	-----	-----	-----

1

F: Forced
S: Scheduled

2

Reason:
 A-Equipment (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory
 E-Operator Training &
 Licensee Examination
 F-Administrative
 G-Operational Error
 (Explain)
 H-Other (Explain)

3

Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

4

Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets for
 Licensee Event Report
 (LER) File (NUREG-
 0161)

5

Exhibit 1- Same Source

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO: 50-244

UNIT: R.E. Ginna Nuclear Power Plant

DATE: July 11, 1997

COMPLETED BY: Benjamin A. Norton
Benjamin A. Norton

TELEPHONE: (716) 771-3653

MONTH June, 1997

The unit operated at full power for the entire month of June. The average power level was 99.8%.

