

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9904300200 DOC.DATE: 99/04/23 NOTARIZED: NO DOCKET #  
 FACIL:50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244  
 AUTH.NAME AUTHOR AFFILIATION  
 POPP,R.W. Rochester Gas & Electric Corp.  
 RECIP.NAME RECIPIENT AFFILIATION  
 VISSING,G.S.

SUBJECT: Part 21 rept re power supply that did not work properly  
 when drawn from stock & installed in -25 VDC slot.Power  
 supply will be sent to vendor to perform failure mode  
 assessment.Evaluation will be completed by 991001.

DISTRIBUTION CODE: IE19T COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2  
 TITLE: Part 21 Rept (50 DKT)

NOTES:License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD1-1 PD	1 1	VISSING,G.	1 1
INTERNAL:	FILE CENTER 01	1 1	NRR/DRIP/REXB	1 1
	PDR WARD, M.	1 1	RES/DET/EIB	1 1
	RGN1	1 1	RGN2	1 1
	RGN3	1 1	RGN4	1 1
EXTERNAL:	INPO RECORD CTR	1 1	NOAC SILVER,E	1 1
	NRC PDR	1 1	NUDOCS FULL TXT	1 1


THIS DOCUMENT  
 HAS BEEN SCANNED

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED  
 TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001



TELEPHONE  
AREA CODE 716 546-2700

April 23, 1999

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Guy S. Vissing  
Project Directorate I-1  
Washington, D.C. 20555

Subject: 10 CFR Part 21 Interim Report  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Vissing:

The attached 10 CFR 21 interim report is submitted in accordance with 10 CFR Part 21, Reporting of Defects and Noncompliance, Section 21 (a) (2), which requires "if an evaluation of an identified deviation or failure to comply potentially associated with a substantial safety hazard cannot be completed within 60 days from discovery of the deviation or failure to comply, an interim report is prepared and submitted to the Commission".

Very truly yours, .

Robert W. Popp

xc: Mr. Guy S. Vissing (Mail Stop 8C2)  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

9904300200 990423  
PDR ADDCK 05000244  
S PDR

300013

IE19



**10CFR21 SUBSTANTIAL SAFETY HAZARD EVALUATION  
INTERIM REPORT**

**DESCRIPTION OF DEVIATION:**

A power supply, procured for use in the Nuclear Instrument System (NIS) source ranges (SR), when drawn from stock and placed in NIS SR channel N-31, did not work properly when installed in the -25 VDC slot. However, the power supply functioned properly when installed in the +25 VDC slot. This power supply is expected to function properly in both the positive and negative slots. It is not known whether this was a deviation present since receipt from the vendor, or was initiated during installation activities at Ginna Station (and not a deviation).

**REFERENCE DOCUMENTS :**

Rochester Gas & Electric Purchase Order NQ15139-C-JW

**DATE WHEN EVALUATION WILL BE COMPLETED:**

The power supply will be sent to the vendor to perform a failure mode assessment and determine if the power supply was deficient at the time of receipt. It is estimated that this evaluation will be completed by October 1, 1999.

Prepared: *W. A. Cain*  
Systems Engineer, I&C & Electrical System

*4/20/99*  
Date

Reviewed: *Charles A. Zurell*  
Manager, Nuclear Strategy and Procurement

*4/20/99*  
Date

