

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9905170169 DOC. DATE: 99/04/30 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME AUTHOR AFFILIATION
 WALDEN, J.V. Rochester Gas & Electric Corp.
 WIDAY, J.A. Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

VISSING, G.S.

SUBJECT: Monthly operating rept for Apr 1999 for RE Ginna Nuclear Power Plant. With 990510 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: License Exp date in accordance with 10CFR2, 2.109(9/19/72). 05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD1-1 PD	1 1	VISSING, G.	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 04</u>	1 1
	OC/DBA/PAD	1 1	RGNI	1 1
EXTERNAL:	LMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C
A
T
E
G
O
R
Y

D
O
C
U
M
E
N
T



ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649-0001
AREA CODE 716-546-2700



May 10, 1999

US Nuclear Regulatory Commission
Document Control Desk
Attn: Guy S. Vissing
Project Directorate I-1
Washington, DC 20555

Subject: Monthly Report for April, 1999
Operating Status Information
R.E. Ginna Nuclear Power Plant
Docket No. 50-244

Dear Mr. Vissing:

Pursuant to Ginna Improved Technical Specifications Section 5.6.4, attached is the monthly operating status report for Ginna Station for the month of April, 1999.

Very truly yours,

Joseph A. Widay
Joseph A. Widay
Plant Manager

xc: U.S. Nuclear Regulatory Commission
Mr. Guy S. Vissing (Mail Stop 14B2)
Project Directorate I-1
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

Attachments

9905170169 990430
PDR ADOCK 05000244
R PDR

OPERATING DATA REPORT

-1-

50-244

May 10, 1999

COMPLETED BY:

John V. Walden
John V. Walden

TELEPHONE (716) 771-3588

OPERATING STATUS

1. Unit Name: R.E. GINNA NUCLEAR POWER PLANT
2. Reporting Period: April, 1999
3. Design Electric Rating (Net MWe): 470
4. Maximum Dependable Capacity (Net MWe): 480

Notes:

	This Month	Yr.-to-Date	Cumulative**
5. Number of hours Reactor Was Critical	<u>188.6</u>	<u>1613.8</u>	<u>208333.0</u>
6. Hours Generator On-line	<u>139.3</u>	<u>1564.2</u>	<u>205262.9</u>
7. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>8.5 *</u>
8. Net Electrical Energy Generated (MWH)	<u>36678.0</u>	<u>689984.0</u>	<u>92541064.4</u>

** CUMULATIVE TOTAL COMMENCING NOVEMBER 8, 1969

DOCKET NO: 50-244
UNIT NAME: R.E. GINNA NUCLEAR POWER PLANT
DATE: May 10, 1999
COMPLETED BY: John V. Walden
TELEPHONE: (716) 771-3588

UNIT SHUTDOWN

REPORTING PERIOD: April, 1999
(Month/Year)

NO.	DATE	TYPE	DURATION (HOURS)	REASON ⁽¹⁾	METHOD OF SHUTTING DOWN ⁽²⁾	CAUSE/CORRECTIVE ACTIONS
		F: FORCED S: SCHEDULED				COMMENTS
1	3/1/99	S	523.6	C	1	
2	4/23/99	F	13.8	G	3	LER 1999-006
3	4/27/99	F	42.8	A	3	LER 1999-007

SUMMARY:

The unit was placed on line on April 22, 1999 following refueling and maintenance. A reactor trip occurred when Instrument & Control Technicians removed fuses from the wrong power range nuclear instrument channel while another was defeated.

The unit was placed on line on April 23, 1999. A second reactor trip occurred on April 27, 1999 when a reactor protection system bistable failed while another channel was defeated for calibration.

The unit was placed on line on April 29, 1999 and power was slowly increased for fuel conditioning for the remainder of the month.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)



10/10/10