

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9905190155 DOC. DATE: 99/05/12 NOTARIZED: NO DOCKET #
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G 05000244
 AUTH. NAME: AUTHOR AFFILIATION
 * Rochester Gas & Electric Corp.
 RECIP. NAME RECIPIENT AFFILIATION

Revised
12/29/99
[Signature]

JOHNSON, A. Records Management Branch (Document Control Desk)

SUBJECT: Rev 11 to "Technical Requirements Manual for Ginna Station."

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 0 ENCL 1 SIZE: 6
 TITLE: OR Submittal: General Distribution

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72). 05000244

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
LPD1-1 LA	1 1	LPD1-1 PD	1 1
VISSING, G.	1 1		
INTERNAL: <u>FILE CENTER 01</u>	1 1	NRR/DE/EMCB	1 1
NRR/DE/EMEB	1 1	NRR/DSSA/SPLB	1 1
NRR/DSSA/SRXB	1 1	NRR/SPSB JUNG, I	1 1
NUDOCS-ABSTRACT	1 1	OGC/HDS3	1 0
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

0

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

DOCUMENT CONTROL

Document Transmittal

To: DOCUMENT CONTROL DESK
US NRC
ATT: ALLEN JOHNSON
PROJECT DOCTORATE 1-1
WASHINGTON DC 20555

Transmittal: 9905026N 055
Date: 05/10/1999
Holder: 1217

LISTED BELOW ARE NEW OR REVISED CONTROLLED DOCUMENTS. REVIEW THE ATTACHED INSTRUCTION LETTER (IF APPLICABLE), AND UPDATE YOUR CONTROLLED DOCUMENT IN ACCORDANCE WITH IP-DOC-1.

Doc Id	Doc Title	Rev	Rev Date	Qty
TRM	TECHNICAL REQUIREMENTS MANUAL FOR GINNA STATION	011	05/12/1999	1

180141

=====

Receipt Acknowledgement and Action Taken:

Signature _____ Date _____

Return to: Rochester Gas & Electric Corporation
Ginna Station - Records Management
1503 Lake Road
Ontario, New York 14519

9905190155 990512
PDR ADOCK 05000244
PDR

Rochester Gas and Electric Corporation
Inter-Office Correspondence

May 7, 1999


Subject: Improved Technical Specifications (ITS), Amendment No. 74; Bases Revision 15; and Technical Requirements Manual (TRM) Revision 11

To: Distribution

Attached is Amendment No. 74 to the Ginna Station Improved Technical Specifications (ITS). This Amendment revises the specific gravity requirements for the station batteries. This Amendment was approved by the NRC in a safety evaluation dated April 23, 1999. This Amendment is considered effective May 12, 1999.

In addition to the Amendment, the associated changes to the ITS Bases and the Technical Requirements Manual are also included. Instructions for the necessary changes to your controlled copy of the ITS are attached.

Please contact Tom Harding (extension 3384) if you have any questions.


Thomas L. Harding

Attachment A

Please replace the following pages of your controlled copy of the ITS as follows:

<u>Volume</u>	<u>Section</u>	<u>Remove</u>	<u>Insert</u>
I	Attachment A to License	First Page	First Page
I	Attachment A to License	LEP-ii	LEP-ii
I	Attachment A to License	LEP-viii	LEP-viii
II	Chapter 3.8 (LCO)	3.8-19	3.8-19
II	Chapter 3.8 (Bases)	B 3.8-37	B 3.8-37
II	Chapter 3.8 (Bases)	B 3.8-52	B 3.8-52
II	Chapter 3.8 (Bases)	B 3.8-55	B 3.8-55
II	Chapter 3.8 (Bases)	B 3.8-56	B 3.8-56
III	TRM	First Page	First Page
III	TRM	LEP-i	LEP-i
III	TRM Chapter 5.0	TRM 5.0-2	TRM 5.0-2



GINNA STATION

TRM
Revision 10

TECHNICAL REQUIREMENTS MANUAL (TRM)


Responsible Manager

4/18/99
Effective Date

Controlled Copy No. 1217

List of Effective Pages
(TRM)

Page	Rev.	Page	Rev.	Page	Rev.	Page	Rev.
TOC		Section 3.3 (con'd)		Section 3.7 (con'd)			
i	8						
ii	4	TRM 3.3-13	4	TRM 3.7-10	6		
		TRM 3.3-14	4	TRM 3.7-11	10		
Section 1.0		TRM 3.3-15	4	TRM 3.7-12	1		
TRM 1.0-1	0	TRM 3.3-16	4	TRM 3.7-13	10		
		Section 3.4		TRM 3.7-14	1		
Section 2.0				TRM 3.7-15	4		
TRM 2.0-1	6	TRM 3.4-1	1	TRM 3.7-16	1		
		TRM 3.4-2	1	TRM 3.7-17	6		
Section 3.0		TRM 3.4-3	0	TRM 3.7-18	1		
TRM 3.0-1	1	TRM 3.4-4	0	TRM 3.7-19	1		
		TRM 3.4-5	0	TRM 3.7-20	6		
Section 3.1		TRM 3.4-6	0	TRM 3.7-21	6		
TRM 3.1-1	0	TRM 3.4-7	0	TRM 3.7-22	6		
TRM 3.1-2	1	TRM 3.4-8	3	TRM 3.7-23	1		
TRM 3.1-3	2	TRM 3.4-9	3	TRM 3.7-24	1		
TRM 3.1-4	0	TRM 3.4-10	3	TRM 3.7-25	8		
TRM 3.1-5	5	TRM 3.4-11	3	TRM 3.7-26	8		
TRM 3.1-6	1	TRM 3.4-12	3				
TRM 3.1-7	2	TRM 3.4-13	3	Section 3.8			
		TRM 3.4-14	3	TRM 3.8-1	0		
Section 3.2		Section 3.5		TRM 3.8-2	3		
TRM 3.2-1	0	TRM 3.5-1	0	TRM 3.8-3	10		
		Section 3.6		Section 3.9			
Section 3.3		TRM 3.6-1	0	TRM 3.9-1	0		
TRM 3.3-1	1	Section 3.7		TRM 3.9-2	8		
TRM 3.3-2	0			TRM 3.9-3	8		
TRM 3.3-3	1	TRM 3.7-1	1	TRM 3.9-4	1		
TRM 3.3-4	0	TRM 3.7-2	1	TRM 3.9-5	10		
TRM 3.3-5	0	TRM 3.7-3	6	TRM 3.9-6	8		
TRM 3.3-6	0	TRM 3.7-4	4	TRM 3.9-7	8		
TRM 3.3-7	1	TRM 3.7-5	1	Section 4.0			
TRM 3.3-8	1	TRM 3.7-6	1	TRM 4.0-1	3		
TRM 3.3-9	6	TRM 3.7-7	3	Section 5.0			
TRM 3.3-10	10	TRM 3.7-8	4				
TRM 3.3-11	4	TRM 3.7-9	1	TRM 5.0-1	3		
TRM 3.3-12	4			TRM 5.0-2	7		

Table TR 5.1-1 (page 1 of 1)
Temporary LCO Requirements

Item	Action Report #	Temporary LCO Requirement	Required Actions If Not Met	Effective Dates
5.1.1	97-0783	a. Verify key switches for MOVs 852A and 852B are in "off position" every 31 days.	a. Declare associated ECCS train inoperable per LCO 3.5.2.	6/19/97 until LCO 3.5.2 is changed
5.1.2	97-0894	a. Verify NaOH System tank NaOH solution concentration is $\leq 35\%$ by weight every 184 days.	a. Declare NaOH system inoperable per LCO 3.6.6.	6/19/97 until LCO 3.6.6 is changed.
5.1.3	N/A	a. R-11 required to be operable in MODES 1,2,3, and 4.	a. Perform either an RCS water inventory balance (SR 3.4.13.1) or analysis of containment atmosphere grab samples once within 12 hours and every 12 hours thereafter.	12/18/98 until LCO 3.4.15 is changed.
5.1.4	98-1726	a. Verify specific gravity of the designated pilot cell in each Train A and Train B battery is ≥ 1.195 every 31 days.	a. Declare associated battery inoperable per LCO 3.8.6.	1/8/99 until LCO 3.8.6 is changed.
5.1.5	98-1726	a. Verify average specific gravity of all connected cells of each Train A and Train B battery is ≥ 1.195 every 92 days.	a. Declare associated battery inoperable per LCO 3.8.6.	1/8/99 until LCO 3.8.6 is changed.

