

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9906040152      DOC. DATE: 99/05/24      NOTARIZED: NO      DOCKET #  
 FACIL: 50-244 Robert Emmet Ginna Nuclear Plant, Unit 1, Rochester G      05000244  
 AUTH. NAME      AUTHOR AFFILIATION  
 MECREDY, R.C.      Rochester Gas & Electric Corp.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 VISSING, G.S.

SUBJECT: Forwards LER 99-007 re personnel error, causes two channels  
 to be in tripped condition, resulting in reactor trip for RE  
 Ginna Nuclear Power Plant. Util currently planned to submit  
 suppl to LER by 990730.

DISTRIBUTION CODE: IE22T      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 + 7  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES: License Exp date in accordance with 10CFR2,2.109(9/19/72).      05000244

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD1-1 PD	1    1	VISSING, G.	1    1
INTERNAL:	AEOD/SPD/RRAB	1    1	<u>FILE CENTER</u>	1    1
	NRR/DIPM/IOLB	1    1	NRR/DIPM/IQMB	1    1
	NRR/DRIP/REXB	1    1	NRR/DSSA/SPLB	1    1
	RES/DET/EIB	1    1	RGN1 FILE 01	1    1
EXTERNAL:	L ST LOBBY WARD	1    1	LMITCO MARSHALL	1    1
	NOAC POORE, W.	1    1	NOAC QUEENER, DS	1    1
	NRC PDR	1    1	NUDOCS FULL TXT	1    1

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTR  
 DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED  
 TOTAL NUMBER OF COPIES REQUIRED: LTTR    16    ENCL    16





ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N Y 14649-0001

AREA CODE 716 541 1211

ROBERT C. MECREDY  
Vice President  
Nuclear Operations

May 24, 1999

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Attn: Guy S. Vissing  
Project Directorate I-1  
Washington, D.C. 20555

Subject: LER 1999-007, Personnel Error Causes Two Channels to be  
in Tripped Condition, Resulting in Reactor Trip  
R.E. Ginna Nuclear Power Plant  
Docket No. 50-244

Dear Mr. Vissing:

The attached Licensee Event Report LER 1999-007 is submitted in accordance with 10 CFR 50.73, Licensee Event Report System, item (a) (2) (iv), which requires a report of, "Any event or condition that resulted in a manual or automatic actuation of any engineered safety feature (ESF), including the reactor protection system (RPS)". A Level II Event Evaluation is in progress for this event, which may result in additional corrective actions. It is currently planned to submit a supplement to this LER by July 30, 1999.

Very truly yours,

*Joseph A. Widay for*  
Robert C. Mecredy

xc: Mr. Guy S. Vissing (Mail Stop 8C2)  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

U.S. NRC Ginna Senior Resident Inspector

9906040152 990524  
PDR ADOCK 05000244  
S PDR

1/1  
IE 22