



Washington Public Power Supply System
A JOINT OPERATING AGENCY

P. O. Box 968 3000 GEO. WASHINGTON WAY RICHLAND, WASHINGTON 99352 PHONE (509) 375-5000

G02-79-125
July 16, 1979

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1900 N. California Boulevard
Walnut Creek, California 94596

Attention: Mr. R.H. Engelken, Director

Subject: WPPSS NUCLEAR PROJECT NO. 2
DOCKET NO. 50-397, CPPR-93
REPORTABLE DEFICIENCY -10CFR50.55(e)

REGULATORY DOCKET FILE COPY

Dear Mr. Engelken:

In accordance with the provision of 10CFR 50.55(e), your staff was informed by telephone on June 21, 1979 of a reportable deficiency which involved powering emergency D.C. MCC Room Cooler, RRA-FC-12, from non-critical motor control center MC-7C-A.

Attached is our report on the deficiency.

Please contact us if you have additional questions.

Very truly yours,

D. L. Renberger

D. L. RENBERGER
Assistant Director
Technology

DLR:HLB:cs

Attachment

cc: JJ Verderber w/att - B&R, NY
JJ Byrnes w/att - B&R, NY
John G. Davis, Acting Director, NRC, Washington, D.C.
WNP-2 Files w/att
ND Lewis - NRC

7907250310

Boia
S
1/1



11