


Washington Public Power Supply System
A JOINT OPERATING AGENCY



P. O. Box 988

3000 GEO. WASHINGTON WAY

RICHLAND, WASHINGTON 99352

PHONE (509) 375-5000

January 28, 1980
G03-80-170

A012

Docket No. 50-397

Mr. R. H. Engelken, Director
U. S. Nuclear Regulatory Commission
1990 North California Boulevard
Suite 202, Walnut Creek Plaza
Walnut Creek, California 94956

Subject: WPPSS NUCLEAR PROJECT NO. 2
IE BULLETIN NO. 79-28 "POSSIBLE MANFUNCTION OF
NAMCO MODEL EA180 LIMIT SWITCHES AT ELEVATED
TEMPERATURES"

Dear Mr. Engelken:

The Washington Public Power Supply System has reviewed the subject
IE Bulletin and offers the following in response:

According to our records, we have no NAMCO Model EA180 stem mounted
limit switches in use or planned for use in safety-related applications
at sustained temperatures above 175°F.

The WNP-2 safety-related limit switches used in high temperature
locations are NAMCO Model EA700.

Very truly yours,

D. L. Renberger

D. L. RENBERGER
ASSISTANT DIRECTOR
TECHNOLOGY

DLR:FJ:crw

8 003280 065

80-01

