

Washington Public Power Supply System
A JOINT OPERATING AGENCY


P. O. Box 968

3000 GEO. WASHINGTON WAY

RICHLAND, WASHINGTON 99352

PHONE (509) 375-5000

August 28, 1980
G02-80-189



Docket No. 50-397

U. S. Nuclear Regulatory Commission
Region V
1990 N. California Boulevard
Suite 202 Walnut Creek Plaza
Walnut Creek, California 94596

Attention: Mr. R. H. Engelken, Director

Dear Mr. Engelken:

Subject: WNP-2 RESPONSE TO IE BULLETIN 80-19

In response to the subject IE Bulletin, please be advised that WNP-2 does not use any type of mercury-wetted relays in the Reactor Protective System or any other safety-related system.

Very truly yours,

D. L. Renberger

D. L. Renberger
Assistant Director, Technology

bk

cc: Office of I&E, Division of RCI--Washington, D.C.
W. Woods, NUS
N. S. Reynolds, D&L

8009120568

Q

R

