

Washington Public Power Supply System
A JOINT OPERATING AGENCY

P. O. Box 968

3000 GEO. WASHINGTON WAY

RICHLAND, WASHINGTON 99352


PHONE (509) 375-5000

*Central
Files*

Docket No. 50-397

December 24, 1980
G02-80-310

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, CA 94596



Attention: Mr. R. H. Engelken, Director

Gentlemen:

Subject: WPPSS NUCLEAR PROJECT NO. 2
RESPONSE TO IE BULLETIN NO. 80-23

Our review of WNP-2 design indicates that Valcor solenoid valves having Part Numbers V70900-21-1 or -3 are not used in this facility to perform any safety-related function. No further action needs to be done for this facility relative to IE Bulletin No. 80-23.

Very truly yours,

R. G. Matlock

R. G. MATLOCK
Program Director, WNP-2

RGM:BHS:cd

cc: JR Lewis - BPA
ND Lewis - EFSEC, Olympia
RE Snaith - B&R
V. Stello - NRC
AD Toth - NRC Site
JJ Verderber - B&R
B. Wood - NUS Corporation
WNP-2 Files



810-1270471

Q

Ao
2

80-202

