

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION# NBR: 8111030151 DOC. DATE: 81/10/27 NOTARIZED: NO DOCKET# #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power 05000397  
 AUTH. NAME: AUTHOR AFFILIATION  
 BOUCHEY, G. D. Washington Public Power Supply System  
 RECIP. NAME: RECIPIENT AFFILIATION  
 EISENHUT, D. G. Division of Licensing

SUBJECT: Provides final test results to demonstrate operational adequacy of safety relief valve for facility, in response to NUREG. 0737, Item II.D.1. Submittal of NEDE-24988-P. & letter completes item.

DISTRIBUTION CODE: B0018 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: PSAR/FSAR AMDTS and Related Correspondence

NOTES: 2 copies all matl: PM.

05000397

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	A/D LICENSNG	1	0	LIC BR #2 BC	1	0
	LIC BR #2 LA	1	0	AULUCK, R. 01	1	1
INTERNAL:	ELO	1	0	HUM. FACT ENG. 40	1	1
	I&E 06	3	3	IE/EPDBI 35	1	1
	IE/EPLBI 36	3	3	LIC QUAL BR 32	1	1
	MPA	1	0	NRR/DE/CEB 11	1	1
	NRR/DE/EQB 13	3	3	NRR/DE/GB 28	2	2
	NRR/DE/HGEB 30	2	2	NRR/DE/MEB 18	1	1
	NRR/DE/MTEB 17	1	1	NRR/DE/QAB 21	1	1
	NRR/DE/SEB 25	1	1	NRR/DSI/AEB 26	1	1
	NRR/DSI/VASB 27	1	1	NRR/DSI/CPB 10	1	1
	NRR/DSI/CSB 09	1	1	NRR/DSI/ETSB 12	1	1
	NRR/DSI/ICSB 16	1	1	NRR/DSI/PSB 19	1	1
	NRR/DSI/RAB 22	1	1	NRR/DSI/RSB 23	1	1
	NRR/DST/LGB 33	1	1	OP LIC BR 34	1	1
	PROC/TST REV 20	1	1	<del>REG FILE</del> 04	1	1
	SIT ANAL BR 24	1	1			
	EXTERNAL:	ACRS 41	16	16	BNL (AMDTS ONLY)	1
FEMA-REP DIV 39		1	1	LPDR 03	1	1
NRC PDRI 02		1	1	NSIC 05	1	1
NTIS		1	1			

NOV 06 1981

MAY

TOTAL NUMBER OF COPIES REQUIRED: LTR 65 ENCL 78

87



## Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

October 27, 1981  
G02-81-421  
SS-L-02-PLP-81-034

Docket No. 50-397

Mr. D. G. Eisenhower, Director  
U. S. Nuclear Regulatory Commission  
Division of Licensing  
Office of Nuclear Reactor Regulation  
Washington, D. C. 20555



Dear Mr. Eisenhower:

Subject: TRANSMITTAL OF SAFETY/RELIEF VALVE  
(S/RV) OPERABILITY TEST REPORT FOR  
SUPPLY SYSTEM NUCLEAR PROJECT NO. 2

- References:
- 1) Letter, T. Dente (BWR Owner's Group) to D.G. Eisenhower (NRC), "Transmittal of Valve Operability Test Report from Generic BWR Safety/Relief Valve (S/RV) Test Program", dated September 25, 1981
  - 2) Letter, G.D. Bouchee (WNP-2) to D.G. Eisenhower (NRC), "Supply System Nuclear Project No. 2 Preliminary Safety/Relief Valve (S/RV) Operability Test Results", dated July 21, 1981


In response to NUREG 0737 Item II.D.1, this letter provides the final test results which demonstrate the operational adequacy of the S/RV's for WNP-2. In addition, the adequacy of the S/RV discharge piping and supports has also been demonstrated. These final test results are contained in NEDE-24988-P, "Analysis of Generic BWR Safety/Relief Valve Operability Test Results", which was submitted to the NRC via Reference 1. WNP-2 is a participant in the BWR Owner's Group generic S/RV operability test program.

WNP-2 employs the Crosby type of S/RV. The applicability of the generic test results to this plant's S/RV's has already been demonstrated in Reference 2. It should be noted that Reference 2 incorrectly stated that the tested Crosby 6210 Valve applicable to WNP-2 was Model No. HB-65-DF. The valve employed by WNP-2 is HB-65-BP.

Boo'  
s  
1/0

8111030151

A



Mr. D. G. Eisenhower  
Page Two

October 27, 1981  
G02-81-421

A review of the test report shows that the operational adequacy of the S/RV's and the piping and supports for WNP-2 has been demonstrated for the conditions defined in Item II.D.1. The submittal of NEDE-24988-P and this letter satisfies the October, 1981 and January, 1982 submittal requirements of Item II.D.1 and completes WNP-2 efforts on this item.

Very truly yours,



G. D. Bouchey  
Deputy Director, Safety and Security

GDB/PLP/jca

cc: M.W. Hodges - NRC  
J.A. Olshinski - NRC  
D.M. Verrelli - NRC  
N.S. Reynolds - D&L  
R. Auluck - NRC  
WNP-2 Files

