


- NOTES:
1. FOR GEN. CONCRETE NOTES & TYP. DETAILS SEE DWG. 5749
 2. FOR HATCH COVER & CRANE DETAILS SEE DWG. 5855
 3. FOR SLAB & BEAM SCHD. SEE DWG. 5852 & 5853
 4. ELECT. OPENINGS TO BE FILLED WITH CONC. BY CONTRACT NO. 218 AFTER CONDUITS ARE IN PLACE.
 5. FOR SPLICE LENGTHS AT CONSTRUCTION JOINTS SEE NOTES DWG. 5851
 6. ALL WORK ON THIS DWG. IS BY CONT. 200A [EXCEPT AS OTHERWISE SPECIFIED]. PERMANENT MATERIAL WILL BE FURNISHED TO 200A CONTRACTOR, SEE SPECIFICATIONS. FOR CONTRACTS 210, 215, 218 WORK CONTRACTORS SHALL BOTH FURNISH AND INSTALL ALL MATERIALS.
 7. (E) DENOTES ELECTRICAL PENETRATION



ALL WORK ON THIS DRAWING IS QUALITY CLASS I WITH THE EXCEPTION OF THE FOLLOWING WHICH IS CLASSIFIED AS CLASS II:

- GRATINGS, CHECK PLATE, STRUCTURAL STEEL STAIRS & PLATFORMS
- HANDRAIL, TOE PLATES, LADDERS, FIRE SLEEVES (INCLUDING CONCRETE ANCHORS), ARMORING, ANGLES INCLUDING CONCRETE ANCHORS, EMBEDDED LADDER RUNGS

PRC APERTURE CARD

INFORMATION ONLY

BURNS AND ROE, INC. ENGINEERS AND ARCHITECTS ORADLE, N.J. LOS ANGELES, CALIF.	
STRUCTURAL DIESEL GENERATOR BUILDING MISC. SECTIONS & DETAILS	
WASHINGTON PUBLIC POWER SUPPLY SYSTEM HARFORD, MD.	
ENGINEER	AS NOTED
ARCHITECT	AS NOTED
DESIGNER	AS NOTED
DRAWN	AS NOTED
CHECKED	AS NOTED
APPROVED	AS NOTED
DATE	DATE
1	2
3	4
5	6
7	8
9	10
11	12
13	14
15	16
17	18
19	20

POOR ORIGINAL