

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8210060319      DOC. DATE: 82/09/28      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 BOUCHEY, G.D.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION  
 SCHWENCER, A.      Licensing Branch 2

SUBJECT: Commits to implementing mod of control logic on pressure interlocks of low pressure ECCS injection valves by fuel load. Commitment dependent on timely equipment delivery. Info closes SER Outstanding Issue 1.7(8).

DISTRIBUTION CODE: B001S      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

## NOTES:

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
NRR/DL/ADL		1	0	NRR LB2 BC		1	0
NRR LB2 LA		1	0	AULUCK, R.	01	1	1
INTERNAL: ELD/HDS2		1	0	IE FILE		1	1
IE/DEP EPDS	35	1	1	IE/DEP/EPLB	36	3	3
NRR/DE/AEAB		1	0	NRR/DE/CEB	11	1	1
NRR/DE/EQB	13	3	3	NRR/DE/GB	28	2	2
NRR/DE/HGEB	30	2	2	NRR/DE/MEB	18	1	1
NRR/DE/MTEB	17	1	1	NRR/DE/QAB	21	1	1
NRR/DE/SAB	24	1	1	NRR/DE/SEB	25	1	1
NRR/DHFS/HFEB	40	1	1	NRR/DHFS/LQB	32	1	1
NRR/DHFS/OLB	34	1	1	NRR/DHFS/PTRB	20	1	1
NRR/DSI/AEB	26	1	1	NRR/DSI/ASB	27	1	1
NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1
NRR/DSI/ETSB	12	1	1	NRR/DSI/ICSB	16	1	1
NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1
NRR/DSI/RSB	23	1	1	NRR/DST/LGB	33	1	1
REG FILE	04	1	1	RGN5		2	2
RM/DDAMI/MIB		1	0				
EXTERNAL: ACRS	41	6	6	BNL (AMDTS ONLY)		1	1
DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1
LPDR	03	1	1	NRC PDR	02	1	1
NSIC	05	1	1	NTIS		1	1



**Washington Public Power Supply System**

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

September 28, 1982  
G02-82-810

Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT NO. 2  
SAFETY EVALUATION REPORT, NUREG 0892, OUTSTANDING ISSUE  
1.7(8), PRESSURE INTERLOCKS ON EMERGENCY CORE COOLING  
INJECTION VALVES

Reference: Letter G02-82-631, G.D. Bouchey (SS) to A. Schwencer (NRC)  
"Safety Evaluation Report, NUREG 0892, Outstanding Issue  
1.7(8)" dated July 28, 1982

In the referenced letter, the Supply System committed to a modification of the control logic on the pressure interlocks of the low pressure ECCS injection valves. Based on recent discussions with the NRC, it is the Supply System's understanding that the NRC concurs with the proposed modification but is not satisfied with the hardware implementation schedule, viz, during the first refueling outage.

At the time that the Supply System response was drafted, it was not possible to commit to an earlier implementation date due to uncertainties in the final design configuration and procurement of qualified hardware. Since then, the basic design configuration has been completed. However, since hardware definition and subsequent procurement is not yet finalized, equipment delivery dates are not known.

In response to the NRC concern with the proposed schedule, the Supply System commits to implementing this change by fuel load and will make every effort to meet this goal. If this schedule is threatened due to delays in delivery of qualified equipment, it may be necessary to use hardware which is not fully qualified to IEEE requirements but has a qualification program either planned or underway. In addition, it may also be necessary to request other, as yet unforeseen, dispensation from the NRC to avoid delay of the WNP-2 licensing process.

B001




23

1944

Mr. A. Schwencer  
Page Two  
September 28, 1982  
G02-82-810

Unless notified otherwise, the Supply System will proceed under the premise that the proposed approach will satisfy the NRC concerns. The Supply System also reiterates its continuing commitment to responsive implementation of required changes within the constraints placed on it by extended procurement cycles which are currently being experienced.

Very truly yours,



G. D. Bouchey  
Manager, Nuclear Safety and Licensing

RLW/pb

cc: R. Auluck - NRC  
WS Chin - BPA  
R. Feil - NRC Site

