

WNP-2

ELECTRICAL SEPARATION.
PRACTICES

REV. NO.

0

DATE

12-3-82

PREPARED BY:

G.W. BRASTAD

Sharon Laporte
John J. Mallanda

REVIEWED BY:

HW Brasted

APPROVED BY:

John J. Mallanda

WNP-2
ELECTRICAL SEPARATION PRACTICES

	<u>Page No.</u>
I. Purpose	2
II. Electrical Separation Criteria	2
A. Definitions	2
B. Class 1E Redundant Circuit Design Requirements	5
1. Spatial Separation Between Raceways	5
2. Spatial Separation Within Enclosures and Equipment	9
3. Separation for Fail-Safe Systems	9
4. Raceway, Cable, Equipment, and Enclosures Identification	11
5. Transient Data Acquisition System (TDAS)	12
6. General Plant/PGCC Interface	12
7. Isolation Devices	13
C. Associated Circuit Design Requirements	13
1. Prime Circuits	13
2. Proximity Circuits	14
3. Prime and Proximity Circuit Identification	15
D. Non-Class 1E Circuit Design Requirements	16
III. Criteria Implementation	17
A. Class 1E Circuits	18
B. Prime Circuits	18
C. Non-Class 1E Circuits	19
D. Non-Class 1E, Non-Divisional Circuits	19
E. General Plant/PGCC Interface	20
IV. Field Verification	20
V. References	20
VI. Tables and Figures	21

I. Purpose

The purpose of this document is to clarify the WNP-2 electrical separation criteria, describe practices used to implement the criteria, and to provide sufficient information in a manner to simplify verification of implementation in the field. There are no differences in the design criteria between this document and the WNP-2 FSAR.

This document should be used by engineers, designers, contractors, QA/QC personnel and operations personnel.

II. Electrical Separation Criteria

A. Definitions

1. Class 1E

Class 1E is the safety classification of the electrical equipment and systems that are essential to emergency reactor shutdown, containment isolation, reactor core cooling, and containment and reactor heat removal, or otherwise prevent significant release of radioactive material to the environment.

2. Power Circuits

Power circuits provide electrical energy for equipment motive power and heating requiring 14.4 kV, 6.9 kV, 4.16 kV, 480 volts, 240 volts, 120/208 V AC, 250 and 125 V DC (see Table I for details).

3. Control Circuits

Control circuits use 120 V AC (or below) or 125 V DC (or below), and are designed to supply control power for plant systems. The largest control circuit protective device (fuse/breaker) has a 35 amp rating. The majority of the control circuits are intermittent in operation. Control circuits include the following functions (see Table I for details):

- a. 125 V DC or 120 V AC control to switchgear, control room and local panels, and logic interlock circuits.
- b. 125 V DC or 120 V AC control power to solenoids.
- c. Annunciator/computer digital circuits.
- d. Space heaters including motor heaters.

4. Instrumentation Circuits

Instrumentation circuits are low level analog or digital signals.

5. Low Energy Circuits

Low energy circuits are control and instrumentation circuits.

6. Isolation Device

An isolation device prevents an electrical event in one section of a circuit from causing unacceptable consequences in other sections of the circuit or other circuits.

7. Associated Circuits

Associated circuits are defined as either prime or proximity circuits as follows:

a. Prime Circuits

A Non-Class 1E circuit which receives power from a Class 1E source. The circuit begins at the load side of the source circuit protective device (isolation device), through the interconnecting cables, and up to the final connected load. The portion of a prime circuit which is routed in a Class 1E raceway is additionally termed "Associated By Proximity".

b. Proximity Circuits

A proximity circuit is a Non-Class 1E circuit which is routed (along any portion of its length) in a raceway with a Class 1E circuit or is contained in an enclosure with Class 1E circuits and physically routed less than 6" from a Class 1E circuit (without an appropriate barrier). The portion of the proximity circuit which is routed in a Class 1E raceway is termed "Associated By Proximity". If the circuit leaves the Class 1E raceway, the circuit is termed and treated as Non-Class 1E unless the circuit is also prime (see Figure 4).

8. Redundant

For the purposes of this document redundant shall refer to the collection of Class 1E circuits, components, equipment, etc. (system(s)) performing a specific plant safety function which is a backup to other Class 1E system(s) independently performing the same safety function. Safety functions are Emergency Reactor Shutdown, Containment Isolation, Reactor Core Cooling, Containment and Reactor Heat Removal, and Offsite Radioactive Release prevention. For example, the Low Pressure Core Spray System is redundant to the Residual Heat Removal System (Low Pressure Coolant Inspection mode) Loop C for the "Reactor Core Cooling" safety function.

9. Intruding Circuits

Intruding circuits are of two types: 1) Class 1E or prime circuits which enter equipment or an enclosure assigned to a redundant Class 1E division, 2) Redundant prime circuits which enter common equipment or enclosures assigned to a Non-Class 1E division; one of these becomes intruding. For example, Division A prime and Division B prime circuits within a Division A panel requires the Division B prime circuit be treated as an intruder.

10. Barrier

A barrier is material or a structure placed between redundant Class 1E or prime equipment or circuits to limit damage to Class 1E circuits from internally generated fires. Within enclosures and equipment barriers are Havg Siltemp tape or sleeving, conduits (flexible and rigid) and sheet metal enclosures or metal plates. Outside enclosures and equipment barriers are solid steel tray covers and bottoms, sheet metal panels, Thermolag insulation, and conduits (flexible or rigid).

11. Associated Circuits

11. Power Generation Control Complex (PGCC)

Associated circuits are defined as either prime or proximity circuits. The PGCC located in the Main Control Room is defined for the purposes of this document as a modular assembly of termination cabinets interconnected by floor sections comprised of multiple, separate cable ducts on which are mounted control room panels. The PGCC forms an interface between the incoming plant cables and control room panels.

The circuit begins at the load side of the source circuit. The periphery of the PGCC is defined as the subfloor area between the termination cabinets and the Main Control Room wall.

13. Direct Bridging

Direct bridging is defined as a circuit which routes between redundant Class 1E raceways (see Figure 1A). Direct bridging is prohibited.

14. Secondary Bridging By Proximity

Secondary bridging by proximity is defined as:

- Bridging of redundant Class 1E circuits by two (or more) Non-Class 1E (Division A, B, XXX1, XXX2, or XXX3) proximity circuits, routed together in a common enclosure or raceway, and each having part of their routing in a redundant Class 1E raceway (See Figure 1B).

Fig. 1B Bridging of Redundant Class 1E circuits by Non-Class 1E (Division A, B, XXX1, XXX2, or XXX3) proximity circuits within enclosures (system equipment). These proximity circuits may also be extensions of back circuits originating from Class 1E raceways (See Figure 1C) and safety functions. Safety functions are Emergency Reactor Shutdown,

15. Fail-Safe Systems. Reactor Core Cooling, Containment and Reactor heat removal and Offsite radioactive release prevention. These systems used to shutdown (SCRAM) the reactor are designed to fail safe upon loss of power (de-energize to operate). These systems are the Reactor Protection System (RPS) and those portions of the Neutron Monitoring System (NMS) i.e., Source Range Monitoring (SRM), Intermediate Range Monitoring (IRM), Average Power Range Monitoring (APRM), and Local Power Range Monitoring (LPRM) providing input to the RPS.

In addition, system inputs and logic associated with the containment isolation function are designed to be fail-safe.

16. Equipment assigned to a Non-Class 1E division one of these become... For the purposes of this document equipment is defined as panels and racks including open-faced instrument racks.

B. Class 1E Redundant Circuit Design Requirements


Each Class 1E component and interconnecting cabling shall be assigned to one of seven Class 1E divisions as noted in Table ITr. Class 1E components of one division are separated from Class 1E components of other redundant divisions. Minimum separation distances for trays, conduits and cables within enclosures are described below. Note that the separation distances specified are to preclude internally generated fire propagation between some redundant Class 1E divisions and do not consider effects of externally generated fires or pipe breaks and missiles.

1. Spatial Separation Between Raceways

a) General Plant Areas (Outside PGCC)

* Distances shown consider the ideal arrangement of two (2) raceways only. If more than two (2) raceways exist in any particular arrangement, physical separation distances chosen must be based on the complete configuration. Additionally, minimum distances are shown assuming that there are no equipment or materials in that distance that can aid in the propagation of fire.

(1) Minimum horizontal separation requirement between any two redundant Class 1E divisions is 3 feet. This is also applicable if one raceway is enclosed and the enclosed raceway is not lower than the open raceway. Also, refer to the redundant Class 1E raceways used Figure 12.1. (Source: NFPA 70, Art. 310.10)



(2) Minimum vertical separation requirements between any two redundant Class 1E divisions are shown below.



Barrier or solid bottom
 DIV I
 DIV II
 8' TRAY OR CONDUIT
 5' DIV II CONDUIT (TYPICAL)

THREE OR MORE } DIV II }
 SUPER TIER AND }
 NO AUTOMATIC } TWO OR LESS
 FIRE DETECTION } DIV II }
 & EXTINGUISHING }
 AVAILABLE } DIV II }

DIV II

[illegible]

(3) Where minimum separation requirements between two raceways of redundant Class 1E divisions are not met, one of the following methods shall be implemented. Class 1E components of one division are separated from Class 1E components of other redundant divisions. Minimum separation distances for trays, conduits, and cables within enclosures are described below. Note that the separation distances specified are to prohibit interdivision raceways installed parallel between redundant Class 1E divisions and do not consider effects of external generated fire or pipe breaks and missiles.



B = 12" Minimum or Flush to Ceiling

TRAY OR CONDUIT C = 12" Minimum or Flush to Floor

PER TRAY, CONDUIT D = 1" Minimum

NO MINIMUM

FIRE DETECTION (DIV I, DIV II)


Note 1 - No minimum separation distance is required between redundant division conduits or enclosed trays but they must not physically touch.

Vertical Separation


Where Class I/II Open/Enclosed Raceways Installed Parallel to each other and of redundant Class I/II divisions are not met, one of the following methods shall be implemented.

(a) Horizontal Separation: DIV I

1. Open/Enclosed Raceways Installed Parallel




2. Enclosed Raceways Installed Parallel (Type 1)



A = 12" Minimum or Flush to Wall.

Note 1: No minimum separation distance is required between redundant division conduits or enclosed trays but they must not physically touch.


- (4) Tray covers shall be used for all crossovers of redundant division raceway systems, except when the bottom raceway is a conduit. The schemes shown below shall be used regardless of the voltage level of the cables in a crossover raceway system.



"W" is defined as the nominal tray width of the widest tray involved.

3W = 3 times the nominal tray width or flush to a wall

SECTION A-A



- (5) Open raceways assigned to route Non-Class 1E power cables (Division A or B) shall be separated from all Class 1E raceways using the separation criteria specified in a). (1) through (4) above.

b) Unique Requirements For Certain General Plant Areas

1) Cable Spreading Room and Cable Chases

The minimum separation distance between open trays of redundant Class 1E divisions shall be one foot horizontally and three feet vertically. The minimum separation distance between conduits and open trays of redundant Class 1E divisions is one-inch with a barrier provided when the conduit is below or to the side of the open tray and three feet when the conduit is located above the open raceways. Where these distances cannot be maintained, fire barriers shall be installed. Automatic fire detection and suppression must be provided or these areas become General Plant Areas.

2) Periphery of PGCC

A modular floor raceway system is not provided in this area. Cables in this area shall be routed in grounded flexible conduit with 3 feet horizontal separation maintained between redundant Class 1E flexible conduits. Where this distance cannot be maintained, one of the redundant divisions shall be routed in rigid conduit. The redundant conduits shall not touch (a fire barrier may be used to physically separate the two conduits).

3) Class 1E Underground Duct System

Class 1E equipment located remotely from the plant (e.g., equipment located at the ultimate heat sink) is serviced by divisionally separated Class 1E underground duct systems and manholes. The underground duct system for Class 1E systems is constructed of steel encased in reinforced concrete. The minimum horizontal

3) Class 1E Underground Duct System (Cont'd)

separation between redundant duct banks measured from the bank edges is 18 inches. Redundant duct banks do not crossover. Separation within manholes is provided by barriers.

c) Power Generation ^{DIV 1 1" Min} Control Complex (PGCC)

Separation is provided by the design of the modular floor in the PGCC. The modular floor is latticed and constructed of steel "I" beams and rectangular steel tubes forming longitudinal and lateral raceways. These raceways interconnect the control panels (which are bolted on the modular floor) and the termination cabinets. The network, including transition and extension raceways, provides separation using vertical and/or horizontal barriers and fire stops. Miniducts (raceways within raceways) are of similar construction to the floor raceways and provide separation within the longitudinal raceways. Cables in the miniducts are routed in flexible metallic conduit or wrapped with Siltemp tape.

When it is necessary to route cables between PGCC sections which are not directly connected by floor raceways it is permissible to route these cables through the cable spreading room; a special set of raceways has been allocated for this use. The cables and raceways shall be considered part of PGCC and therefore are identified the same as those in PGCC.

2. Spatial Separation Within Enclosures and Equipment

Where devices of redundant Class 1E systems are mounted in or on the same enclosure or equipment, physical separation (six inches), barriers, or isolation devices shall be provided. In addition, separated or isolated terminal boards and wiring shall be provided. When it is necessary for a single device such as a relay to be connected to wiring from redundant Class 1E divisions, the intruding division wiring shall be routed immediately away from the device to attain the required six-inch separation or to the extent where a barrier can be installed. Within open faced instrument racks all wiring between terminal boxes and the instrumentation shall be routed in flexible metallic conduits.

3. Separation for Fail-Safe Systems

Outside of equipment and enclosures, circuits belonging to fail-safe systems or portions of systems designed to be fail-safe shall meet the following requirements:

- a) The fail-safe divisions do not provide redundant safety functions to the non-fail-safe divisions except as noted in 2) below. Therefore, in general, no separation is required between the non-fail-safe divisions (Div 1, 2, 3) and the fail-safe divisions (Div 4, 5, 6, 7). The following specific criteria applies to fail-safe circuits:

- 1) External to PGCC fail-safe circuits shall be routed in grounded conduit (rigid or flex) or totally enclosed raceways carrying only fail-safe cables/wires; the grounded raceways are provided only to preserve the fail-safe nature of these circuits.
- 2) Within PGCC fail-safe circuits shall be routed in grounded flexible metallic conduit carrying only fail-safe circuits and shall be assigned to raceways as described below.
- 3) Since the Nuclear Steam Supply Shutoff System logic outputs control Divisions 1 and 2 valves and PGCC contains no Division 4, 5, 6, or 7 raceways it is necessary to route the fail-safe cables with non-fail-safe cables. Hence, Divisions 4 & 6 cables are assigned compatibility with Division 1, and Divisions 5 & 7 with Division 2. These Divisions are compatible in General Plant Areas as well as in PGCC.

Considering the above, Division 1 raceways/cables/wires require no separation from Divisions 4 or 6 raceways/cables/wires; Division 2 raceways/cables/wires require no separation from Divisions 5 or 7 raceways/cables/wires. Divisions 4 and 6 shall be separated from Division 2 and Divisions 5 and 7 shall be separated from Division 1. Divisions 4, 5, 6, or 7 need not be separated from Division 3 except to preclude direct bridging between redundant Class 1E raceways.

b) RPS SCRAM Solenoid Cabling

Wires from both RPS trip system trip actuators to a single group of SCRAM solenoids are permitted to route in a single conduit. A single conduit shall not contain wires to more than one group of SCRAM solenoids. Wiring for the A and B solenoids for the same control rod can run in the same conduit. See Figure 2.

c) NMS and Main Steam Line Cabling

Cables routed through the containment penetrations are grouped so that failure of all cabling in a single penetration cannot prevent a SCRAM. This applies specifically to the NMS and main steam line inboard isolation valve position switch cables. See Figures 2 and 3.

d) RPS Power Supplies

Power supplies to systems which de-energize to operate require only that separation which is deemed prudent to ensure reliable operation. Therefore, the RPS motor generator sets output cabling are not required to comply with Class 1E separation requirements.

e) Four Division Separation

Wiring for the four RPS SCRAM group outputs and the NMS LPRM inputs shall be routed as four separate divisions. See Table XV and XVI and Figure 2.

- f) The NMS cabling in the area immediately underneath the reactor need not be completely routed in enclosed raceways nor separated in accordance with Section II.B.1a due to space limitations and the need for cable flexibility. ~~unshielded cables are grounded raceways are provided only to preserve the~~
- g) Class 1E logic inputs to the RPS and Containment Isolation System from main steam turbine process and status sensing instrumentation (Load Rejection or Turbine Trip), Turbine Generator Building leak detection and Main Steam Tunnel high radiation instrumentation, their associated instrument racks, cabling and raceways are located in the Turbine Generator Building. This equipment, even though located in a non-seismic Category I structure, shall be mounted to seismic Category I requirements and all related cabling routed to Class 1E requirements.
4. Raceway, Cable, Equipment, and Enclosure Identification
- a) Class 1E cables routed within conduits need not be identified within the conduit. ~~These are compatible in General Plant Areas as~~
- b) Class 1E General Plant raceways shall be uniquely identified with a color coded marker every 15 feet; at the beginning, end, at pull boxes, and discontinuities (walls, structures, etc.) as shown in Table III. ~~These are compatible in General Plant Areas as~~
- c) Class 1E cables routed in Division 1 through 7 raceways in General Plant Areas shall be uniquely identified with a color coded marker every 15 feet and at their terminations as shown in Table III. These markers are provided on the cables up to the first termination within equipment and enclosures.
- d) Class 1E cables routed in PGCC raceways shall be uniquely identified with a color coded marker every 5 feet near the cable divisional marker as shown in Table V. These markers are provided on the cables up to the first termination within equipment and enclosures. PGCC longitudinal raceways shall be identified with a color coded marker every 5 feet. Each lateral raceway shall be identified at the longitudinal raceway lip centered above the lateral raceway.
- e) Within enclosures and equipment Class 1E intruder circuits shall be uniquely identified with a color coded marker at 12" + 2" inch intervals as shown in Table VII. Additionally, to differentiate between cables and wires, color coded wire markers are utilized as shown in Table VI.
- f) Circuits that have been upgraded from Non-Class 1E to Class 1E and are already installed in raceways shall be identified with a Class 1E color coded marker at terminations, pull boxes, and entrances and exits to raceways. Upgraded cables shall be routed in Class 1E raceways. Cable installation records shall be reviewed to provide assurance that these cables are routed in Class 1E raceways and installed to Class 1E requirements (cable installation parameters). Otherwise, megger and continuity tests shall be performed, termination and routing reinspected to Class 1E requirements, and documentation prepared verifying the upgrade.

- g) Equipment and enclosures shall be uniquely identified with two color coded markers; one marker with the identification number and a second with the assigned separation division of the residing components, cables, and wires. These markers shall be color coded as shown in Tables III, IV and V. Individual components located on or in equipment and enclosures require identification markers (not necessarily color coded), but need not have individual divisional separation markers. For example, an instrument rack shall be uniquely identified with color coded identification marker and a divisional separation marker. However, each separate instrument need not have a color coded identification marker or a divisional separation marker.
- h) Within open faced instrument racks wiring from terminal boxes to individual instruments is routed in flexible conduits. These conduits need not be identified with a cable identification number or with a divisional separation marker.
- i) Two different equipment, enclosure, and cable identification schemes exist within PGCC; one for those provided within the General Electric NSSS scope and the other for those provided within the Balance of Plant scope. Refer to Tables IV, V, XIII, and XIV for details of these schemes.

5. Transient Data Acquisition System (TDAS)

The TDAS is a Non-Class 1E, computer based, data collection and reduction system which receives the majority of its inputs from Class 1E systems. The system shall be designed as follows:

- a. All TDAS input circuits within raceways shall be identified and routed to Class 1E requirements up to a remote isolation device. From the isolation device to the remote multiplexer the circuits are considered to be Non-Class 1E.
- b. Remote multiplexer outputs are transmitted to the computer via a fiber optic cable which is inherently an isolation device. The fiber optic cable, therefore, can be routed in any raceway without regard to separation criteria.
- c. TDAS remote multiplexers are supplied from a Non-Class 1E 24VDC current limiting power supply. The power source to this power supply is Class 1E with a Class 1E isolation device. The circuit to the power supply shall be routed as prime (see Section II.C.1). Downstream of the power supply, the circuits shall not be routed as prime.

6. General Plant/PGCC Interface

For the purposes of cable identification General Plant Area cabling entering the PGCC interfaces with PGCC cabling at termination modules within the termination cabinets. This cabling shall be designed to the divisional compatibilities and designations as shown in Tables XIII and XIV.

7. Isolation Devices

Where circuit isolation devices are required, consideration shall be given to types of devices available and the type of circuit protection required.

Isolation device types shall be applied as follows:

- a) Class 1E power circuits shall be isolated from Non-Class 1E circuit faults by devices which provide adequate circuit interrupting capability. Circuit breakers tripped by an accident signal are preferable. However, where Non-Class 1E circuits are helpful to operations personnel following an accident, coordinated circuit breakers or fuses actuated by time overcurrent trips shall be used. Trip characteristics shall be such that for all faults the downstream device will interrupt current prior to trip of any upstream breaker or fuse. Various combinations of fuses and circuit breakers may be used.

In addition to current interrupting devices, current limiting devices may be used either alone or in conjunction with interrupting devices to isolate power circuits. Current limiting shall be accomplished by using current limiting or isolation transformers.

- b) Low energy Class 1E circuits shall be isolated from redundant low energy Class 1E circuits or from Non-Class 1E circuits by devices such as relays, isolation amplifiers, resistors, fuses, circuit breakers, or current transformers.

When it is necessary to interface between redundant Class 1E divisions, relay coil-to-contact isolation is acceptable. That is, the coil of the relay may be powered from one division and the relay contacts can be used for interface with a redundant division.

The contacts shall not be used in more than one redundant division circuit since this condition would be contact-to-contact separation which is not acceptable.

Class 1E instrumentation circuits may be isolated from Non-Class 1E portions of the circuit by a fuse, resistor(s), or an isolation amplifier.

C. Associated Circuit Design Requirements

1. Prime Circuits

- a. Redundant prime circuits shall be physically separated with the same requirements as redundant Class 1E circuits (See Section II.B) from the load side of the source circuit protective device to the final connected load except as noted in c. below. For example, a Division A' circuit shall be separated from a Division B' circuit and a Division 2 circuit; a Division B' circuit shall be separated from a Division A' circuit and Division 1 circuit.
- b. Class 1E power sources shall be protected from failures within prime circuits by a Class 1E isolation device.
- c. Deviations to prime circuit separation criteria implementation are as follows:

- 1) Circuits downstream of Class 1E isolation devices (circuit breakers) which are tripped by an accident signal shall be treated as Non-Class 1E and not as prime.
- 2) Emergency lighting, obstruction lighting, main control room normal lighting, meteorological tower supervisory, and fire isolation protection circuits shall be provided with two series Class 1E isolation devices (circuit breakers/fuses). Downstream of the second isolation device the circuit shall be treated as Non-Class 1E and not as prime.
- 3) A single circuit supplies power to the Technical Support Center (TSC). This circuit shall be routed as prime to the Motor Control Center incoming breaker (Non-Class 1E) located in the TSC. Downstream of this breaker the circuit shall be treated as Non-Class 1E and not as prime.
- 4) Circuits supplying power to the 24VDC power sources for the Transient Data Acquisition System remote multiplexers and the General Electric scope Regulatory Guide 1.47 displays shall be routed as prime from the Class 1E isolation device (circuit breaker) to the current limiting 120VAC/24VDC power supply. Downstream of this power supply the circuits shall be treated as Non-Class 1E and not as prime.
- 5) Circuits supplying power to other Regulatory Guide 1.47 displays from the Division 1 and 2 24VDC batteries shall be treated as Non-Class 1E and not as prime.
- 6) The Non-class 1E inverters (IN-1, Security System, and TDAS) input power circuits from the Class 1E 125VDC battery shall be treated as prime to the inverter. Downstream of the inverter the output circuits shall be treated as Non-Class 1E and not as prime.

2. Proximity Circuits

Proximity circuits when routed in a Class 1E raceway ("Associated by Proximity") shall meet the same physical separation criteria as that applied to the Class 1E circuits as follows.

 - a. Routing criteria for proximity circuits are as shown in Tables X, XI, and XII external to PGCC and Table XIV within PGCC. Proximity circuits may also be prime circuits. Refer to Section II.C.1 for prime circuit separation criteria.
 - b. Proximity circuit sections routed in Non-Class 1E raceways shall be treated as Non-Class 1E and have no specific separation criteria applied except as described in Sections II.B.1.a.5 and II.C.1 (See Figure 4).
 - c. Within equipment or enclosures, no specific separation criteria is applied to proximity circuits unless they are also prime circuits.

- d. Bridging Circuits
- 1) Class 1E circuits, prime circuits, and proximity circuits, as shown in Figure 1A shall not bridge between redundant Class 1E raceways. Design control to alert designers of, and potential for, cable direct bridging is provided by Note 6 in the computerized cable schedule (B&R Drawings E550 and Class E551). Refer to Table (XIV) Examples 1c through 4. Unstream of the general isolation device the circuit shall be unstream of
 - 2) Secondary bridging within Class 1E equipment or enclosures is allowed for low energy circuits as shown in Figure 1C.
 - 3) Secondary bridging by proximity circuits is allowed to occur within Non-Class 1E or Non-Divisional raceways as shown in Figure 1B. It is acceptable to route Divisions A, B, XXX1, XXX2, and XXX3 cables together in the same PGCC Non-Divisional raceway.
- e. Note 5 of the computerized cable schedule is assigned to any Non-Class 1E cable with the potential to become a direct bridge. This occurs when this cable is routed in a Class 1E raceway and has a continuing section routed in a Non-Class 1E raceway. For example, Note 5 would be applied to a Division A cable routed in a Division 1 raceway and subsequently routed into a Non-Divisional PGCC raceway; potentially this cable could be routed into a Division B raceway and then into a Division 2 raceway creating a direct bridge. and 1. 24VDC systems. 2. 120VAC systems.

3. Prime and Proximity Circuit Identification

- a. Prime cables routed in Division A and B raceways in general plant areas shall be uniquely identified with a color coded marker every 15 feet as shown in Table IV except as follows:
 - 1) Prime cables routed in conduit need not be uniquely identified with the color coded marker.
 - 2) Enclosed and open raceways shall be identified every 15 feet, at discontinuities, at pull boxes, and at end points with the appropriate prime color coded marker. If Class 1E cables are also routed within the same enclosed raceway then the raceway will be identified as Division 1 through 7, and no prime marker is required.
 - 3) Cables that have been upgraded from Non-Class 1E to prime and are already physically installed in plant raceways shall not be retrofitted with the prime color coded marker except at all terminations, pull points, and entrances and exits to raceways.
- b. Prime cables routed in PGCC raceways shall be uniquely identified with a color coded marker every 5 feet near the cable divisional marker as shown in Table V except as follows:

Circuits that have been upgraded from Non-Class 1E to prime and are already physically installed in the PGCC raceways shall be identified with the prime color coded marker only at entrances and exits to PGCC raceways and at terminations within enclosures. Design control to alert designers of a

- c. Within Class 1E enclosures and equipment, intruding prime circuits shall be identified the same as Class 1E intruding circuits as in II.B.4.e above.

- d. Within Non-Class 1E multi-divisional enclosures and equipment assigned to either Division A, B, XXX1, or XXX2, an intruding prime circuit shall be uniquely identified as in II.B.4.e above.

- e. Proximity circuits shall have a unique color coded marker as described in Table IV.

- f. Conduits which contain prime and proximity cables with a Division 1 through 7 compatibility shall be identified with the appropriate divisional separation marker even if these conduits route to Non-Class 1E enclosures or equipment.

D. NON-CLASS 1E CIRCUIT DESIGN REQUIREMENTS

Non-essential circuits or portions of circuits, which are not prime or "Associated By Proximity" are termed and treated as Non-Class 1E. Refer also to Figure 4. Electrical separation criteria shall not apply to Non-Class 1E circuits except as noted in II.B.1.a).(5) or below for utility power circuits. Non-Class 1E circuits shall be assigned to Non-Class 1E divisions as shown in Table XIV. Non-Class 1E raceways need not be physically separated from each other or from any Class 1E raceways unless they contain power circuits. Deviations to strict divisional assignments are as follows:

1. Digital computer signals in the reactor building are routed in Class 1E divisional raceways as applicable by the device being served. Non-Class 1E digital signals in other areas are routed in instrumentation raceways of Division B irrespective of device division being served.
2. Analog computer signals in the reactor building are routed in Class 1E divisional raceways as applicable by the device being served. Non-Class 1E analog signals in other areas are routed in instrumentation raceways of Division A.

Non-Class 1E Division A and B raceways, excepting conduits, do not exist within the Reactor Building or the Cable Spreading Room. This requires that most Non-Class 1E cables be routed in Class 1E raceways; these cables become "Associated by Proximity". Division A and B conduits routed within these areas are designated with separation markers as shown in Table IV. If cables within these conduits have a Division 1 or 2 "compatibility" then the separation markers shall be in accordance with Class 1E requirements (see Section II.B.4) the same as Class 1E insulating covering as in Table IV above.

Within PGCC, raceways are designated Division 1, 2, 3, or Non-Divisional. No Division A or B raceways exist. Thus, Division A and B cables shall be assigned to Division 1 and 2, respectively, or to a Non-Divisional raceway. All cables shall be uniquely identified as in Table IV above.

Within Class 1E Main Control Room panels Non-Class 1E utility power circuits shall be separated by 6" or a barrier from all other wiring.

Non-Class 1E circuits need not be uniquely identified inside enclosures or equipment except for wires as shown in Table VI. All wires shall

be uniquely identified with color coded markers even if these are Non-Class 1E cables routed in open raceways shall be uniquely identified as described in Table IV. Non-Class 1E cables shall be tagged with color coded markers at their terminations, pull points, entrances and exits to raceways, and every 100 feet. Division A and B raceways are tagged every 100 feet at discontinuities, entrances and exits to rooms, pull boxes, and end points.

Also to Figure 1. Electrical separation criteria shall not apply. Non-Class 1E cables routed in PGCC raceways shall be uniquely identified with a cable I.D. marker every 10 feet and with a color coded cable separation marker every 5 feet as shown in Table V. Raceways need not be uniquely identified. Each cable shall be uniquely identified. The Non-Class 1E cables which wholly route in compatible Non-Class 1E raceways (Div. A or Div. B) are routed in accordance with cable routing criteria stated in Tables X, XI and XII. Division markers for equipment/raceways and cables are color coded per Table IV.

III. Criteria Implementation

The purpose of this section is to assist the design engineer in the implementation of the design criteria. The principal elements for design consideration include: Analog computer signals in the Reactor Building are routed in Class 1E divisional raceways as applicable by the device being served.

- ° Device service requirements
- ° Providing an appropriate power supply based on device service requirements,
- ° Assigning the cables to meet device/power source compatibility,
- ° Routing of the cables in raceways to meet the separation criteria requirements, and
- ° Enclosure/equipment/raceway/cable identification.

The following details explain the steps to be followed to assure proper implementation of the criteria.



11

12

13

14

15

A. Class 1E Circuits

Class 1E systems are listed in Table II. routed in Class 1E raceways. These cables become associated by proximity. Division A and B conductors route

All Class 1E electrical equipment is tagged with an equipment number. In addition, a division identification marker is provided which indicates the assignment to one of seven divisions (Divisions 1, 2, 3, 4, 5, 6, and 7). This equipment division marker is inscribed with color coded characters using the color scheme shown in Tables III, XIII, and XIV for all equipment external to PGCC and per Table V for equipment internal to PGCC including control room panels.

All devices required to preserve Class 1E functions are supplied from Class 1E power sources of the compatible division as shown in Table II. For example, RHR Loop A is supplied from the Division 1 Class 1E power source.

The assignment of a proper cable number is key to the implementation of separation criteria. Each cable number is guided by Class 1E division designation, the equipment of origin, and the circuit/cable identification number. The methodology of cable number assignment and the significance of various characters are provided in Tables VIII, XIII, and XIV. In addition to the unique identification number, each cable is also identified with a divisional marker as shown in Tables III and V. Non-Class 1E cables shall not be routed in PGCC raceways.

Routing criteria for Class 1E cables in General Plant Area raceways is provided in Tables X, XI and XII. Table XIII provides the routing requirements inside the PGCC raceways. As indicated in these tables, routing of Class 1E cables in non-compatible division raceways or Non-Class 1E raceways is not permitted.

Divisionalized raceways are designed to meet the criteria requirements as stated in Section II.B.1. The raceway identification scheme is provided in Tables III and V.

Each class 1E enclosure is identified with an appropriate divisional marker to show the residing Class 1E division of the internal cables and wires. Intruder circuits are identified with a color coded marker in accordance with Table VII.

B. Prime Circuits

Prime circuits are identified on the cable schedules by a A'1 or B'2 designation in the "SFTY CLR" field. See Table IX Column 14 for details. A'1 signifies a cable that connects a Class 1E Division 1 power source to a Non-Class 1E Division A device. Similarly B'2 signifies a cable that connects a Division 2 power source to a Division B device.

The Division 1 power source is never connected to a Division B device via a B' cable. Similarly, a Division 2 power source is never connected to a Division A device via an A' cable.

All prime cables and the Non-Class 1E divisional raceways in which they route, in addition to the Non-Class 1E identification markers, are identified with a checkered marker as described in Tables IV and V.


A'1 and B'2 circuits are not routed in the same raceway. The separation requirements for the prime cables in enclosures is the same as that for the Class 1E cables as shown in Table VII.

Within PGCC prime circuits are required to be routed in Class 1E compatible divisional raceways as shown in Table XIV.

C. Non-Class 1E Circuits

Non-Class 1E circuits, such as Turbine Generator, plant service circuits, etc. are assigned to either Division A or Division B. As described in Section II.D, Non-Class 1E raceways for routing of Non-Class 1E cables do not exist in all plant areas. Therefore, certain Non-Class 1E cables (prefixed with A or B) are required to be routed in Class 1E raceway systems. Such cables are treated as "Associated by Proximity" and are divisionally marked as shown in Tables IV and V. Table V for cables internal to PGCC including control room wiring.

Within PGCC, Division A, Division B, XXX1, 2 and 3 Non-Class 1E circuits are allowed to be routed together in a Non-Divisional raceway. Precautions must be taken to assure that these circuits do not cause direct bridging. Refer to Table XIV for further discussion.



Detail 1 illustrates the treatment of a proximity cable with sections routed in both Class 1E and Non-Class 1E raceways. Due to the programming limitation of the computerized cable schedule, such a cable is treated in two sections. The section routed in the Class 1E raceway is assigned a type, a divisional compatibility, and an AXXX - 9000 series number in the cable schedule. This entry (see Table IX, Column (2)) is developed as shown in Table VIII, Item (2). The cable destination is called out to be TP - an imaginary Transition Point - with a note that the cable continues to be identified with a consecutive number. Refer to Table IX, Column (4) for details. The portion of the cable which is routed in a Non-Class 1E raceway has type/cable compatibility noted in Column 2 of Table IX. This section of the cable is assigned a consecutive cable number. The 9000 series cable as described above are color coded as shown in Table IV. Note that both consecutive cable numbers appear along the entire length of the cable in the Class 1E as well as the Non-Class 1E raceways.

D. Non-Class 1E, Non-Divisional Circuits

All plant cables which are Non-Class 1E and Non-Divisional are assigned to Division A. There are certain systems such as the security system, fire protection, lighting, communications etc. which are not assigned to a division. Identification requirements for these systems are noted in Item 2 of Table IV.

E. General Plant/PGCC Interface

The requirements of General Plant/PGCC interface are shown in Table XIII and XIV. GE NSSS circuit design is based on the general details provided in Tables XV and XVI.

IV. Field Verification

To be provided in Revision 1 to this document.

V. References

WNP-2 FSAR Section 8.3

Contract 218 Specification

General Electric Specification 22A7416

TABLE I
POWER/CONTROL CABLE CLASSIFICATION

SERVICE VOLTAGE (VOLTS)	LOAD TYPE								
	MOTORS - ALL EXCEPT SMALL MOTORS	MOTOR-OPERATED VALVES	SOLENOID VALVES	SPACE HEATER (INC. MOTOR HEATER)	PROCESS HEATER	TRANS. (INC. PWR. AND LIGHT 'G.)	FDR'S TO SWG'R. & LOC. CONT. PANEL (SEE NOTE 2)	METERING, PROTECTION & CONTROL CKTS.	SMALL MOTORS (SEE NOTE 1)
120 VAC 125 VDC & BELOW	P	P	C	(See Note 2) C (up to 900W)	P	P	C (up to 35A circuits)	C	C
120 VAC 125 VDC & BELOW	P	P	C	P	P	P	P & C	C	NA
ABOVE 120 VAC 125 VDC	P	P	NA	P	P	P	P	NA	NA

NOTES:

1. INCLUDED ARE: ELECTRO HYDRAULIC OPERATORS (EHO'S), HVAC DAMPERS, NMS STARTUP RANGE DETECTOR DRIVE MOTOR, MOTORS UP TO 1/3 HP.
2. CONTROL DESIGNATION IS TO BE RETAINED FOR CABLES REQUIRING SIZES LARGER THAN #10 AWG FOR VOLTAGE DROP REDUCTION.

LEGEND:

P - POWER
C - CONTROL
NA - NOT APPLICABLE

The recommendations of General Engineering and Research, Inc. are based on the general details provided in Table I. The design of cables is based on the general details provided in Table I.

TABLE 11

ASSIGNMENT OF SYSTEMS TO DIVISIONS OF SEPARATION

<u>Division 1</u>	<u>Division 2</u>	<u>Division 3</u>
RHR A	RHR B	HPCS
LPCS	RHR C	Standby Emergency Power 3
Containment Outboard Isolation Valves	Containment Inboard Isolation Valves	125 VDC Battery 3
Standby Emergency Power 1 RCIC	Standby Emergency Power 2	HPCS Service Water
Automatic Depressurization Div. 1 controls	Automatic Depressurization Div. 2 controls	Safety-Related Display Instr. 3
Standby Gas Treatment (Loop 1)	Standby Gas Treatment (Loop 2)	
250 volt DC Battery		
125 volt DC Battery 1	125 volt DC Battery 2	
24 volt DC Battery 1	24 volt DC Battery 2	
Standby Service Water Pump A	Standby Service Water Pump B	
MSTV-LCS (Inboard)	MSTV-LCS (Outboard)	
Leak Det. System 1	Leak Det. System 2	
CAC 1	CAC 2	
Cont. Inst. Air 1	Cont. Inst. Air 2	
SLCS 1	SLCS 2	
Mn. Cont. Rm. HVAC 1	Mn. Cont. Room HVAC 2	
Remote Shutdown 1	Remote Shutdown 2	
RPT 1 Output	RPT 2 Output	
Safety-Related Display Instr. 1	Safety-Related Display Instr. 2	
Suppression Pool Temp. Monit. 1	Suppression Pool Temp. Monit. 2	
Power & Control for Selected non-Class 1E Equipment (prime circuits)	Power & Control for Selected non-Class 1E Equipment (prime circuits)	
Fuel Pool Cooling and Cleanup 1	Fuel Pool Cooling and Cleanup 2	
Reactor Bldg. Pressure Control 1	Reactor Bldg. Pressure Control 2	
Drywell and Head Area Recirculation Fans 1	Drywell and Head Area Recirculation Fans 2	

ASSIGNMENT OF RPS, NSSSS AND NMS TO DIVISIONS OF SEPARATION

(FAIL-SAFE WIRING)

<u>Division 4⁺</u>	<u>Division 5*</u>	<u>Division 6⁺</u>	<u>Division 7*</u>
RPS A1	RPS A2	RPS B1	RPS B2
NSSSS A1	NSSSS A2	NSSSS B1	NSSSS B2
NMS A	NMS C	NMS B	NMS D

+ Compatible with Division 1

* Compatible with Division 2

TABLE III

DIVISION MARKERS FOR CLASS 1E EQUIPMENT, RACEWAYS, & CABLES EXTERNAL TO PGCC

RACEWAY TYPE	CABLE DIVISION	CABLE DIVISION MARKING CHARACTER	RACEWAY DIVISION MARKING CHARACTERS	EQUIPMENT/RACEWAY/ CABLE MARKER	
				BACKGROUND COLOR	CHARACTER COLOR
H,P,C,S	1	DIV. 1	*DIV1	YELLOW	BLACK
H,P,C,S	2	DIV. 2	*DIV2	ORANGE	BLACK
H,P,C,S	3	DIV. 3	*DIV3	RED	BLACK
R,C,S	4	CHA1	*CHA1	LT. BLUE	RED
R,C,S	5	CHA2	*CHA2	GREEN	RED
R,C,S	6	CHB1	*CHB1	DRK. BLUE	RED
R,C,S	7	CHB2	*CHB2	BROWN	RED

Raceway Types

- H - High Volt Power - 4.16 KV and above
- P - Power - 480/240/208/120 V AC
250/125 V DC
- C - Control-120 V AC/125 V DC and below
- S - Signal
- R - RPS Scram SOV Raceway

*Raceway type letter is utilized at beginning of marking characters.

Example: PDIV1 = Power Raceway, Division 1

Typical Division 1 Markers (Yellow Background)

1LPCS-5 DIV. 1

Cable Marker

The Cable Marker Includes
Both the Cable Number &
The Division Marking
Characters

*DIV1

Raceway, Pullbox, etc.
Marker

(Voltage Level is Added
For Above 600 V
Application)

DIV. 1

Equipment Marker

Black Characters
(Typical)

TABLE IV

Page 1 of 2

DIVISION MARKERS FOR PRIME AND NON-CLASS 1E ENCLOSURES, EQUIPMENT, RACEWAYS, AND CABLES

EXTERNAL TO PGCC

DIVISIONAL MARKER	MARKER BACKGROUND COLOR	CHARACTER COLOR	E550/E551 CABLE COMPATI- BILITY	REPRESENTATIVE CABLE NUMBER	CABLE MARKER BACKGROUND COLOR	E550/E551 REFERENCE NOTES	PRIME CIRCUITS (NOTE 2)	
							E550/E551 SAFETY CLR FIELD	ADDITIONAL CHECKERED MARKER
*DIV A	Silver	Black	A	AMISC402	Silver	-	A'1	Red/White
			1	(NOTE 1) AMISC9001	Silver/ Yellow	**		
*DIV B	Gold	Black	B	BMISC402	Gold	-	B'2	Green/White
			2	(NOTE 1) BMISC9001	Gold/ Orange	**		

Notes

*See Note on Table III

**See Table VIII, Page 4, Note 5

See Page 2 for Notes.

Equipment Markers for Non-Class 1E Devices

- Equipment marker for Div..A separation class is - Black characters on Silver background.
Equipment marker for Div. B separation class is - Black characters on Gold background.
- All non-divisional equipment, raceways and cables shall be identified by a tag having black characters on a white background.

DIVISION MARKERS FOR NON-CLASS 1E EQUIPMENT, RACEWAYS AND CABLES
EXTERNAL TO PGCC

NOTES

- 1.a. A Non-Class 1E 9000 series cable is routed partially or wholly in a Class 1E raceway (Associated by Proximity).
 - b. A Non-Class 1E cable, which is physically not separated from a Class 1E cable within its equipment of origin or destination, but is never routed in a Class 1E raceway, is also assigned with a 9000 series number. These cables are marked with dual color tags as stated above for a 9000 series cable. However, such cables are not considered to be "Associated by Proximity". This is implemented by "Non-divisional (Div. A or Div. B) cable compatibility" in E550/551 cable schedules.
- 2.a. Prime cables connect Non-Class 1E loads to Class 1E power sources.
A'1 signifies Div. 1 power feeder to Non-Class 1E Div. A device.
B'2 signifies Div. 2 power feeder to Non-Class 1E Div. B device.
A'2 & B'1 circuits are not permitted.
 - b. An additional checkered marker, as stated in the table, is applied to prime cables as well as to the Non-Class 1E raceways carrying prime cables.

TABLE V

DIVISION MARKERS FOR EQUIPMENT, RACEWAYS, CABLES
IN PGCC*

PGCC Divisional Separation Class		Circuit Categories			CABLE MARKERS			PGCC raceway/equipment marker lettering - lettering color is black.	PGCC raceway/equipment/cable marker background color.	
		Class 1E	Associated By Proximity	Non Class 1E	Cable Separation Categories as Shown On Cable ID Marker	CABLE SEPARATION MARKER				Prime cables have an additional checkered marker with this color scheme.
						Cable Separation Categories as Shown On Cable Separation Marker	Lettering Color			
1	X			RPS-A1	RPS-I	RED	N/A	DIV 1	YELLOW	
	X			DIV-1A	DIV I	BLACK				
	X			RPS-B1	RPS-I	RED				
	X			DIV-1B	DIV I	BLACK				
	X			ESSI	ESS I	BLACK				
	X			NSSI	NSS I	BLACK				
	X			SI,CI	DIV I	BLACK				
		X		XXXI	N/A	N/A	RED/WHITE			
		X		DIVA	N/A	N/A	RED/WHITE			
2	X			RPS-A2	RPS-II	RED	N/A	DIV 2	BLUE	
	X			DIV-2A	DIV II	WHITE				
	X			RPS-B2	RPS-II	RED				
	X			DIV-2B	DIV II	WHITE				
	X			ESSII	ESS II	WHITE				
	X			NSSII	NSS II	WHITE				
	X			SII,CII	DIV II	WHITE				
		X		XXXII	N/A	N/A	GREEN/WHITE			
		X		DIV B	N/A	N/A	GREEN/WHITE			
3	X			ESSIII	ESSIII	WHITE	N/A	DIV 3	GREEN	
		X		XXXIII	N/A	N/A	BLUE/YELLOW			
	X			S/CIII	DIVIII	WHITE	N/A			
Non-Div		X		XXX1	N/A	N/A	N/A	N/A	WHITE	
		X		XXX11						
		X		XXX111						
		X		DIV A						
		X		DIV B						

*This table includes control room panel markers even though these panels are not defined as part of PGCC.

TABLE VI
INTERNAL PANEL WIRE IDENTIFICATION

For the purpose of differentiating between wires and cables, all individual conductors of a multiconductor cable shall be defined as wires. In addition, single conductor cables 10 AWG and smaller shall be defined as wires within equipment and enclosures.

Wire markers shall be required only where wires from 2 or more cables terminate to a device.

The wires of prime cables requiring wire markers for traceability shall be identified with the appropriate prime cable marker installed in a flag fashion adjacent to each wire marker.

The color of the character and marker sleeve background shall be derived from the cable number and prefix as follows:

<u>Cable Functional Division</u>		<u>Wire Marker</u>	
<u>Prefix & (No.)</u>		<u>Character Color</u>	<u>Background Color</u>
1		Black	Yellow
2		Black	Orange
3		Black	Red
4		Red	Gray
5		Red	Green
6		Red	Blue
7		Red	Tan
A		Red	White
B		Green	White
A (9000)		Red	White/Yellow
B (9000)		Green	White/Orange

TABLE VII

INTRUDER CABLE MARKER

Each enclosure is identified with an appropriate divisional marker to show the residing division of the internal wires/cables. If a Class 1E or a prime cable intrudes into the enclosure of a redundant Class 1E division, or a prime cable intrudes into a Division A, B, XXX1, XXX2 enclosure with redundant prime cables then that cable and the internal wiring connected to such cable shall be additionally identified with striped marker tape using the following color scheme:

<u>Intruding Cable Marker Divisional Assignment</u>	<u>Striped Marker Color Code</u>
1, 4, 6, A', XXX1	Yellow/White
2, 5, 7, B', XXX2	Blue/White
3, XXX3	Green/White

All cables identified as intruding cables within equipment/enclosure are identified with a striped marker, as stated above, every 12 + 2 inches beginning at the panel entrance point and continuing to the internal wire string associated with each conductor.



11

EXPLANATORY INFORMATION CONCERNING CABLE ROUTINGCABLE LEGEND

The legend for the column identification in Table IX is as follows:

(1) CABLE NUMBER

Cable numbers have ten spaces allocated. Five spaces before the dash and four spaces after the dash. Each space has a specific meaning, as described below.

FIRST SPACE

1 DIVISION 1
2 DIVISION 2
3 DIVISION 3
4 DIVISION 4
5 DIVISION 5
6 DIVISION 6
7 DIVISION 7
A DIVISION A
B DIVISION B

SIXTH SPACE

Always to be the Dash (-)

SEVENTH, EIGHTH, NINTH & TENTH SPACE

Numbers 1 thru 9999 as required

SECOND, THIRD, FOURTH & FIFTH SPACE

System or Equipment Identification -
The following are typical examples:

ADS AUTOMATIC DEPRESS. SYSTEM
RHR RESIDUAL HEAT REMOVAL
IR1A INSTRUMENT RACK 1A
M7BA MOTOR CONTROL CENTER, NO. MC-7B-A
MISC MISCELLANEOUS
P8AE POWER PANEL, NO. PP-8A-E
SH5 SWITCHGEAR 6.9 kV (HIGH), NO. SH-5
SM7 SWITCHGEAR 4.16 kV (MEDIUM), NO. SM7
SL71 SWITCHGEAR 480 V (LOW), NO. SL-71

EXAMPLES OF CABLE NUMBERS:

1M7BA-221 = 1 (DIV. 1) M (MOTOR CONTROL CENTER) 7BA (MCC NO.) 221 (CABLE NO.)

TABLE VIII (Continued)

Page 2 of 5

2RHR-222 = 2 (DIV. 2) RHR (SYSTEM) .222 (CABLE NO.)

(2) T/C (TYPE AND COMPATIBILITY)

T = TYPE OF RACEWAY WHICH CABLE IS COMPATIBLE TO IS AS FOLLOWS:

P POWER	C CONTROL
H HIGH VOLT: (6.9kV, 4.16kV)	S SIGNAL
R RPS	Rc RPS SCRAM SOV RACEWAY

C = COMPATIBILITY (OUTSIDE OF PGCC) WHICH IS AS FOLLOWS:

1 COMPATIBLE CABLES ARE ROUTED IN DIV 1 RACEWAY SYSTEM ONLY
2 COMPATIBLE CABLES ARE ROUTED IN DIV 2 RACEWAY SYSTEM ONLY
3 COMPATIBLE CABLES ARE ROUTED IN DIV 3 RACEWAY SYSTEM ONLY
4 COMPATIBLE CABLES ARE ROUTED IN DIV 4 RACEWAY SYSTEM ONLY
5 COMPATIBLE CABLES ARE ROUTED IN DIV 5 RACEWAY SYSTEM ONLY
6 COMPATIBLE CABLES ARE ROUTED IN DIV 6 RACEWAY SYSTEM ONLY
7 COMPATIBLE CABLES ARE ROUTED IN DIV 7 RACEWAY SYSTEM ONLY

(3) FROM

EQUIPMENT OR DEVICE IDENTIFICATION WHICH THE CABLE ORIGINATES FROM

(4) TO

EQUIPMENT OR DEVICE IDENTIFICATION WHICH THE CABLE TERMINATES TO

(5) FOR

SYSTEM AND/OR SERVICE CABLE IS BEING USED FOR

(6) RACEWAY ROUTING

NUMBER INDICATED DENOTES NODES THROUGH WHICH THE CABLE PASSES IN SEQUENCE. IF LETTERS "ENTR" APPEAR IN THE ROUTING, THE CABLE ENTERS AT A POINT BETWEEN THE PRECEDING AND SUCCEEDING NODES. IF THE LETTERS "ENTR" DO NOT APPEAR, THE CABLE ENTERS AT FIRST NODE SHOWN. IF THE WORD "EXIT" APPEARS IN THE ROUTING, THE CABLE EXISTS AT A POINT BETWEEN THE PRECEDING AND SUCCEEDING NODES. IF THE WORD "EXIT" DOES NOT APPEAR, THE CABLE EXISTS AT THE LAST NODE SHOWN. THE ABOVE MENTIONED NODES ARE LOCATED AND SHOWN ON RACEWAY DRAWINGS. WHEN NODES DO NOT APPEAR, RACEWAYS ARE NOT USED. IN SUCH CASES, CABLES SHALL RUN "FROM" POINT OF ORIGATION "TO" POINT OF TERMINATION WITH OR WITHOUT CONDUIT, AS INDICATED ON THE DESIGN DRAWING.

TABLE VIII (Continued)

(7) CABLE REQD.

NUMBER OF SINGLE OR MULTIPLE CONDUCTOR CABLES REQUIRED.

(8) CABLE SPEC

SEE CABLE TYPES AND DESCRIPTIONS BELOW. (TYPICAL)

<u>TYPE</u>	<u>NUMBER</u>	<u>CONDUCTOR SIZE</u>	<u>OD INCHES</u>	<u>AREA SQ. IN.</u>
A	8kV UNGROUNDED NEUTRAL POWER CABLE 1C	250	1.276	1.2788

(9) CONDUCTOR NO.

NUMBER OF CONDUCTORS IN A CABLE. (1C = ONE CONDUCTOR, 12C = TWELVE CONDUCTORS, ETC.)

(10) CONDUCTOR SIZE

WIRE SIZE IN EITHER AWG. OR MCM.

(11) CIRCUIT LENGTH

INDICATES TOTAL LENGTH IN FEET FOR EACH CONDUCTOR INCLUSIVE OF THE DISTANCES "FROM" THE POINT OF ORIGATION TO RACEWAY ENTRANCE AND FROM THE RACEWAY EXIT "TO" THE POINT OF TERMINATION. WHEN RACEWAY ROUTING IS OMITTED, LENGTH INDICATED REFERS TO DISTANCES "FROM" THE POINT OF ORIGATION "TO" THE POINT OF TERMINATION IN FEET FOR EACH CONDUCTOR. THUS, IF THE CABLE CONSISTS OF THREE SINGLE CONDUCTORS, THE TOTAL LENGTH WOULD BE THREE TIMES RUN LENGTH.

(12) REV S.

REVISION NO. OF THE CABLE ISSUE IS DESIGNATED BY THE REV. NO. 'S' DESIGNATES THE CONSTRUCTION ISSUE STATUS OF THE CABLE.

(13) REFERENCE NOTES

SEE DRAWINGS E550 AND E551 FOR REFERENCE NOTES. THE LISTED NOTES BELOW WHICH RELATE TO ELECTRICAL SEPARATION ARE REITERATED FROM THE ABOVE DRAWINGS.

E550 REF. NOTES

- 4 THIS CABLE IS NON-CLASS 1E CABLE THAT DOES NOT ROUTE INTO REDUNDANT CLASS 1E RACEWAYS.
- 5 THIS CABLE IS CLASSIFIED IN THE SEPARATION GROUPING AS "ASSOCIATED BY PROXIMITY".
 - A) CABLE NUMBERS PREFIXED (FIRST SPACE) WITH "A" AND ROUTED IN DIVISION 1 RACEWAYS.
(COMPATIBILITY IS 1)
 - B) CABLE NUMBERS PREFIXED (FIRST SPACE) WITH "B" AND ROUTED IN DIVISION 2 RACEWAYS.
(COMPATIBILITY IS 2)
- 8 THIS CABLE MAY HAVE MORE THAN ONE DESIGNATION IN THE "9000" SERIES NUMBERS. FOR ROUTING PURPOSES, THESE CABLES SHALL BE CONTINUOUS FROM ONE PIECE OF EQUIPMENT TO ANOTHER. THERE SHALL NOT BE ANY SPLICES OR TERMINATIONS AT TRANSITION POINTS, FIRE STOPS, OR CABLE NUMBER CHANGES. "TP" INDICATES A TRANSITION POINT. "CONT" INDICATES CONTINUED ON CABLE SHOWN.
- 9 WHEN A CABLE CANNOT BE IDENTIFIED AS AN INTEGRAL PART OF A SPECIFIC SYSTEM, THE NUMBER "9999" WILL BE INPUT AS THE MECHANICAL SYSTEM NUMBER. THE CABLES ASSIGNED THIS NUMBER WILL BE REVIEWED PERIODICALLY.
- 13 ALL CABLES WITH PREFIX DIVISION 1 THROUGH 7 AND PRIME CABLES DESIGNATED UNDER THE "SFTY CLR" FIELD AS A'1 OR B'2 SHALL BE INSTALLED TO QUALITY CLASS 1 REQUIREMENTS (ONLY FOR PRIME CABLES INSTALLED AFTER 10-20-81).

E551 REF NOTES

- 4 SAME AS FOR E550.
- 5 SAME AS FOR E550.
- 8 SAME AS FOR E550.
- 9 SAME AS FOR E550.
- 21 THIS CABLE REVISED FROM MULTI-CONDUCTOR TO MULTIPLE SINGLE CONDUCTORS DUE TO INVENTORY REQUIREMENTS. PHASING TAPE SHALL BE USED FOR COLOR CODE LABELING ON CONDUCTOR ENDS ONLY. PHASING TAPE TO BE APPLIED APPROXIMATELY TWO INCHES FROM TERMINAL CONNECTOR. FOR COLOR CODE REQUIREMENTS SEE APPLICABLE CONNECTION DRAWING.
- 22 ALL CABLES WITH PREFIX (FUNCTIONAL DIV.) 1 THROUGH 7 AND PRIME CABLES DESIGNATED UNDER THE "SFTY CLR" FIELD AS A'1 OR B'2 SHALL BE QUALITY CLASS 1 (ONLY FOR PRIME CABLES INSTALLED AFTER 10-20-81).
14. SAFETY CLEARANCE FIELD
- THE DESIGNATION OF A'1 IN THESE FIELDS REPRESENTS A DIVISION A (NON-CLASS 1E) CABLE THAT IS POWERED FROM DIVISION 1 (CLASS 1E). AND SIMILARLY, B'2 SIGNIFIES A DIVISION B (NON-CLASS 1E) CABLE THAT IS POWERED FROM DIVISION 2 (CLASS 1E).

TABLE IX
SAMPLE CABLE SCHEDULE

(1) CABLE NUMBER	(2) T/C	(3) FROM	(4) TO	(5) FOR	MECH SYSTEM	FROM DWG NO	(7) CABL REQD	(8) CABL SPEC	(9) CONDUCTOR NO	(10) SIZE	(14) SFTY CLR	(11) CKT LGTH	(12) REV	(13) S	(13) REF NOTES
AM7A-0102	P A	XFMR TR-7A-B	PNL ELP-7A-B	FEEDER	4150		4	G1	1C	2/0	A'1	0015	002	*	
AM7A-0152	P A	LOCAL DISC SW	PUMP HOIST MT-CRA-6A	FEEDER	5110		3	G1	1C	2	A'1	0050	002	*	
AM7A-9010	P 1	MCC MC-7A	RFS BUS MTG GEN SET MG-1	FEEDER	2620		3	G1	1C	4	A'1	0044	002	*	
			ENTR:COLX K.1 13'06";COLY 11 22'06"; EL 54'8"												
			RTNG:6987-ENTR-6994-EXIT-6995												
			EXIT:COLX K.1 6'00";COLY 12.2 35'00"; EL 56'4"												
AM7A-9100	P 1	MCC MC-7A	TP CONT AM7A-9101	FEEDER	4150		3	G1	1C	1/0	A'1	0062	002	*	4,5
			ENTR:COLX K.1 13'06";COLY 11 22'06"; EL 54'8"												
			RTNG:6992-ENTR-6987-6966-EXIT-6969												
			EXIT:COLX J 16'06";COLY 10 6'06"; EL 51'6"												
AM7A-9101	P A	TP	XFMR TR-7A-B	FEEDER	4150		3	G1	1C	1/0	A'1	0366	002	*	4
			CONT AM7A-9100												
			ENTR:COLX J 16'06";COLY 10 6'06"; EL 48'6"												
			RTNG:6696-ENTR-6582-6583-7054-7055-7058-7062-7063- 7064-7065-1050-1051-1070-EXIT-1073												
			EXIT:COLX F 6'00";COLY 14 13'06"; EL 73'6"												
AM7A-9110	P 1	MCC MC-7A	TP	FEEDER	5250		3	G1	1C	4/0	A'1	0066	002	*	4,5
			CONT AM7A-9111												
			ENTR:COLX K.1 9'06";COLY 11 22'06"; EL 54'8"												
			RTNG:6992-ENTR-6987-6966-EXIT-6969												
			EXIT:COLX J 16'06";COLY 10 6'06"; EL 51'6"												
AM7A-9111	P A	TP	COMPRESSOR	FEEDER	5250		3	G1	1C	4/0	A'1	0278	002	*	4
			CONT AM7A-9110 CAS-C-1A												
			ENTR:COLX J 16'06";COLY 10 6'06"; EL 48'6"												
			RTNG:6696-ENTR-6582-6583-6549-6548-6546-6545-0429- 0427-EXIT-0424												
			EXIT:COLX G 6'06";COLY 7 8'00"; EL 41'6"												
AM7A-9120	P 1	MCC MC-7A	INVERT PKG IN-1	FEEDER	4350		3	G1	1C	1/0	A'1	0054	002	*	
			ENTR:COLX K.1 12'00";COLY 11 22'06"; EL 54'8"												
			RTNG:6987-ENTR-6992-6994-EXIT-6995												
			EXIT:COLX K.1 6'00";COLY 12.2 33'06"; EL 56'4"												



20

TABLE X
CABLE ROUTING CRITERIA
POWER CABLES IN RACEWAYS

Raceway Type	Raceway Division	CABLE APPLICATION													
		14.4KV POWER	6.9KV POWER	4.16 KV POWER						480/240/208/120VAC 250/125VDC PWR					
		CABLE DIVISIONS													
		A	B	A	B	1	2	3	A	B	1	2	3	A	B
Hc	A	X													
Hc	B		X												
H	A			X					X						
H	B				X					X					
H	1					0			AP						
H	2						0			AP					
H	3							+							
P	A													X	
P	B														X
P	1										0			AP	
P	2											0			AP
P	3												+		

X - Non-Class 1E division cables.

0 - Class 1E division cables.

+

AP - "Associated by Proximity" cables - Non-Class 1E cables routed in compatible Class 1E raceway.

Hc - High Voltage Raceway - Conduit.

H - High Voltage Raceway - Conduit or tray.

P - 480V or below Power Raceway - Conduit or tray.

Example 1 - 14.4KV Div. A power cable can only be routed in Div. A conduit.

Example 2 - It is permissible to route 6.9KV & 4.16KV Div. A power cables in same Div. A raceway.

Example 3 - 4.16KV Div. 3 power cables can only be routed in Div. 3 H raceways.

Example 4 - It is permissible to route Div. A power cable in Div. 1 power raceway. Such cables are identified by "NOTE 5" in the E550 Cable Schedule Reference Note Column. (For details, see Table IX, Column 13). These cables have raceway compatibility identified per Table IX, column 2.



11

TABLE XI
CABLE ROUTING CRITERIA
CONTROL CABLES IN RACEWAYS
EXTERNAL TO PGCC

Raceway Type	Raceway Division	CABLE APPLICATION													
		Control Indic. & Annun.		RPS/NSSS Trip Logic Cables					Control Ind, Ann. & *		RPS Scram SOV Control Ckts.				
		CABLE DIVISIONS													
		1	2	3	4	5	6	7	A	B	4	5	6	7	
C	1	0							AP						
C	2		0							AP					
C	3			+											
C	4				0										
C	5					0									
C	6						0								
C	7							0							
C	A								X						
C	B									X					
Rc	4										0				
Rc	5											0			
Rc	6												0		
Rc	7													0	

* Digital Computer Signal in Reactor Building only.

- C - Raceway to route control circuits.
- Rc - RPS Scram Solenoid Raceway - Conduit.
- X - Non-Class 1E Division Cables.
- +
- High Pressure Core Spray (HPCS) Class 1E Division Cables.
- 0 - Class 1E Division Cables.
- AP - "Associated by Proximity" - Non-Class 1E Cables routed in compatible Class 1E raceway.

Example 1 - Class 1E Div. 1 Control Cables can only be routed in Div. 1 control raceways. Non Class 1E Div. A Control/Indication/Ann. Cables are permitted to route in Class 1E Div. 1 raceways only. Such cables are termed "Associated by Proximity" and are identified by "Note 5" in the E551 Cable Schedule Reference Note Column. (For details see Table VIII, Column 13.). These cables have raceway compatibility identified per Table VIII, Column 2.

Example 2 - Class 1E Div. 3 control cables can only route in Div. 3 raceways.

TABLE XII
CABLE ROUTING CRITERIA
INSTRUMENTATION/SIGNAL CABLES IN RACEWAYS
EXTERNAL TO PGCC

Raceway Type	Raceway Division	CABLE APPLICATION									
		ANALOG SIGNAL		NMS/NSSS/RPS TRIP LOGIC SIGNAL CABLES						SIGNAL	
										Analog	Digital
		CABLE DIVISION									
		1	2	3	4	5	6	7	A	B	
S	1	0							AP		
S	2		0							A	
S	3			+							
S	4				0						
S	5					0					
S	6						0				
S	7							0			
S	A								X		
S	B									X	

Example 1

Example 2

Example 3

- X - Non-Class 1E Division Signal Cables.
- 0 - Class 1E Division Signal Cables.
- +
- AP - "Associated by Proximity" - Non-Class 1E Cables routed in compatible Class 1E raceways.
- S - Signal Cable Raceway - solid tray or conduit.

- Example 1 - It is permissible to route Div. A signal cable in Div. 1 raceway. Such cables are termed as "Associated by Proximity" and are identified by "Note 5" in the E551 Cable Schedule Reference Note Column (For details see Table VIII, Column 13). These cables have raceway compatibility identified per Table VIII, Column 2.
- Example 2 - Div. 5 RPS/NMS signal cable can only be routed in Div. 5 signal raceways.
- Example 3 - Non-Class 1E Div. A signal cables route only in Div. A signal raceways.

TABLE XIII
GENERAL PLANT AND PGCC
CLASS 1E CABLE INTERFACE

CONTROL/INDICATION/SIGNAL

INTER- FACE BOP CABLE DIV.	NSSS PGCC CABLE DIV. *	BOP PGCC CABLE DIV. *	PGCC RACEWAY DIVISION		
			1	2	3
1	ESSI	Div 1	0		
2	ESSII	Div 2		0	
3	ESSIII	Div 3			+
4	RPS A1		0		
6	RPS B1		0		
5	RPS A2			0	
7	RPS B2			0	
1	NSSI		0		
2	NSSII			0	
4	DIV1A		0		
6	DIV1B		0		
5	DIV2A			0	
7	DIV2B			0	

Note 1

Note 2

Note 2

General Plant
Area-Raceways

PGCC
Raceways

0 - Class 1E Division Cables

+ - High Pressure Core Spray (HPCS) Class 1E Division Cables

* - Cable Identification Marker

Note 1 - Class 1E circuits are routed in compatible Class 1E division of PGCC raceways.

Note 2 - RPS/NSS Class 1E control and signal cables are considered compatible to either Div 1 or Div 2 PGCC raceway routing as stated in Table II.

**TABLE XIV
GENERAL PLANT AND PGCC**

**NON-CLASS 1E CABLE INTERFACE
CONTROL/INDICATION/SIGNAL**

GENERAL PLANT INTERFACING CABLE DIVISION	POWER SUPPLY CONNECTION	SEE NOTE 1		CABLE ROUTED IN PGCC RACEWAY DIVISION			
		NSSS PGCC CABLE DIVISION (a)	BOP PGCC CABLE DIVISION (b)	1	2	3	NON- CLASS 1E
DIV A	PRIME A'1	XXX1	DIV A	AP			
DIV A	NON PRIME	XXX1	DIV A	AP			X
DIV A	NON PRIME	XXX2	DIV B				X
DIV A	NON PRIME	XXX2	DIV B				X
DIV B	PRIME B'2	XXX2	DIV B		AP		
DIV B	NON PRIME	XXX2	DIV B		AP		X
DIV B	NON PRIME	XXX2	DIV A				X
DIV B	NON PRIME	XXX2	DIV A				X
DIV 3	PRIME 3	XXX3	DIV 3			X	
DIV 3	DIV 3	XXX3	DIV 3			X	
General Plant Area Raceways	PGCC Raceways	X - Non-Class 1E cables. AP - Associated by Proximity.					

Note 1 In PGCC there are two types of routing/cable tagging configurations. "NSSS" circuits (General Electric scope circuits interfacing with 600 Series panel modules) follow the cable divisional tagging per column (a). All other circuits (Balance of Plant circuits interfacing with 800 Series panel modules) follow the cable divisional tagging per column (b).

Note 2 For examples see Sh. 2 of this table.


TABLE XIV

p. 2 OF 2

GEN. PLANT
AREA


PGCC

EXAMPLE 1




NOTE: PRIME CABLES XXX1, XXX2, XXX3 CAN NOT BE ROUTED IN NON-DIVISIONAL PGCC DUCTS. PRIME CABLES ARE ALLOWED TO ROUTE IN ONLY THE COMPATIBLE DIVISIONAL DUCTS.

EXAMPLE 2




NOTE: INTERNAL TO PGCC DIV A CABLE MAY BE ROUTED IN DIV 1 OR NON-DIV. PGCC RACEWAY.

EXAMPLE 3



① NOTE: INTERNAL TO PGCC DIV A CABLE MAY BE TAGGED AS XXX2 AND ROUTED IN NON-DIVISIONAL PGCC RACEWAY. SUCH CABLE IS NOT ALLOWED TO ROUTE IN DIV 2 PGCC RACEWAY THEREBY AVOIDING DIRECT BRIDGING.

EXAMPLE 4



② NOTE: WHEN INTERFACING PGCC CABLE IS TAGGED XXX2 AND ROUTED IN ND/DIV 2 PGCC RACEWAYS, SUCH CABLE IS NOT ALLOWED TO ROUTE IN A DIVISION 1 PGCC RACEWAY IN DOWN STREAM CIRCUITS THEREBY AVOIDING DIRECT BRIDGING.

**SEPARATION
CODES**

[illegible]

```

B22A Nuclear Boiler Process Instrumentation
B22C Auto Depressurization System (ADS)
B22E Jet Pump Instrumentation

B22H Nuclear Steam Supply Shutoff System (NSSSS)

B35A Reactor Recirculation
C12A Reactor Manual Control (RMC)
C12B Control Rod Drive Hydraulic (CRD HYD)
C34A Feedwater Control
C41A Standby Liquid Control
C51A Startup Range Neutron Monitoring
C51B Power Range Neutron Monitoring
C51C Startup Drive Control
C51D Traversing In-Core Probe Calib (Tip)
C61A Remote Shutdown
C72A Reactor Protection System (RPS)
C72B RPS Motor Generator Set Control
C91A Computer Interconnection
D17A Process Radiation Monitoring
D21A Area Radiation Monitoring (ARM)
E12A Residual Heat Removal (RHR)
E21A Low Pressure Core Spray (LPCS)
E22A High Pressure Core Spray (HPCS)
E22B HPCS Power Supply
E31A Leak Detection
E51A Reactor Core Isolation Cooling (RCIC)
G11A Radwaste
G33A Reactor Water Cleanup
H13A Annunciator System
H64A Off Gas System - Low Temp.

```

PGCS POWER SUPPLY CLASSIFICATION

POWER SOURCE DESCRIPTION AS SHOWN ON ELEMENTARY	NON CLASS 1E			CLASS 1E		
				PRIME		
120VAC INSTR BUS	X	X	X			
125 VDC INSTR BUS	X	X	X			
24VDC INSTR BUS	X	X	X			
28VDC INSTR BUS	X	X	X			
120 VAC INSTR BUS A				X		X
120 VAC INSTR BUS B				X		X
125 VDC INSTR BUS A				X		X
125 VDC INSTR BUS B				X		X
24VDC INSTR BUS A				X		X
24VDC INSTR BUS B				X		X
120VAC UPS BUS	X	X	X			
120VAC UPS BUS A				X		X
120VAC UPS BUS B				X		X
120VAC RPS BUS A	X	X				
120VAC RPS BUS B	X	X				
120VAC INSTR BUS C					X	X
120VDC INSTR BUS C					X	X
24VDC INSTR BUS C					X	X

<u>NSSS</u> <u>CODE</u>	<u>BOP</u> <u>CODE(1)</u>	<u>DESCRIPTION</u>
ESS1	Div 1	Core Standby Cooling System Division 1
ESS2	Div 2	Core Standby Cooling System Division 2
ESS3	Div 3	Core Standby Cooling System Division 3
A1	Div 4	Reactor Protection System/Nuclear Steam Supply Shutoff System Channel A Division 1
B1	Div 6	Reactor Protection System/Nuclear Steam Supply Shutoff System Channel B Division 1
A2	Div 5	Reactor Protection System/Nuclear Steam Supply Shutoff System Channel A Division 2
B2	Div 7	Reactor Protection System/Nuclear Steam Supply Shutoff System Channel B Division 2
NSS1	Div 1	Nuclear Steam Supply Shutoff System Division 1
NSS11	Div 2	Nuclear Steam Supply Shutoff System Division 2
DIV 1A	Div 4	Neutron Monitoring System Trip Logic A1 Division 1A
DIV 1B	Div 6	Neutron Monitoring System Trip Logic B1 Division 1B
DIV 2A	Div 5	Neutron Monitoring System Trip Logic A2 Division 2A
DIV 2B	Div 7	Neutron Monitoring System Trip Logic B2 Division 2B
XXX1 or DIV B	DIV A	All other non-safety functions routed with Division 1 PGCC raceways or Non- Class 1C PGCC raceways. (XXX1 cable in DIV 1 raceway is associated)
XXX11 or DIV B	DIV A	All other non-safety functions routed with Division 2 cables or Non-Class 1E PGCC raceways. (XX11 Div 2 raceway is associated)
XXX111	DIV 3	All other non-safety functions routed with Division 3 PGCC raceways.

41

**TABLE XV
POWER GENERATION CONTROL COMPLEX**

Sheet 2-of 2

**PGCC CABLE TYPES
(Supplied by General Electric)**

**CIRCUIT DESIGN
GENERAL INFORMATION**

NSSS CODE	BOP CODE	DESCRIPTION
SP1 AWG 20		1 Twisted Shielded Pair of #20 Wire
SP4 AWG 20	GE-7A	4 Twisted Shielded Pairs of #20 Wire
SP7 AWG 20	GE-5A	7 Twisted Shielded Pairs of #20 Wire
SP13 AWG 20		13 Twisted Shielded Pairs of #20 Wire
TC4 Cu/Cn	GE-5	7 Twisted Shielded Pairs of #16 Wire
TC8 Cu/Cn	GE-6	4 Shielded Pairs of Copper Constantan Thermocouple Wire
TC8 Chr/Cn		8 Shielded Pairs of Copper Constantan Thermocouple Wire
	GE-7	8 Shielded Pairs of Chrome Constantan Thermocouple Wire
ST/1 AWG 20		4 Twisted Shielded Pairs of #16 Wire
	GE-4	Twisted Shielded Triple Conductors of #20 Wire
	GE-3	12 Conductors of #14 Wire with Overall Shield
MC7 AWG 14		7 Conductors of #14 Wire
MC19 AWG 14	GE-1	19 Conductors of #14 Wire
MC8 AWG 16		8 Conductors of #16 Wire
MC12 AWG 16	GE-2	12 Conductors of #16 Wire
MC19 AWG 16		19 Conductors of #16 Wire
MC27 AWG 16		27 Conductors of #16 Wire
MC37 AWG 16		37 Conductors of #16 Wire
MC7 AWG 16		7 Conductors of #20 Wire
MC12 AWG 20		12 Conductors of #20 Wire
MC19 AWG 20		19 Conductors of #20 Wire
MC27 AWG 20		27 Conductors of #20 Wire
MC37 AWG 20		37 Conductors of #20 Wire
MC48 AWG 20		48 Conductors of #20 Wire
7/C AWG 14		7 Separate Conductors of #14 Wire Routed In Conduit
12/C AWG 14		12 Separate Conductors of #14 Wire Routed In Conduit
2 COND PWR		2 Power Conductors Routed In Conduit
3 COND PWR		3 Power Conductors Routed In Conduit
COAX RG-6		Coaxial Cable Type RG-6
COAX RG-22		Coaxial Cable Type RG-22
COAX RG-59		Coaxial Cable Type RG-59
COAX RG-59AM		Coaxial Cable Type RG-59AM
	GE-8	6 3/c #16 Individually Shielded
	GE-9	2 1/c #10
	GE-10	2 1/c #12
	GE-12	4 4/c #14
	GE-13	4 4/c #16 Individually Shielded
	GE-14	7/c #16 Overall Shield

Example 1: BOP PGCC Cable Information
Obtained from the B&R BOP
cable routing
Cable No. CM-K2-1.10
From: H13-P891
To: H13-P811
Signal & Separation: C2
Cable Type: GE-1
Raceway: Div 2

NSSS CODE	BOP CODE (1)	PGCC SIGNAL DESCRIPTION DESCRIPTION
GE/MAC	S	Milliamp Process Signal
Low A	S	Low Level Analog Signal
Low D	S	Low Level Digital Signal
Comp A	S	160 MV Computer Analog Signal
Comp D	S	Computer digital Signal
M/R IN	S	Meter/Recorder Input
ANN IN	C/S	Annunciator Input
28 VDC	C	28 Volt DC Power
120 VAC	C	120 Volt AC Power
125 VDC	C	125 Volt DC Power
C1 120A	C	120 Volt AC Control & Indication Signal
C1 125D	C	125 Volt DC Control & Indication Signal
C1 28D	C/S	28 Volt DC Control & Indication Signal
24 VDC	C	24 Volt DC Power
CT 5A	C	5 Amp. Current Transformer Circuit
ARM IN	S	Area Radiation Monitor Input

(1) This BOP code corresponds to BOP cable signal classification for BOP PGCC Cables and for those cables that interface with the NSSS PGCC cables.

TABLE XVI

NSSS VENDOR

GENERAL DESIGN INFORMATION
SYSTEM CABLES AND ROUTING CRITERIA

DESCRIPTION	FIELD				IN PGCC MODULAR FLOOR DUCTS				NSSS SPECIAL CABLE REQ.				REMARKS
	NON CLASS 1E	CLASS 1E	CABLE TYPE	RACEWAY DIV	RACEWAY DIVISION	PGCC SEPARATION CATEGORY	PGCC SIGNAL CLASS	PGCC CABLE TYPE	IMP. (OHMS)	CAPAC. (pf/ft)	MAX. VOLTS (V RMS)	Special Requir.	
RPS/NSSS TRIP LOGIC CONTROL CABLES	X	K1	C4	Div 1	A1	C1120A	12/C#14					NA	Failsafe cables routed in grounded flex CND within PGCC.
	X	K1	C6	Div 1	B1	C1120A	12/C#14						
	X	K1	C5	Div 2	A2	C1120A	12/C#14						
	X	K1	C7	Div 2	B2	C1120A	12/C#14						
RPS SCRAM SOLENOIDS CABLES	X	H2	R4	Div 1	A1	C1120A	2COND PWR					SCRAM SOV CKT NEUTRAL TO BE #6AWG FROM MAIN CONTROL PANEL TO SCRAM GROUP PULL BOX AT SOVS	RPS scram SOV cables trip logic A1 & B1 and LPRM group 1 & 3 cables are routed in separate PGCC Division 1 ducts, similarly for RPS scram SOV cables
	X	H2	R6	Div 1	B1	C1120A	2COND PWR						
	X	H2	R5	Div 2	A2	C1120A	2COND PWR						
	X	H2	R7	Div 2	B2	C1120A	2COND PWR						
RPS TRIP LOGIC SIGNAL CABLES	X	L2	S4	Div 1	A1	GEMAC	SP4					NA	trip logic A2 & B2 and LPRM group 2 & 4 cables.
	X	L2	S6	Div 1	B1	GEMAC	SP4						
	X	L2	S5	Div 2	A2	GEMAC	SP4						
	X	L2	S7	Div 2	B2	GEMAC	SP4						
SRM			M7						75	20.5	1000	COAX 3 SHLD HI RAD, TEMP	Neutron Monitoring System Group 1
			M1				LOW A	COAX RG6	75	20.0	1500	COAX STD	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
			L4				C1 280	COAX RG59	47	37.3	2000	SHLD	
C51A			M6						130	9.8	1000	COAX 3 SHLD.	
			M1				LOW A	COAX RG6	75	20.0	1500	COAX STD.	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
			L4	S4	Div 1	Div 1A	C1 280	COAX RG59	47	37.3	2000	SHLD	
LPRM							C1 280	MC19				NA	
			M5						62	25.7	2300	COAX HI RAD TEMP.	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
			M1						75	20.5	1000	COAX 3 SHLD HI RAD, TEMP	
C51B			M1				LOW A	COAX RG6	75	20.0	1500	COAX STD	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
			L4				LOW A	COAX RG59	47	37.3	2000	SHLD	
D17A				S6	Div 1	Div 1B							
				S5	Div 2	Div 2A							
				S7	Div 2	Div 2B							
PROC RAD MON													
NMS	X	I	S6	Div 1	Div 1B								NMS GROUP III
	X	I	S5	Div 2	Div 2A								NMS GROUP II
	X	I	S7	Div 2	Div 2B								NMS GROUP IV
	X	I											

Continued on Page 2

5 1 0 2

Continued From Page 1

44

20-111620-1707-1206







FIGURE 1B


SECONDARY BRIDGING
BY PROXIMITY



NOTE: SECONDARY BRIDGING IS ALLOWED WHERE
 ACCEPTABLE BY ANALYSIS

FIGURE 1C


SECONDARY BRIDGING WITHIN
EQUIPMENT AND ENCLOSURES



NOTE: SECONDARY BRIDGING IN ENCLOSURES IS ALLOWED
WHERE ACCEPTABLE BY ANALYSIS

FIGURE 2

FOUR PENETRATION RPS SEPARATION CONCEPT



* RPS SENSORS A&B OR C&D MAY BE CONNECTED TO A COMMON PROCESS TAP


† RPS SENSORS A&C OR B&D MUST NOT BE CONNECTED TO A COMMON PROCESS TAP.

** WIREWAYS NA, NB, ETC. MAY BE ASSIGNED TO SEPARATE DIVISIONS AS APPROPRIATE TO PLANT LAYOUT.

*** SEE FOUR PENETRATION RPS SEPARATION CONCEPT

FIGURE 3

NSSSS SEPARATION CONCEPT SEPARATION CONCEPT



* INTERCONNECTING CONDUITS USED FOR MAIN STEAM ISOLATION VALVE LOGIC ONLY



FIGURE 4

PROXIMITY CIRCUIT SECTIONALIZATION

