

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

may

ACCESSION NBR: 8311010193 DOC. DATE: 83/10/25 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME: SORENSEN, G.C. AUTHOR AFFILIATION: Washington Public Power Supply System
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Advises that installation of acoustic monitoring sys to monitors discharge of safety relief valves & provide open/closed info & alarms in control room completed, per SER Confirmatory Item 18 & TMI Action Item II.D.3.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DL/ADL	1 0		NRR LB2 BC	1 0
	NRR LB2 LA	1 0		AULUCK, R. 01	1 0
INTERNAL:	ELD/HDS2	1 0		IE FILE	1 1
	IE/DEPER/EPB 36	3 3		IE/DEPER/IRB 35	1 1
	IE/DEQA/QAB 21	1 1		NRR/DE/AEAB	1 0
	NRR/DE/CEB 11	1 1		NRR/DE/EHEB	1 1
	NRR/DE/eqB 13	2 2		NRR/DE/GB 28	2 2
	NRR/DE/MEB 18	1 1		NRR/DE/MTEB 17	1 1
	NRR/DE/SAB 24	1 1		NRR/DE/SGEB 25	1 1
	NRR/DHFS/HFEB40	1 1		NRR/DHFS/LQB 32	1 1
	NRR/DHFS/PSRB	1 1		NRR/DL/SSPB	1 0
	NRR/DSI/AEB 26	1 1		NRR/DSI/ASB	1 1
	NRR/DSI/CPB 10	1 1		NRR/DSI/CSB 09	1 1
	NRR/DSI/ICSB 16	1 1		NRR/DSI/METB 12	1 1
	NRR/DSI/PSB 19	1 1		NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1		REG FILE 04	1 1
	RGNS	3 3		RM/DDAMI/MIB	1 0
EXTERNAL:	ACRS 41	6 6		BNL (AMDTs ONLY)	1 1
	DMB/DSS (AMDTs)	1 1		FEMA-REP DIV 39	1 1
	LPDR 03	1 1		NRC PDR 02	1 1
	NSIC 05	1 1		NTIS	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 4

Washington Public Power Supply System

P.O. Box 968 3000 George Washington Way Richland, Washington 99352 (509) 372-5000

October 25, 1983
G02-83-969

Docket No. 50-397

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Schwencer:

Subject: NUCLEAR PROJECT NO. 2
SAFETY RELIEF VALVE POSITION INDICATION

Reference: WPPSS Nuclear Project No. 2, Safety Evaluation Report,
NUREG-0892, March 1982

Resolution of Confirmatory Item 18 and TMI-2 Item II.D.3, as referenced in the subject Safety Evaluation Report, requires the installation of an acoustic monitoring system which will monitor the discharge of each SRV and provide open/closed information and alarms in the control room.

The current status of the acoustic monitoring system is that it has been installed and successfully tested. The staff requirement that the installation be completed prior to operation has been satisfied. If there are any questions, please contact Mr. P. L. Powell, Manager, WNP-2 Licensing.

Very truly yours,

G. C. Sorensen
G. C. Sorensen, Acting Manager
Nuclear Safety and Regulatory Programs

BDP/tmh

cc: R Auluck - NRC
WS Chin - BPA
AD Toth - NRC Site

8311010193 831025
PDR ADOCK 05000397
E PDR

*13001
1/10*

