

④ SEE SECTION 190 CONTRACT 215.  
8. ALL INSTRUMENTATION PIPING AND TUBING DOWNSTREAM OF THE INSTRUMENT ROOT VALVE SHALL BE CLASSIFIED AS FOLLOWS:

QUALITY CLASS II	} Ø
SEISMIC CATEGORY II	
CODE GROUP D	

Ø EXCEPT AS NOTED ON MG19, INSTRUMENT CONN. DIAGRAM

9. ALL PIPING, VALVES AND ASSOCIATED COMPONENTS REFERRING TO THIS NOTE SHALL BE CLASSIFIED AS FOLLOWS:

QUALITY CLASS II
SEISMIC CATEGORY I
CODE GROUP C

10. PIPING, VALVES & ASSOCIATED COMPONENTS  
ON THIS DWG. SHALL BE CLASSIFIED AS  
FOLLOWING (Bolted Joints are indicated  
on this diagram)  
SEISMIC CATEGORY I  
( QUALITY CLASS I  
( CODE GROUP D \*  
( \* STRAINERS SHALL HAVE ALL FABRICATION  
MATERIALS TO APPLICABLE REQUIREMENTS OF  
ASME B31.2 EXCEPT THAT THERE IS NOT  
REQUIRED A PERFORATED PLATE MAY BE ASTM  
MATERIAL & COMPLIANCE WITH NA-3700 IS NOT  
MANDATORY. FURNISHED & INSTALLED BY CONTR.

11. ALL PIPING FOR FPG(9)-1 UPSTREAM OF FPG-V-1  
FPG(O)-1, FPG(11)-1 AND FPG(52) 1 SHALL HAVE  
ALL WELDS EXAMINED BY LIQUID  
PENETRANT EXAMINATION, AND SHALL HAVE  
ALL FABRICATION AND MATERIALS TO  
APPLICABLE REQUIREMENTS OF ASME III.  
EXCEPT CODE STAMP IS NOT REQUIRED.

QUALITY CLASS II  
SEISMIC CATEGORY II &  
CODE GROUP D

[illegible]


CF-SPV-III-2

FIG. 1  
(D-6)

LEGEND

1. ALL VALVES SUFFIXED WITH A  
(V) EQUAL A 3/4" VENT VALVE.

2. ALL VALVES SUFFIXED WITH A  
(D) EQUAL A 3/4" DRAIN VALVE.




SEE NOTE 1

DESIGN CONTROL FOR START-UP SYSTEM(S)

TRANSFERRED TO WPPSS. ALL FUTURE CHANGES TO THIS (THESE) SYSTEM(S) SHALL BE INITIATED AND APPROVED BY THE SUPPLY SYSTEM. ALL REVISIONS TO THIS DRAWING REQUIRE APPROVAL OF THE SUPPLY SYSTEM AND THE ARCHITECT/

LINE NUMBERS IN  
THIS IDENTIFY PUMP  
PC'D DEMINERALIZER

 FSAR FIG. NO  
9.1-4(3.2-12)

BURNS AND ROE, INC.  
ENGINEERS AND CONSTRUCTORS  
ORADELL, N. J.    HEMPSTEAD, N. Y.    LOS ANGELES, CALIF.

FLOW DIAGRAM  
FUEL POOL COOLING  
AND CLEAN-UP SYSTEM

WASHINGTON PUBLIC POWER SUPPLY SYSTEM  
HANFORD No. 2

ENGINEERING REVIEW					SCALE: NONE	
DIVISION	MECH	ELECT.	NUCLEAR	INSTR.	DRAWN: A.B.	CHECKED: Paul. Lusk
ENG. R	<i>Paul</i>	<i>Paul</i>	<i>Paul</i>	<i>Paul</i>	BY: BSS	DATE: 5/3/72
DATE	7/23/72				7/23/72	
APPROVED FOR CONSTRUCTION					REVIEWED BY: CHIEF DRAFTSMAN	
ELECTRICIAN					TWO	
W. O. 2808					DWG. M526	
LIFE SUPPORT					66	