

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8402070297 DOC. DATE: 84/01/27 NOTAM: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME: AUTHORITY AFFILIATION
 LANEY, R.V. Technical Audit Associates, Inc.
 RECIP. NAME: RECIPIENT AFFILIATION
 MAZUR, D.W. Washington Public Power Supply System

SUBJECT: Advises that as-built stress analysis of RHR sys piping & evaluation of Burns & Roe floor response amplification analysis, not included in util final assessment rept appear satisfactory. Mods to previous conclusion unnecessary.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DL/ADL	1		NRR LB2 BC	1
	NRR LB2 LA	1		AULUCK, R. 01	1
INTERNAL:	ELD/HDS2	1		IE FILE	1
	IE/DEPER/EPB 36	3		IE/DEPER/IRB 35	1
	IE/DQASIP/QAB21	1		NRR/DE/AEAB	1
	NRR/DE/CEB 11	1		NRR/DE/EHEB	1
	NRR/DE/eqB 13	2		NRR/DE/GB 28	2
	NRR/DE/MEB 18	1		NRR/DE/MTEB 17	1
	NRR/DE/SAB 24	1		NRR/DE/SGEB 25	1
	NRR/DHFS/HFEB40	1		NRR/DHFS/LQB 32	1
	NRR/DHFS/PSRB	1		NRR/DL/SSPB	1
	NRR/DSI/AEB 26	1		NRR/DSI/ASB	1
	NRR/DSI/CPB 10	1		NRR/DSI/CSB 09	1
	NRR/DSI/ICSB 16	1		NRR/DSI/METB 12	1
	NRR/DSI/PSB 19	1		NRR/DSI/RAB 22	1
	NRR/DSI/RSB 23	1		REG FILE 04	1
	RGN5	3		RM/DDAMI/MIB	1
EXTERNAL:	ACRS 41	6		BNL (AMDTs ONLY)	1
	DMB/DSS (AMDTs)	1		FEMA-REP DIV 39	1
	LPDR 03	1		NRC PDR 02	1
	NSIC 05	1		NTIS	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 53 ENCL 0

TECHNICAL AUDIT ASSOCIATES, INC.

589 OENOKE RIDGE
NEW CANAAN, CT 06840

ROBERT V. LANEY
VICE PRESIDENT
24 TROUT FARM LANE
DUXBURY, MA. 02332
(617) 585-8912

(203) 966-0383

*Al Schreiner
Should go in PDR
T*

January 27, 1984

Mr. D. W. Mazur
Managing Director
Washington Public Power Supply System
P. O. Box 968
3000 George Washington Way
Richland, WA 99352

Dear Mr. Mazur:

By letter of October 21, 1983, F. B. Jewett, Jr. to D. W. Mazur, Technical Audit Associates forwarded its analysis and conclusions related to the WNP-2 design verification program. These were set forth in TAA's Volume II Report, "An Independent Evaluation of the Requirements and Design Verification Program."

As noted on page 98 of Volume II, the Supply System's final as-built stress analysis of residual heat removal system piping and its evaluation of Burns and Roe's floor response amplification analysis were not completed at the time of TAA's report, were not included in the Supply System's Final Assessment Report, and therefore were not considered in reaching conclusions stated in Volume II. TAA has since received both of the items noted, enclosed with Mr. G. D. Boucheys letter to me, dated January 6, 1984.

The TAA evaluation team has reviewed these items, the RHR Addendum to the Supply System's Final Assessment Report, dated December, 1983, and two letters, BRWP-83-211 and BRWP-83-217, dated November 23, 1983, and December 1, 1983, respectively. Both appear satisfactory as to samples selection, depth of review, and disposition of findings. Based on this review, TAA finds no reason to modify the conclusions previously expressed in Volume II, pages 95 through 99.

8402070297 840127
PDR ADQCK 05000397
PDR

*Boo!
1/0*

1944


7



Mr. D. W. Mazur
January 27, 1984
Page 2

In accordance with Mr. Bouchey's request, we are sending copies of this letter directly to the NRC.

Sincerely,



Robert V. Laney

RVL:pb

cc: G. D. Bouchey
C. S. Carlisle
R. B. Glasscock
R. AULUCK, NRC
R. T. DODDS, NRC
J. MARTIN, NRC
T. NOVAK, NRC
A. SCHWENCER, NRC
A. D. TOTH, NRC
F. B. Jewett, Jr.
S. Levy
C. Q. Miller
L. H. Roddis, Jr.
H. E. Sheets

