

CONTAINMENT SYSTEMS

DRYWELL AVERAGE AIR TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.6.1.7 Drywell average air temperature shall not exceed 135°F.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2 and 3.

ACTION:

With the drywell average air temperature greater than 135°F, reduce the average air temperature to within the limit within 8 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.7 The drywell average air temperature shall be the arithmetical average of the temperatures at a minimum of three of the following locations and shall be determined to be within the limit at least once per 24 hours:

	<u>Elevation</u>	<u>Azimuth</u>
a.	504'0"	72°
b.	504'0"	190°
c.	504'0"	275°
d.	560'0"	355°
e.	547'0"	222°

operating
drywell cooling
units

Delete



Handwritten marks and symbols at the bottom left corner, including what appears to be a stylized 'A' and some illegible characters.