


Westinghouse  
Electric Corporation

Switchgear Divisions

700 Braddock Avenue  
East Pittsburgh Pennsylvania 15112

January 31, 1984



United States Nuclear  
Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Attention: Mr. Uldis Potapovs, Chief  
Vendor Program Branch

Subject: Docket No. 99900330/83-01

Dear Mr. Potapovs:

Your letter of January 9, 1984 requests that we supplement our October 13, 1983 letter by identifying the preventive actions we plan to take in regard to Item C of the Notice of Nonconformance.

Procedures have been instituted under which each UVTD is assigned a unique serial number which is clearly stamped on the device before it is delivered for test. This serial number must be shown on the Certificate of Conformance at time of shipment. Procedures directing personnel to file Certificates of Conformance in our shop order folder have also been formalized.

These procedures will prevent a recurrence of the type of situation discovered during your August 1-4, 1983 inspection.

Very truly yours,

A handwritten signature in cursive script that reads "D. B. Jones".

D. B. Jones, Manager  
Quality Assurance  
Switchgear Division

Approved:

A handwritten signature in cursive script that reads "D. M. Sauter".

D. M. Sauter  
General Manager  
Switchgear Division

8403060096 840301  
PDR GA999 EMVWEST  
99900330 PDR

