

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8706010326 DCC DATE: 87/05/20 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORESEN, G. C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Office of Director

SUBJECT: Respondss to IE Bulletin 80-13, "Cracking in Core Spray
 Spargers." Visual examination performed using closed-circuit
 TV revealed no relevant indications of cracking.

DISTRIBUTION CODE: IE11D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Bulletin Response (50 DKT)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 0	PD5 PD	1 1
	SANWORTH, R	1 1		
INTERNAL:	AEOD/DOA	1 1	AEOD/DSP	1 1
	AEOD/DSP/TPAB	1 1	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DOEA/EAB	1 1
	NRR/DOEA/GCB	1 1	NRR/DREP/EPB	1 1
	NRR/PMAS/ILRB	1 1	<u>REG FILE</u> 02	1 1
	RGN5 FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

Washington Public Power Supply System

3000 George Washington Way P.O. Box 968 Richland, Washington 99352-0968 (509)372-5000

May 20, 1987
G02-87-173

Docket No. 50-397

Mr. J. B. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596

Dear Mr. Martin

Subject: NUCLEAR PLANT NO. 2
CORE SPRAY SPARGERS


Reference: IE Bulletin 80-13 "Cracking in Core Spray Spargers",
dated May 12, 1980

During the April 1987 refueling outage, the Supply System performed a visual examination of the WNP-2 Core Spray Spargers per the requirements of the referenced IE Bulletin. No relevant indications were observed in the areas examined. This letter satisfies the 30 day reporting requirement in the referenced IE Bulletin.

The examination was performed remotely using an underwater closed circuit TV (CCTV) system capable of resolving a 0.001 inch diameter wire. The examiners were certified to Level II VT-1 under the Supply System's QA program. At the beginning and end of the examination and at four (4) hour intervals during the examinations, the CCTV system was demonstrated to be capable of resolving a 0.001 inch diameter wire in-situ.

If you have any questions or desire further information on this examination, please contact Mr. P. L. Powell, Manager, WNP-2 Licensing.

Very truly yours,


G. C. Sorensen, Manager
Regulatory Programs

DPR/bk

cc: RB Samworth - NRC
NS Reynolds - BCP&R
NRC Site Inspector
Document Control Desk - NRC

8706010326 870520
PDR ADDCK 05000397
PDR