

WASHINGTON NUCLEAR - UNIT 2

3/4 3-71

TABLE 3.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>REQUIRED NUMBER OF CHANNELS</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>ACTION</u>
1. Reactor Vessel Pressure	2	1	1, 2	80
2. Reactor Vessel Water Level	2	1	1, 2	80
3. Suppression Chamber Water Level	2	1	1, 2	80
4. Suppression Chamber Water Temperature	2/sector	1/sector	1, 2	80
5. Suppression Chamber Air Temperature	2	1	1, 2	80
6. Drywell Pressure	2	1	1, 2	80
7. Drywell Air Temperature	2	1	1, 2	80
8. Drywell Oxygen Concentration	2	1	1, 2	80
9. Drywell Hydrogen Concentration	2	1	1, 2	80
10. Safety/Relief Valve Position Indicators	2/valve	1/valve	1, 2	80 See Note
11. Suppression Chamber Pressure	2	1	1, 2	80
12. Condensate Storage Tank Level	2	1	1, 2	80
13. Main Steam Line Isolation Valve Leakage Control System Pressure	2	1	1, 2	80

NOTE - The acoustic monitor for MS-RV-2D may be inoperable until the Third Refueling Outage scheduled for No Later Than May 15, 1988, or until the first forced outage of sufficient duration to effect repair/replacement prior to that date without applying the shutdown requirement of Action 80.a

8710200349 871013
PDR ADOCK 05000397
P PDR

