

CURTIS ESCHELS  
Chairman



660547  
TAC 59793  
PDR

STATE OF WASHINGTON  
ENERGY FACILITY SITE EVALUATION COUNCIL

Mail Stop PY-11 • Olympia, Washington 98504 • (206) 459-6490 • (SCAN) 585-6490

February 9, 1987

Director of Nuclear Reactor Regulation  
Attn: Ms. E. G. Adensam, Project Director  
BWR Project Directorate No. 3  
Division of BWR Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Ms. Adensam:

Subject: AMENDMENT TO FACILITY OPERATING LICENSE  
NPF-21, WPPSS NUCLEAR PROJECT NO. 2

During their regular meeting of January 26, 1987, the Washington State Energy Facility Site Evaluation Council reviewed and adopted a motion indicating that the Council has no comments on the Washington Public Power Supply System's request by letter dated January 17, 1986, to amend the Operating License for Nuclear Project No. 2.

The Supply System's request involved a change to Section 4.6.4.1 (Suppression Chamber - Drywell Vacuum Breakers) of the WNP-2 Technical Specifications. The proposed amendment will change the surveillance frequency for operability demonstration of the vacuum breaker pairs and position indicators from 31 to 92 days.

The Council was notified of the proposed amendment request by the Supply System in accordance with the notification requirements of 10 CFR 50.91.

We appreciate the opportunity to review this license amendment.

Sincerely,

Curtis Eschels  
Chairman

CE:MM:ab

cc: D.W. Mazur, WPPSS  
G.C. Sorensen, WPPSS  
J.O. Bradfute, NRC

B712090151 B70209  
PDR ADDCK 05000397  
PDR

