

DRYWELL AND SUPPRESSION CHAMBER PURGE SYSTEMLIMITING CONDITION FOR OPERATION

3.6.1.8 The drywell and suppression chamber purge system may be in operation with the drywell and/or suppression chamber purge supply and exhaust butterfly isolation valves open for inerting, deinerting, or pressure control, provided that each butterfly valve is blocked so as not to open more than 70°. PURGING through the Standby Gas Treatment System shall be restricted to less than or equal to 90 hours per 365 days (SEE NOTE 1).

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

- a. With a drywell and/or suppression chamber purge supply and/or exhaust butterfly isolation valve open for other than inerting, deinerting, or pressure control, or not blocked to less than or equal to 70° open, close the butterfly valve(s) within 1 hour or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With a drywell and suppression chamber purge supply and/or exhaust isolation valve(s) with resilient material seals having a measured leakage rate exceeding the limit of Surveillance Requirement 4.6.1.8.2, restore the inoperable valve(s) to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.8.1 When being opened, the drywell and suppression chamber purge supply and exhaust butterfly isolation valves shall be verified to be blocked so as to open to less than or equal to 70° open, unless so verified within the previous 31 days.

4.6.1.8.2 At least once per 6 months, on a STAGGERED TEST BASIS, each 24- and 30-inch drywell and suppression chamber purge supply and exhaust isolation valve with resilient material shall be demonstrated OPERABLE by verifying that the measured leakage is:

- a. Less than or equal to 0.05 L_a per valve test or,
- b. Greater than 4.6.1.8.2.a. provided that: 1) the valves are secured closed and maintenance performed at the next plant cold shutdown to reduce the leakage to within 4.6.1.8.2.a; 2) the leakage added to the previously determined total for all valves and penetrations subject to Type B and C tests per LCO 3/4.6.1.2 shall be less than 0.6 L_a ,
- c. In the event the valves are to be operated, and 4.6.1.8.2.a. has been exceeded, a leakage test must be performed within 24 hours following operation, to ensure compliance with 0.6 L_a .

CONTROLLED COPY

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

4.6.1.8.3 The cumulative time that the drywell and suppression chamber purge system has been in operation PURGING through the Standby Gas Treatment System shall be verified to be less than or equal to 90 hours per 365 days prior to use in this mode of operation (SEE NOTE 1).

NOTE 1: FOR THE PERIOD OF TIME ENDING APRIL 10, 1988
THIS VALUE SHALL BE 100 HOURS PER 365 DAYS.

