

REFUELING OPERATIONS

3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE POOL

LIMITING CONDITION FOR OPERATION

3.9.7 Loads up to 1500 pounds may be permitted to travel over fuel assemblies in the spent fuel storage pool racks provided that the height and weight of the load above the surface of the pool water is limited per Figure 3.9.7-1. (SEE NOTE)

APPLICABILITY: With fuel assemblies in the spent fuel storage pool racks.

ACTION:

With the requirements of the above specification not satisfied, place the crane load in a safe condition. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.7 Crane interlocks and physical stops which prevent crane travel with loads in excess of 1500 pounds over fuel assemblies in the spent fuel storage pool racks shall be demonstrated OPERABLE within 7 days prior to and at least once per 7 days during crane operation.

NOTE: LOADS IN EXCESS OF 1500 POUNDS ARE PERMITTED TO TRAVEL OVER FUEL ASSEMBLIES IN THE SPENT FUEL STORAGE POOL RACKS:

- 1) DURING THE INSTALLATION/REMOVAL OF A PROTECTIVE COVER PROVIDED THAT ADEQUATE MEASURES ARE TAKEN TO PREVENT THE LOAD FROM FALLING INTO THE POOL DURING TRANSIT; AND
- 2) DURING ANY NECESSARY REPAIRS TO THE REACTOR BUILDING ROOF TO REPAIR THE DAMAGE CAUSED

ON FEB. 14, 1988.

WASHINGTON NUCLEAR - UNIT 2

3/4 9-9

8802250459 880218
PDR ADDCK 05000397
P PDR