

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8803020012 DOC.DATE: 88/02/23 NOTARIZED: NO DOCKET #
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME AUTHOR AFFILIATION
 SORENSEN,G.C. Washington Public Power Supply System
 RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License NPF-21, revising limiting condition for operation for 3/4.9.7, "Crane Travel...."

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 141
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL	
	PD5 LA		1	0	
	SAMWORTH,R		1	1	
INTERNAL:	ARM/DAF/LFMB		1	0	
	NRR/DEST/CEB8H7		1	1	
	NRR/DEST/RSB 8E		1	1	
	NRR/PMAS/TLRB12		1	1	
	REG FILE 01		1	1	
EXTERNAL:	LPDR		1	1	
	NSIC		1	1	
	PD5 PD		5	5	
	NRR/DEST/ADS7E4		1	1	
	NRR/DEST/MTB 9H		1	1	
	NRR/DOEA/TSB11F		1	1	
	OGC 15-B-18		1	0	
	RES/DE/EIB		1	1	
	NRC PDR		1	1	

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 17

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

Washington Public Power Supply System

3000 George Washington Way P.O. Box 968 Richland, Washington 99352-0968 (509)372-5000

February 23, 1988

G02-88-044
Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2
OPERATING LICENSE NPF-21, REQUEST FOR A ONE
TIME ONLY TEMPORARY AMENDMENT TO TECHNICAL
SPECIFICATION 3.9.7 (CRANE TRAVEL-SPENT FUEL
STORAGE POOL) UNDER EMERGENCY CIRCUMSTANCES
(ADDITIONAL CLARIFICATION)


Reference: Letter, G02-88-038 G.C. Sorensen (SS) to NRC
same subject, dated February 18, 1988

Numerous discussions were held the morning of February 23, 1988 between R.B. Samworth of the NRC and P.L. Powell and H. L. Aeschliman of the Supply System to discuss the reference submittal. As a result of these discussions, the Supply System requests that the amendment to the Limiting Condition for Operation (LCO) for 3/4.9.7 (Crane Travel-Spent Fuel Storage Pool) be revised as attached.

This change is being submitted in order to ensure that this waiver is for a finite period of time, and to further ensure that it is limited to analyzed loads above the fuel pool and below the roof's superstructure. The previous 10CFR 50.59 and 50.92 evaluations are still applicable to this clarification.

Should you have any further questions regarding this matter, please contact P.L. Powell, Manager, WNP-2 Licensing.

Very truly yours,


G.C. Sorensen, Manager
Regulatory Programs

PLP/slr

cc: JB Martin - NRC RV
NS Reynolds - BCP&R
RB Samworth - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

8803020012 880223
PDR ADOCK 05000397
P DCD

Adol
1/1

