

## REFUELING OPERATIONS

### 3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE POOL

#### LIMITING CONDITION FOR OPERATION

3.9.7 Loads up to 1500 pounds may be permitted to travel over fuel assemblies in the spent fuel storage pool racks provided that the height and weight of the load above the surface of the pool water is limited per Figure 3.9.7-1. (see note)

APPLICABILITY: With fuel assemblies in the spent fuel storage pool racks.

#### ACTION:

With the requirements of the above specification not satisfied, place the crane load in a safe condition. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.9.7 Crane interlocks and physical stops which prevent crane travel with loads in excess of 1500 pounds over fuel assemblies in the spent fuel storage pool racks shall be demonstrated OPERABLE within 7 days prior to and at least once per 7 days during crane operation.

*Note: During the period February 19 through April 19, 1988 this limiting condition for operation is waived for:*

*1) the installation/removal of a protective cover provided that adequate measures are taken to prevent the load from falling into the pool during transit; and*

*2) The movement of roof structural members weighing up to 700 pounds and of construction equipment and supplies necessary to repair the damage to the reactor building roof caused on February 14, 1986.*

WASHINGTON NUCLEAR - UNIT 2

3/4 9-9

8803020013 880223  
PDR ADOCK 05000397  
P DCD