

CONTROLLED COPY

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

ACTION STATEMENTS

- ACTION 20 - Be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
- ACTION 21 - Be in at least STARTUP with the associated isolation valves closed within 6 hours or be in at least HOT SHUTDOWN within 12 hours and in COLD SHUTDOWN within the next 24 hours.
- ACTION 22 - Close the affected system isolation valves within 1 hour and declare the affected system inoperable.
- ACTION 23 - Be in at least STARTUP within 6 hours.
- ACTION 24 - Restore the manual initiation function to OPERABLE status within 8 hours or close the affected system isolation valves within the next hour and declare the affected system inoperable or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- ACTION 25 - Establish SECONDARY CONTAINMENT INTEGRITY with the standby gas treatment system operating within 1 hour.
- ACTION 26 - Lock close or close, as applicable, the affected system isolation valves within 1 hour and declare the affected system inoperable.

TABLE NOTATIONS

- *May be bypassed with reactor steam pressure \leq 1037 psig and all turbine stop valves closed.
- **When handling irradiated fuel in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.
- #During CORE ALTERATIONS and operations with a potential for draining the reactor vessel.
- (a) A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip system is monitoring that parameter.
- (b) Also actuates the standby gas treatment system.
- (c) Also trips and isolates the mechanical vacuum pumps.
- (d) A channel is OPERABLE if 2 of 4 detectors in that channel are OPERABLE.
- (e) Also actuates secondary containment ventilation isolation dampers per Table 3.6.5.2-1.
- (f) Closes only RWCU system outboard isolation valve RWCU-V-4.
- (g) Only valves RHR-V-123A and RHR-V-123B in Valve Group 5 are required for primary isolation.
- (h) Manual initiation isolates RCIC-V-8 only and only with a coincident reactor vessel level-low, level 3.
- (i) not required for RHR-V-8 when control is transferred to the Alternate Remote Shutdown panel during Operational Conditions 1, 2, and 3 and the isolation interlocks are bypassed. When RHR-V-8 control is transferred to the remote shutdown panel under operational modes 1, 2, and 3 the associated key lock switch will be locked with the valve in the closed position. Except RHR-V-8 can be returned to, and operated from, the control room, with the interlocks and automatic isolation capability reestablished
- WASHINGTON NUCLEAR - UNIT 2 3/4 3-15
- in operational conditions 2 and 3 when reactor pressure is less than 135 psig.

