TABLE 3.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION

INSTRUMENT		REQUIRED NUMBER OF CHANNELS	MINIMUM CHANNELS OPERABLE	APPLICABLE OPERATIONAL CONDITIONS	ACTION
1.	Reactor Vessel Pressure	2	1	1, 2	80
2.	Reactor Vessel Water Level	2	1	1, 2	80
3.	Suppression Chamber Water Level	2	1	1, 2	80
4.	Suppression Chamber Water Temperature	2/sector	1/sector	1, 2	80
5.	Suppression Chamber Air Temperature	2	1	1, 2	80
6.	Drywell Pressure	2	1	1, 2	80
7.	Drywell Air Temperature	2	1	1, 2	80
8.	Drywell Oxygen Concentration	2	1	1, 2	80
9.	Drywell Hydrogen Concentration	2	1	1, 2	80
10.	Safety/Relief Valve Position Indicators	2/valve*	1/valve	1, 2	80
11.	Suppression Chamber Pressure	2	1	1, 2	80
12.	Condensate Storage Tank Level	2	1	1, 2	80
13.	Main Steam Line Isolation Valve Leakage Control System Pressure	2	1	1, 2	80

*NOTE - The acoustic monitor for MS-RV-~~2C~~ 1B may be inoperable until the ~~Third~~ fourth Refueling Outage scheduled for No Later Than May 15, ~~1988~~ 1989, or until the first forced outage of sufficient duration to effect repair/replacement prior to that date without applying the shutdown requirement of Action 80.a

TABLE 4.3.7.5-1

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

INSTRUMENT	CHANNEL CHECK	CHANNEL CALIBRATION	APPLICABLE OPERATIONAL CONDITIONS
1. Reactor Vessel Pressure	M	R	1, 2
2. Reactor Vessel Water Level	M	R	1, 2
3. Suppression Chamber Water Level	M	R	1, 2
4. Suppression Chamber Water Temperature	M	R	1, 2
5. Suppression Chamber Air Temperature	M	R	1, 2
6. Primary Containment Pressure	M	R	1, 2
7. Drywell Air Temperature	M	R	1, 2
8. Drywell Oxygen Concentration	M	R	1, 2
9. Drywell Hydrogen Concentration	M	Q	1, 2
10. Safety/Relief Valve Position Indicators	M*	R	1, 2
11. Suppression Chamber Pressure	M	R	1, 2
12. Condensate Storage Tank Level	M	R	1, 2
13. Main Steam Line Isolation Valve Leakage Control System Pressure	M	R	1, 2
14. Neutron Flux:			
APRM	M	R	1, 2
IRM	M	R	1, 2
SRM	M	R	1, 2
15. RCIC Flow	M	R	1, 2
16. HPCS Flow	M	R	1, 2
17. LPCS Flow	M	R	1, 2

*Surveillance of the OPERABLE Tailpipe Temperature instrument channel for SRV MS-RV-~~2G~~ 1B will be performed daily until the acoustic monitor for that valve is once again declared OPERABLE.

Tech Spec Amendment
Table 3.3.7.5-1
Subject: Accident Monitoring Instru

STATE OF WASHINGTON)
)
COUNTY OF BENTON)

I, J. W. Shannon, being duly sworn, subscribe to and say that I am the Assistant Managing Director for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information and belief the statements made in it are true.

DATE 7/25, 1988

J. W. Shannon
Assistant Managing Director

On this day personally appeared before me J. W. Shannon to me known to be the individual who executed the foregoing instrument and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 25th day of July 1988.

Graci M. Hardy
Notary Public in and for the STATE OF WASHINGTON

Residing at Kennewick, WA
Expires February 4, 1990