

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8809070317 DOC.DATE: 88/08/23 NOTARIZED: NO DOCKET #  
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH.NAME AUTHOR AFFILIATION  
 SORESENSEN,G.C. Washington Public Power Supply System  
 RECIP.NAME RECIPIENT AFFILIATION  
 MARTIN,J.B. Region 5, Ofc of the Director

SUBJECT: Provides current status rept on remaining three tasks identified in WNP-2 Fire Protection Program Reevaluation.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 2  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 PD	1 1	SAMWORTH,R	2 2
INTERNAL:	ACRS	2 2	AEOD	1 1
	DEDRO	1 1	NRR MORISSEAU,D	1 1
	NRR/DLPQ/PEB 11	1 1	NRR/DLPQ/QAB 10	1 1
	NRR/DOEA DIR 11	1 1	NRR/DREP/EPB 10	1 1
	NRR/DREP/RPB 10	2 2	NRR/DRIS DIR 9A	1 1
	NRR/PMAS/ILRB12	1 1	NUDOCS-ABSTRACT	1 1
	<del>OE-LIEBERMAN,J</del>	1 1	OGC/HDS2	1 1
	<u>REG FILE</u> 02	1 1	RES/DSIR DEPY	1 1
	RGN5 FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 25

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

RECEIVED  
MRC  
REGION

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

83 AUG 26 9:51

G02-88-183  
August 23, 1988

Docket No. 50-397

Mr. J. B. Martin  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, CA 94596

Subject: NUCLEAR PLANT NO. 2  
OPERATING LICENSE NPF-21  
FIRE PROTECTION REEVALUATION REPORT -  
STATUS REPORT

Reference: Letter G02-88-006, G.C. Sorensen (SS) to J.B. Martin (NRC), same  
subject dated January 8, 1988

In the reference letter, the Supply System provided a status report on the scheduled completion dates for eight (8) tasks that had been identified as improvement initiatives in the WNP-2 Fire Protection Program Reevaluation Report. At that time, five (5) of those tasks had been completed and the remainder were on schedule. The purpose of this letter is to provide a current status report on the remaining three (3) tasks, numbers 6, 7 and 8.

<u>Task</u>	<u>Scheduled Completion Date</u>	<u>Status</u>
6) Document in a report justifications for deviations from NFPA codes	9/87	Report completed 11/87. Procedure revisions completed 5/88. One new procedure remains to be completed, scheduled for 8/88.


8809070317 880823  
PDR ADOCK 05000397  
F PNU

IEO1  
1/0

Page Two  
FIRE PROTECTION REEVALUATION REPORT -  
STATUS REPORT

- |  |      |  |
|--|------|--|
| 7) Correct Thermo Lag configurations if required based on the test program.                          | 6/88 | Rework of Thermo Lag deficiencies completed 5/88.  |
| 8) Complete update of the FSAR to clarify requirements basis (part of the routine 1988 FSAR update.) | 9/88 | Changes necessary to comply with 10CFR50.71 will be included in Amendment 39, scheduled for submittal 8/88. The remaining changes will await NRC approval of Amendment 37. |

Very truly yours,



G. C. Sorensen, Manager  
Regulatory Programs

lw

cc: JB Martin - NRC RV  
NS Reynolds - BCP&R  
RB Samworth - NRC  
DL Williams - BPA - 399  
NRC Site Inspector - 901A