

# CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9809180185      DOC. DATE: 98/08/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 KASKO, B.      Washington Public Power Supply System  
 SMITH, G.O.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1998 for WNP-2. With 980915  
 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

|           | RECIPIENT<br>ID CODE/NAME | COPIES<br>LTTR ENCL | RECIPIENT<br>ID CODE/NAME | COPIES<br>LTTR ENCL |
|-----------|---------------------------|---------------------|---------------------------|---------------------|
|           | PD4-2 PD                  | 1    1              | POSLUSNY, C               | 1    1              |
| INTERNAL: | ACRS                      | 1    1              | AEOD/SPD/RRAB             | 1    1              |
|           | <u>FILE CENTER 01</u>     | 1    1              | OC/DBA/PAD                | 1    1              |
|           | RGN4                      | 1    1              |                           |                     |
| EXTERNAL: | LITCO BRYCE, J H          | 1    1              | NOAC                      | 1    1              |
|           | NRC PDR                   | 1    1              |                           |                     |

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR    10    ENCL    10

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • Richland, Washington 99352-0968

September 15, 1998  
GO2-98-166

Docket No. 50-397

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Subject:           **WNP-2 OPERATING LICENSE NPF-21  
MONTHLY OPERATING REPORT  
AUGUST 1998**

Transmitted herewith is the Monthly Operating Report for the month of August 1998 as required by Technical Specification 5.6.4.

Respectfully,



G. O. Smith  
Plant General Manager  
Mail Drop 927M

cc:   EW Merschoff - NRC RIV  
      C Poslusny, Jr. - NRR  
      DF Kirsch - NRC RIV, WCFO  
      NRC Sr. Resident Inspector - 927N  
      PD Robinson - Winston & Strawn  
      INPO  
      ANI Library  
      Utility Data Institute  
      DL Williams - BPA / 1399

IE2411

9809180185 980831  
PDR ADDCK 05000397  
R PDR

180027

[illegible]

**OPERATING STATUS REPORT**  
for WNP-2

Date: September 1, 1998

---

1. Docket: 50-397
  2. Reporting Period: **AUGUST 1998**
  3. Utility Contact: **Bernice Kasko (509) 377-4473**
  4. Design Electrical Rating (Net MW<sub>e</sub>): 1153
  5. Maximum Dependable Capacity - summer (Net MW<sub>e</sub>): 1107
- 
- |  | <u>MONTH</u> | <u>YEAR</u> | <u>CUMULATIVE</u> |
|--|--------------|-------------|-------------------|
|--|--------------|-------------|-------------------|
- 
10. Challenges to safety/relief valves: None

## UNIT SHUTDOWNS

DOCKET NO.: 50-397  
UNIT NAME: WNP-2  
DATE: September 1, 1998  
COMPLETED BY: B Kasko  
TELEPHONE: (509) 377-4473

REPORT PERIOD: AUGUST 1998

| No.   | Date   | Type<br>F: Forced<br>S: Scheduled | Duration<br>(Hours) | Reason (1) | Method (2) | Cause and Corrective Action To Prevent Recurrence   |
|-------|--------|-----------------------------------|---------------------|------------|------------|---|
| 98-04 | 8/7/98 | F                                 | 349.1               | D          | 1          | Trouble shooting and repair efforts for the EDG-2 voltage regulation system failed to restore EDG-2 to operable condition and in accordance with Technical Specification 3.8.1.F the plant was shutdown (LER 98-14) |

**SUMMARY:** The plant entered the month at 100% power. On August 4, 1998 while performing EDG-2 monthly operability test, EDG-2 reactive load oscillations were observed. As a result, EDG-2 was declared inoperable and in accordance with Technical Specification 3.8.1.F the plant was shutdown. On August 22, 1998 the plant was returned to operation and achieved full power on August 23, 1998.

### (1) REASON

A - Equipment Failure  
B - Maintenance or Test  
C - Refueling  
D - Regulatory Restriction

E - Operator Training &  
License Examination  
F - Administration  
G - Operational Error  
H - Other

### (2) METHOD

1 - Manual  
2 - Manual Scram  
3 - Auto Scram  
4 - Continued  
5 - Reduced Load  
9 - Other

[illegible][illegible]