

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

**SUBJECT:** Informs staff of errors in world-wide-web database related to WNP-2 reactor vessel structural integrity. Marked-up pages containing errors or omissions will be forwarded by 991201.

**NOTES :**

RECIPIENT			RECIPIENT		
ID CODE/NAME	COPIES		ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
CUSHING, J	1	1			
INTERNAL: ACRS	1	1	FILE CENTER 01	1	1
NUDOCS-ABSTRACT	1	1	OGC/RP	1	0
RES/DET/MEB	1	1			
EXTERNAL: NOAC	1	1	NRC. PDR	1	1

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

**TOTAL NUMBER OF COPIES REQUIRED: LTTR 8 ENCL**

may

# ENERGY NORTHWEST

P.O. Box 968 □ Richland, Washington 99352-0968

August 30, 1999  
GO2-99-166

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: **WNP-2, OPERATING LICENSE NPF-21  
ACCEPTABILITY OF REACTOR VESSEL INTEGRITY  
DATABASE INFORMATION RELATIVE TO WNP-2**

Reference: Letter dated July 13, 1999, JS Cushing (NRC) to JV Parrish (Energy Northwest), "Closure of TAC NO. MA1213 - Response to the Requests for Additional Information to Generic Letter 92-01, Revision 1, Supplement 1, 'Reactor Vessel Structural Integrity,' for the Washington Public Power Supply System Nuclear Project No. 2 (WNP-2)"

The purpose of this letter is to inform the staff of errors in the world-wide-web database related to the WNP-2 reactor vessel structural integrity. The referenced letter recommended that we review the database information and provide comments as to its accuracy relative to WNP-2.

Specifically, the application of the minimum shell plate thickness for the thinner section of the core beltline was applied to the thicker shell section when evaluated for irradiation damage. Additionally, there is an omission of seam-weld information related to filler wire /flux control number combinations.

Energy Northwest will print the web site database screens that contain the errors or omissions, mark-up the pages, and forward these changes to the staff by December 1, 1999.

Should you have any questions or require additional information pertaining to this letter, please contact PJ Inserra at (509) 377-4147.

Respectfully,

*D. W. Coleman*

DW Coleman (Mail Drop PE20)  
Manager, Regulatory Affairs

090004

cc: EW Merschoff - NRC - RIV  
JS Cushing - NRC - NRR  
TC Poindexter - Winston & Strawn

NRC Sr. Resident Inspector - 927N  
DL Williams - BPA/1399

9909070168 990830  
PDR ADDCK 05000397  
P PDR

1/0  
A028

