

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8905180307 DOC. DATE: 89/05/18 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORESEN, G.C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Undated ltr providing clarifications re proposed ATWS
 recirculating pump trip design, per 890418 telcon.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
	PD5	LA	1	0		PD5	PD	3	3
		SAMWORTH, R	1	1					
INTERNAL:	ACRS		6	6		NRR	LASHER, D	1	1
	NRR/DEST/ESB	8D	1	1		NRR/DEST/ICSB	7	1	1
	NRR/DEST/PSB	8D	1	0		NRR/DLPQ/QAB	10	1	0
	NRR/DOEA/GCB	11	1	0		NUDOCS-ABSTRACT		1	1
	OC/LFMB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u>	01	1	1		RES/DSIR/EIB		1	1
EXTERNAL:	LPDR		1	1		NRC	PDR	1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 19

m/184 gh



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2
 OPERATING LICENSE NPF-21
 PROVISIONS FOR ATWS RECIRCULATING
 PUMP TRIP (ADDITIONAL INFORMATION)

Reference: 1) Letter, G02-89-055, GC Sorensen (SS) to NRC,
 same subject, dated April 5, 1989

 2) Letter, G02-89-015, GC Sorensen (SS) to NRC
 "Compliance with ATWS Rule 10CFR 50.62 Relating
 to RPT System", dated February 6, 1989

In Reference 1) the Supply System requested that the NRR Staff provide the Supply System with any concerns they might have with the conceptual RPT logic trip design previously submitted (Reference 2). The Supply System requested the NRR respond no later than April 21, 1989. On April 18, 1989 a conference call was held between Hulbert Li, Jerry Mauck, and Bob Samworth of the NRR, and Larry Aeschliman, Bob Green, Gordon Brastad and Scott Mulkey of the Supply System. The purpose of the conference call was to discuss any concerns the Staff had regarding the proposed subject design.

As a result of the above conference call, the Supply System provides the following clarifications:

8905180307 890518
PDR ADDCK 05000397
P PNU



A055
11

Page Two

PROVISIONS FOR ATWS RECIRCULATING PUMP TRIP (ADDITIONAL INFORMATION)

1. The Supply System will install a permanent testing feature that will allow testing, while at power, of the relay logic up to and including the last relay prior to the trip coil.
2. Indication of testing will be provided to the Control Room Operators.
3. The Supply System will submit the appropriate Technical Specification change (no later than March 1, 1990).

It is the Supply System's understanding that the NRR staff has no other specific concerns regarding the WNP-2 RPT proposed design at this time. The Supply System intends to proceed immediately on that basis.

Very truly yours,



G. C. Sorensen, Manager
Regulatory Programs (MD 280)

HLA/bk

cc: JB Martin - NRC RV
NS Reynolds - BCP&R
RB Samworth - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

May 18, 1989

DISTRIBUTION
Docket File
PDR
LPDR
PD 5
JLee

DOCKET NO(S). 50-397

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply System
Post Office Box 968
Richland, Washington 99352

SUBJECT: WASHINGTON PUBLIC POWER SUPPLY SYSTEM - NUCLEAR PROJECT NO. 2

The following documents concerning our review of the subject facility are transmitted for your information.

- ☐ Notice of Receipt of Application, dated _____.
- ☐ Draft/Final Environmental Statement, dated _____.
- ☐ Notice of Availability of Draft/Final Environmental Statement, dated _____.
- ☐ Safety Evaluation Report, or Supplement No. _____ dated _____.
- ☐ Environmental Assessment and Finding of No Significant Impact, dated _____.
- ☐ Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License, dated _____.
- ☒ Bi-Weekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations, dated 5/3/89 [see page(s)] 18962-18963.
- ☐ Exemption, dated _____.
- ☐ Construction Permit No. CPPR-_____, Amendment No. _____ dated _____.
- ☐ Facility Operating License No. _____, Amendment No. _____ dated _____.
- ☐ Order Extending Construction Completion Date, dated _____.
- ☐ Monthly Operating Report for _____ transmitted by letter dated _____.
- ☐ Annual/Semi-Annual Report- _____
_____ transmitted by letter dated _____.

Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc: See next page

OFFICE	DRP/PD5						
SURNAME	JLee						
DATE	5/18/89						

m/184
9/1

