

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Undated ltr forwarding Amend 1 to NPDES Permit WA 002515-1,
issued to Washington Public Power Supply Sys.

NOTES:

RECIPIENT
ID CODE/NAME

COPIES
LTTR ENCL

RECIPIENT
ID CODE/NAME

COPIES
LTR ENCL

PD5 LA
SAMWORTH, R

4	4
1	1

PD5 PD

1 1

INTERNAL: ACRS
NRR/DEST/ADE 8H
NRR/DREP/RPB 10
OC/LFMB
REG FILE 01

6	6
1	1
2	2
1	0
1	1

AEOD/DSP/TPAB
NRR/DEST/SGB 8D
NUDOCS-ABSTRACT
OGC/HDS2
RGN5 DRSS/RPB

1	1
1	1
1	1
1	0
2	2

EXTERNAL: EG&G SIMPSON, F
NRC PDR

$$\begin{array}{cc} 2 & 2 \\ 1 & 1 \end{array}$$

LPDR
NSIC

1	1
1	1

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 26

RIDS / ADDS

R
I
D
S
/
A
D
D
S

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397


U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: NUCLEAR PLANT NO. 2
OPERATING LICENSE NO. NPF-21
MODIFICATION OF NPDES PERMIT

Reference: Letter (No. G02-89-058), G. C. Sorensen (Supply System) to
U.S. NRC, same subject, dated April 10, 1989.

With the referenced letter we transmitted a proposed modification to the WNP-2 NPDES Permit. This modification was approved by the Energy Facility Site Evaluation Council on April 24. In accordance with Appendix B, paragraph 3.2 of our operating license, we are providing the permit change (see attached) for your information.

Very truly yours,



G. C. Sorensen, Manager
Regulatory Programs

JPC/tlr

Attachment

cc: C.J. Bosted, Resident NRC Inspector (901A)
J.B. Martin, Region V NRC
N.S. Reynolds, BCP&R
R.B. Samworth, NRC
D.L. Williams, BPA (399)

8905190188 890519
PDR ADDCK 05000397
P PNU

cool
11

Curtis Eschels
Chairman



STATE OF WASHINGTON

ENERGY FACILITY SITE EVALUATION COUNCIL

Mail Stop PY-11 • Olympia, Washington 98504 • (206) 459-6490 • (SCAN) 585-6490

April 26, 1989

Mr. Donald W. Mazur
Managing Director
Washington Public Power
Supply System
P.O. Box 968
Richland, WA 99352-0968

Dear Mr. Mazur:

SUBJECT: WNP-2 NPDES PERMIT AMENDMENT NO. 1

During their regularly scheduled meeting on April 24, 1989, the Energy Facility Site Evaluation Council approved Amendment No. 1 to the National Pollutant Discharge Elimination System Permit No. WA 002515-1 for the Washington Public Power Supply System's Nuclear Project No. 2 (WNP-2). A copy of the amendment is enclosed for your records.

The amendment changes Special Condition S1.B - Total Residual Chlorine, Monitoring Requirement, Minimum Frequency from "Continuous" to "2 Times per Chlorination" and Sample Type from "N/A" to "Grab". The amendment also deletes Note 3 and renumbers Notes 4 through 6 as Notes 3 through 5. The daily maximum concentration which is allowed was not changed.

This amendment allows the Supply System to discontinue continuous monitoring of total residual chlorine and begin using grab samples as the means for obtaining samples for total residual chlorine determination prior to blowdown of cooling water to the Columbia River.

Thank you for your continued cooperation in these matters.

Sincerely,

Curtis Eschels
Chairman

CE:AF:kc

Enclosure

cc: G. Sorensen, Supply System
Bill Kiel, Supply System

MAY 01 REC'D

