

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8907190022 DOC. DATE: ~~89/06/30~~ NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH. NAME AUTHOR AFFILIATION  
 HUTCHISON, L.B. Washington Public Power Supply System  
 POWERS, C.M. Washington Public Power Supply System  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1989 for WNP-2.W/890710 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: *REGULATORY INFORMATION SYSTEM*

R  
I  
D  
S  
/  
A  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
S

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID CODE/NAME		LTTR	ENCL	ID CODE/NAME		LTTR	ENCL
PD5 LA		3	3	PD5 PD		1	1
SAMWORTH, R		1	1				
INTERNAL: ACRS		10	10	AEOD/DOA		1	1
AEOD/DSP/TPAB		1	1	IRM TECH ADV		2	2
NRR/DLPQ/PEB 10		1	1	NRR/DOEA/EAB 11		1	1
NRR/DREP/RPB 10		1	1	NUDOCS-ABSTRACT		1	1
REG FILE <u>01</u>		1	1	RGN5		1	1
EXTERNAL: EG&G SIMPSON, F		1	1	LPDR		1	1
NRC PDR		1	1	NSIC		1	1

*Cent No P723006561*

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 29

*MR gh*

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397

July 10, 1989


U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

SUBJECT: NUCLEAR PLANT NO. 2  
MONTHLY OPERATING REPORT

Transmitted herewith is the Monthly Operating Report  
for June 1989 as required by our Technical Specifications  
6.9.1.6.

Very Truly Yours,

  
C. W. Powers (M/D 927M)  
WNP-2 Plant Manager

CMP/lc

Enclosure

cc: Mr. J. B. Martin - NRC Region V  
Mr. C. J. Bosted - NRC Site Representative (901A)  
Ms. Dottie Sherman - ANI, Farmington CT  
Mr. J. T. Wheelock - INPO  
Mr. W. H. Lovelace - NRC, Washington D.C.

8907190022 890630  
PDR ADOCK 05000397  
R PDC

*Cent No P123006561*  
*IFPA*  
*11*

DOCKET NO. 50-397

UNIT NAME WNP-2

DATE 7/5/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONSREPORT PERIOD JUNE 19 89  
month, year

NO.	DATE	TYPE	HOURS	REASON	METHOD	LER NUMBER	SYSTEM	COMPONENT	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
89-06	4/28/89	S	663.6	C	4	-	RC	FUELXX	REFUELING OUTAGE CONCLUDED
89-07	6/29/89	S	33.52	B	1	-	HA	MECFUN	GENERATOR WAS REMOVED FROM GRID TO PERFORM OVERSPEED TESTS ON TURBINE. A REACTOR SCRAM OCCURED PRIOR TO COMPLETION OF TESTS
89-08	6/30/89	S	4.2	B	1	-	HA	MECFUN	GENERATOR WAS REMOVED FROM GRID TO COMPLETE OVERSPEED TESTING OF TURBINE AND PERFORM SCRAM TIME TESTING

**SUMMARY**

WNP-2 COMPLETED SCHEDULED REFUELING OUTAGE AND RETURNED TO POWER IN JUNE. SUBSEQUENTLY 2 SCHEDULED OUTAGES FOR TESTING WERE INCURRED.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-397

UNIT WNP-2

DATE 7/5/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509)377-2486

MONTH JUNE 1989

DAY AVERAGE DAILY POWER LEVEL  
(MwE-Net)

1.	<u>0</u>
2.	<u>0</u>
3.	<u>0</u>
4.	<u>0</u>
5.	<u>0</u>
6.	<u>0</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>0</u>
10.	<u>0</u>
11.	<u>0</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL  
(MwE-Net)

17.	<u>0</u>
18.	<u>0</u>
19.	<u>0</u>
20.	<u>0</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>50</u>
29.	<u>0</u>
30.	<u>61</u>
31.	<u></u>

## INSTRUCTIONS

On this form, list the average daily unit power level in MwE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

OPERATING DATA REPORT  
WNP-2

01-Jul-89

DOCKET: 50-397

REPORTING PERIOD: Jun-89 OUTAGE + ON-LINE HOURS 720

UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486

LICENSED THERMAL POWER (MWt): 3323  
NAMEPLATE RATING (GROSS MWe): 1200.9  
DESIGN ELECTRICAL RATING (NET MWe): 1100  
MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1140  
MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1095

IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:

NONE

POWER TO WHICH RESTRICTED, IF ANY (NET MWe):

REASONS FOR RESTRICTIONS, IF ANY:

NONE

	MONTH	YEAR	CUMULATIVE
REPORT PERIOD HOURS	720	4343	39847.2
HOURS REACTOR CRITICAL	94.5	2798.3	29015.9
RX RESERVE SHUTDOWN HRS	0.0	0.0	340.4
HRS GENERATOR ON LINE	18.7	2681.9	27846.5
UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
GROSS THERMAL ENERGY (MWH)	28470	7149562	76260767
GROSS ELECTRICAL ENERGY (MWH)	3390	2350670	25384170
NET ELECTRICAL ENERGY (MWH)	-4264	2245452	24413760
UNIT SERVICE FACTOR	2.6%	61.8%	69.9%
UNIT AVAILABILITY FACTOR	2.6%	61.8%	70.8%
UNIT CAPACITY FACTOR (MDC NET)	-0.5%	47.2%	56.0%
UNIT CAPACITY FACTOR (DER NET)	-0.5%	47.0%	55.7%
UNIT FORCED OUTAGE RATE	0.0%	3.0%	9.1%
FORCED OUTAGE HOURS	0.0	83.6	2775.2

SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

NONE

IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

