

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8907310145 DOC. DATE: 89/07/24 NOTARIZED: YES DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORESEN, G.C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to Generic Ltr 89-06, "SPDS."

DISTRIBUTION CODE: A003D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR/Licensing Submittal: Suppl 1 to NUREG-0737 (Generic Ltr 82-33)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1		PD5 PD	7 7
	SAMWORTH, R	1 1			
INTERNAL:	NRR/DLPQ/HFB 10	1 1		NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0		<u>REG FILE</u> 01	1 1
	RES/DSIR/EIB	1 1			
EXTERNAL:	LPDR	1 1		NRC PDR	1 1
	NSIC	1 1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 17 ENCL 16

R
I
D
S
/
A
D
D
S

m/A4 gh



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

July 24, 1989
G02-89-127

Docket No. 50-397

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2
RESPONSE TO GENERIC LETTER 89-06

Reference: 1) Letter, NRC to All Licensees of Operating Plants
"Task Action Plan Item I.D.2 - Safety Parameter
Display System - 10CFR50.54(f) - Generic Letter
89-06", dated April 12, 1989
2) G. W. Knighton (NRC) to G.C. Sorensen (SS),
"Safety Parameter Display System", dated
October 13, 1987
3) G. C. Sorensen (SS) to NRC, "Safety Parameter
Display System", dated January 7, 1988

In response to Reference 1) the Supply System certifies that the WNP-2 SPDS (Graphic Display System) fully meets the requirements of NUREG-0737, Supplement 1, taking into account information provided in NUREG-1342.

Reference 1) includes a checklist for BWR SPDS Parameter Selection. Not all of the parameters included on this list are displayed by the WNP-2 Graphic Display System. As NUREG-0737, Supplement 1 states "(t)he specific parameters to be displayed shall be determined by the licensee," we do not view this as an issue of compliance to this document.

Also, the NRC SER for the WNP-2 SPDS (transmitted with reference 2) accepted the parameters displayed with the exception of hydrogen monitoring (not displayed). We responded to this concern in Reference 3).

Very truly yours,

Alan Hoster

G. C. Sorensen, Manager
Regulatory Programs

AGH/bk

8907310145 890724
PDR ADOCK 05000397
P PDC

cc: JB Martin - NRC RV
NS Reynolds - BCP&R
RB Samworth - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

A003
11

22 23 24 25
26 27 28 29

STATE OF WASHINGTON)
COUNTY OF BENTON)

Subject: Generic Letter 89-06

I, A. G. HOSLER, being duly sworn, subscribe to and say that I am the Manager, WNP-2 Licensing, for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information and belief the statements made in it are true.

DATE July 24, 1989

A. G. Hosler
A. G. HOSLER, Manager
WNP-2 Licensing

On this day personally appeared before me A. G. HOSLER to me known to be the individual who executed the foregoing instrument and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 24th day of July, 1989.

Barbara A. Robertson
Notary Public in and for the
State of Washington

Residing at Richland, WA

11.11.55

