

CONTROLLED COPY

TABLE 3.8.4.2-1

PRIMARY CONTAINMENT PENETRATION CONDUCTOR OVERCURRENT PROTECTIVE DEVICES

<u>EQUIPMENT</u>	<u>PRIMARY PROTECTION</u>	<u>BACKUP PROTECTION</u>
a. <u>6900V Circuit Breakers</u>		
RRC-P-1A	E-CB-RRR (Relay)	E-CB-S5 (Relay) E-CB-N2/5 (Relay)
RRC-P-1B	E-CB-RRB (Relay)	E-CB-S6 (Relay) E-CB-N2/6 (Relay)
b. <u>480VAC Fused Disconnects</u>		
MS-V-16	MC-8B-A	Fused
RWCU-V-1	MC-8B-A	Fused
RHR-V-9	MC-8B-A	Fused
RCIC-V-63	MC-8B-A	Fused
RCC-V-40	MC-8B-A	Fused
RHR-V-123B	MC-8B-A	Fused
RCIC-V-76	MC-8B-A	Fused
RHR-V-123A	MC-8B-A	Fused
		<div style="border: 1px solid black; border-radius: 50%; padding: 5px; display: inline-block;"> MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB MC-8B 125ACB </div>

Change all
to state
Fused

8908180333 890814
PDR ADOCK 05000397
PDC