

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8909180101 DOC. DATE: ~~89/08/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L.B. Washington Public Power Supply System
 POWERS, C.M. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Aug 1989 for WPPS 2.W/890908 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
PD5 LA	3	3	PD5 PD	1	1
SAMWORTH, R	1	1			
INTERNAL: AGRS	10	10	AEOD/DOA	1	1
AEOD/DSE/TPAB	1	1	IRM TECH ADV	2	2
NRR/DLPQ/PEB 10	1	1	NRR/DOEA/EAB 11	1	1
NRR/DREP/RPB 10	1	1	NUDOCS-ABSTRACT	1	1
REG FILE 01	1	1	RGN5	1	1
EXTERNAL: EG&G SIMPSON, F	1	1	LPDR	1	1
NRC PDR	1	1	NSIC	1	1

Cent. No 723006559

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 29

me gh

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397

September 8, 1989

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

SUBJECT: NUCLEAR PLANT NO. 2
MONTHLY OPERATING REPORT

Transmitted herewith is the Monthly Operating Report
for August 1989 as required by our Technical Specifications
6.9.1.6.

Very Truly Yours;



C. M. Powers (M/D 927M)
WNP-2 Plant Manager

CMP/lc

Enclosure

cc: Mr. J. B. Martin - NRC Region V
Mr. C. J. Bosted - NRC Site Representative (901A)
Ms. Dottie Sherman - ANI; Farmington CT
Mr. J. T. Wheelock - INPO
Mr. W. H. Lovelace - NRC; Washington D.C.

8909180101 890831
PDR ADCK 05000397
R PDC

Ent No P723006559
IF24
11

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-397

UNIT WNP-2

DATE 9 /1/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509)377-2486

MONTH AUGUST 1989

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

1.	<u>1060</u>
2.	<u>1058</u>
3.	<u>1040</u>
4.	<u>1030</u>
5.	<u>1054</u>
6.	<u>894</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>152</u>
10.	<u>761</u>
11.	<u>570</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>157</u>

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

17.	<u>227</u>
18.	<u>494</u>
19.	<u>737</u>
20.	<u>733</u>
21.	<u>732</u>
22.	<u>738</u>
23.	<u>745</u>
24.	<u>663</u>
25.	<u>739</u>
26.	<u>748</u>
27.	<u>745</u>
28.	<u>752</u>
29.	<u>751</u>
30.	<u>743</u>
31.	<u>749</u>

INSTRUCTIONS

On this form, list the average daily unit power level in MwE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

01-Sep-89

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

DOCKET NO. 50-397

UNIT NAME WNP-2

DATE 9/1/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509)377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD AUG 1989
month, year

NO.	DATE	TYPE	HOURS	REASON	METHOD	LER NUMBER	SYSTEM	COMPONENT	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
89-09	8/6/89	F	59.6	A	3	89-031	CH	TURBIN	REACTOR SCRAM FROM 100% POWER ON LOW RPV LEVEL. INITIATED BY TRIP OF "B" REACTOR FEEDWATER DRIVE TURBINE ON LOW LUBE OIL PRESSURE DURING TESTING OF BACKUP OIL PUMPS.
89-10	8/11/89	F	115	F	1	89-034	EB	ELECON	PLANT WAS SHUTDOWN TO RESOLVE AND CORRECT ELECTRICAL FUSE COORDINATION AND SEPARATION ISSUES ON SAFETY RELATED LOW VOLTAGE MOTOR CONTROL CENTERS
89-11	8/17/89	F	17.3	G	3	89-035	IA	INSTRU S	REACTOR SCRAM FROM 67% POWER DUE TO INADVERTENT ACTUATION OF AN RPV LOW LEVEL SWITCH DURING EXECUTION OF A TECH SPEC SURVEILLANCE.

SUMMARY

WNP-2 INCURRED 3 FORCED SHUTDOWNS DURING AUGUST AS DESCRIBED ABOVE.
ALSO, POWER OUTPUT WAS LIMITED TO 71% AFTER 8/17/89 DUE TO REPAIR OF "B" RFW PUMP.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)