

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8910190082 DOC. DATE: ~~89/09/30~~ NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH. NAME AUTHOR AFFILIATION  
 HUTCHINSON, L.B. Washington Public Power Supply System  
 POWERS, C.M. Washington Public Power Supply System  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1989 for WPPS 2 Nuclear  
 Plant. W/891009 Ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	SAMWORTH, R	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	IRM TECH ADV	2 2
	NRR/DLPQ/PEB 10	1 1	NRR/DOEA/EAB 11	1 1
	NRR/DREP/RPB 10	1 1	NUDOCS-ABSTRACT	1 1
	REG FILE 01	1 1	RGN5	1 1
EXTERNAL:	EG&G SIMPSON, F	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 29

R  
I  
D  
S  
/  
A  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

---

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

---

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

---

Docket No. 50-397

October 9, 1989

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

SUBJECT: NUCLEAR PLANT NO. 2  
MONTHLY OPERATING REPORT

Transmitted herewith is the Monthly Operating Report  
for September 1989 as required by our Technical Specifications  
6.9.1.6.

Very Truly Yours;

*C M Powers*

C. M. Powers (M/D 927M)  
WNP-2 Plant Manager

CMP/lc

Enclosure

cc: Mr. J. B. Martin - NRC Region V  
Mr. C. J. Bosted - NRC Site Representative (901A)  
Ms. Dottie Sherman - ANI; Farmington CT  
Mr. J. T. Wheelock - INPO  
Mr. W. H. Lovelace - NRC; Washington D.C.

8910190082 890930  
PDR ADOCK 05000397  
R PDC

IE24  
1/1



DOCKET NO. 50-397

UNIT NAME WNP-2

DATE 10/1/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509)377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD SEPT 1989  
month, year

NO.	DATE	TYPE	HOURS	REASON	METHOD	LER NUMBER	SYSTEM	COMPONENT	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
89-12	9/21/89	F	29	A	2	-	HC	HT EXCH-D	PLANT WAS MANUALLY SHUTDOWN BECAUSE OF RAPIDLY INCREASING CONDUCTIVITY DUE TO CONDENSER TUBE IN-LEAKAGE. TWO DAMAGED TUBES WERE PLUGGED AND PLANT REMAINED DOWN FOR REPAIR OF STEAM EXTRACTION LINES.
89-13	9/22/89	S	167.16	A	4	-	HJ	PIPEXX-E	PLANT REMAINED DOWN FOR REPAIR/REPLACEMENT OF TWO FAILED STEAM EXTRACTION LINE EXPANSION BELLOWS AND CONDENSER BAFFLE REPAIR. AFTER COMPLETION OF REPAIR TO ALL DAMAGED COMPONENTS, THE PLANT WAS RETURNED TO SERVICE.

SUMMARY

WNP-2 INCURRED 1 FORCED OUTAGE WHICH WAS EXTENDED FOR REPAIR OF RELATED COMPONENTS.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		



34

1  
2  
3  
4  
5

6  
7  
8  
9  
10

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-397

UNIT WNP-2

DATE 10/1/89

COMPLETED BY LB HUTCHISON

TELEPHONE (509)377-2486

MONTH SEPTEMBER 1989

## DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

1.	<u>745</u>
2.	<u>757</u>
3.	<u>759</u>
4.	<u>755</u>
5.	<u>716</u>
6.	<u>747</u>
7.	<u>750</u>
8.	<u>746</u>
9.	<u>747</u>
10.	<u>950</u>
11.	<u>1014</u>
12.	<u>1058</u>
13.	<u>1061</u>
14.	<u>1067</u>
15.	<u>1045</u>
16.	<u>1002</u>

## DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

17.	<u>1062</u>
18.	<u>1062</u>
19.	<u>1050</u>
20.	<u>944</u>
21.	<u>673</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>550</u>
31.	<u>0</u>

### INSTRUCTIONS

On this form, list the average daily unit power level in MwE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

01-Oct-89

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:



25