

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9005080177 DOC.DATE: 90/05/01 NOTARIZED: NO DOCKET #
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME AUTHOR AFFILIATION
 SORESEN, G.C. Washington Public Power Supply System
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to Generic Ltr 89-21 requesting plant status on
 implementation of USIs re ATWS.

DISTRIBUTION CODE: A012D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Generic Ltr 89-21 Response, Implementation of Unresolved Safety Issue

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL	
	PD5	PD	1	1		SAMWORTH, R	1	1		
INTERNAL:	ACRS		1	1		BARBER, G PTSB	1	1		
	<u>REG FILE</u>	01	1	1		WESSMAN, R PD13	1	1		
EXTERNAL:	LPDR		1	1		NRC PDR	1	1		
	NSIC		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 0

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

14-00000

14-00000

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

May 1, 1990
G02-90-087

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21
RESPONSE TO GENERIC LETTER 89-21 REQUESTING PLANT
STATUS ON IMPLEMENTATION OF UNRESOLVED SAFETY
ISSUES AS RELATED TO ATWS (TAC NOS. 74538 AND 59158)

- Reference: 1) Letter; G02-89-215, GC Sorensen to NRC,
same subject, dated November 30, 1989
- 2) Letter, G02-89-055, GC Sorensen to NRC, "Provisions
for ATWS Recirculating Pump Trip" dated April 5, 1989

In Reference 1 we stated that Technical Specification changes required as a result of modifications to the ATWS Recirculation Pump Trip (RPT) logic would be submitted by March 1, 1990. With the trip logic, including its testing capability, as described in Reference 2 we have concluded that no changes to the Technical Specifications are required.

Very truly yours,

R. Sorensen
for C. Sorensen, Manager
Regulatory Programs

AGH/bk

cc: JB Martin - NRC RV
NS Reynolds - BCP&R
RB Samworth - NRC
DL Williams - BPA/399
NRC Site Inspector - 901A

9005080177 900501
PDR ADOCK 05000397
P PDC

*A012
1/0*

