

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9007180136 DOC.DATE: 90/06/30 NOTARIZED: NO DOCKET #
 FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH.NAME AUTHOR AFFILIATION
 HUTCHISON, L.B. Washington Public Power Supply System
 POWERS, C.M. Washington Public Power Supply System
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1990 for Washington Nuclear
 Plant Unit 2.W/900706 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD5 LA		3	3		PD5 PD		1	1
	SAMWORTH, R		1	1					
INTERNAL:	ACRS		10	10		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		IRM TECH ADV		2	2
	NRR/DLPO/LPEB10		1	1		NRR/DOEA/OEAB11		1	1
	<u>REG FILE</u> 01		1	1		RGN5		1	1
EXTERNAL:	EG&G BRYCE, J.H		3	3		LPDR		1	1
	NRC PDR		1	1		NSIC		1	1

Cent NO
P475028254

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 29 ENCL 29

Monthly Rpt
WPPSS

R
I
D
S
/
A
D
S
/
A
D
D
S



9

4

—

[illegible]

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397

July 6, 1990

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Dear Sir:

SUBJECT: NUCLEAR PLANT NO. 2
MONTHLY OPERATING REPORT
JUNE 1990

Transmitted herewith is the Monthly Operating Report as required
by our Technical Specifications 6.9.1.6.

Very Truly Yours,


C. H. Powers (M/D 927M)
WNP-2 Plant Manager

CMP/lc

Enclosure

cc: Mr. J. B. Martin - NRC Region V
Mr. C. J. Bosted - NRC Resident Inspector (901A)
Ms. Dottie Sherman - ANI, Farmington CT
Mr. J. T. Wheelock - INPO
Mr. W. H. Lovelace - NRC, Washington D.C.

9007180136 900630
PDR ADOCK 05000397
R PDC

Ent No
PA75028254
IE24
1/1

DOCKET NO. 50-397

UNIT NAME WNP-2

DATE 7/2/90

COMPLETED BY LB Hutchison

TELEPHONE (509)377- 2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD June 1990
month, year

NO.	DATE	TYPE	HOURS	REASON	METHOD	LER NUMBER	SYSTEM	COMPONENT	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE
90-02	4/21/90	S	720	C	4		RC	Fuel xx	Refueling operation completed. However, outage was extended due to failure of a Diesel Generator. Rewinding of Diesel Generator rotor is in progress.

SUMMARY

WNP-2 remained shutdown the entire month of June as described above.

TYPE	REASON	METHOD	SYSTEM & COMPONENT
F-Forced	A-Equip Failure	F-Admin	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	Instructions for
	C-Refueling	H-Other	Preparation of
	D-Regulatory Restriction		Data Entry Sheet
	E-Operator Training		Licensee Event Report
	& License Examination		(LER) File (NUREG-0161)
		1-Manual	
		2-Manual Scram	
		3-Auto Scram	
		4-Continued	
		5-Reduced Load	
		9-Other	

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-397

UNIT WNP-2

DATE 7/6/90

COMPLETED BY LB Hutchison

TELEPHONE (509) 377-2486

MONTH June 1990

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

1.	<u>0</u>
2.	<u>0</u>
3.	<u>0</u>
4.	<u>0</u>
5.	<u>0</u>
6.	<u>0</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>0</u>
10.	<u>0</u>
11.	<u>0</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

17.	<u>0</u>
18.	<u>0</u>
19.	<u>0</u>
20.	<u>0</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>0</u>
31.	<u>0</u>

INSTRUCTIONS

On this form, list the average daily unit power level in MwE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

OPERATING DATA REPORT
WNP-2

01-Jul-90

1. DOCKET: 50-397
2. REPORTING PERIOD: Jun-90 OUTAGE + ON-LINE HOURS 720
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1140
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1095

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:

None

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):

11. REASONS FOR RESTRICTIONS, IF ANY: None

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	720	4343	48607.2
13. HOURS REACTOR CRITICAL	0.0	2653.8	35729.1
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	0.0	2639.5	34487.4
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	0	8233337	96577777
18. GROSS ELECTRICAL ENERGY (MWH)	0	2739380	32143330
19. NET ELECTRICAL ENERGY (MWH)	-9590	2625543	30911686
20. UNIT SERVICE FACTOR	0.0%	60.8%	71.0%
21. UNIT AVAILABILITY FACTOR	0.0%	60.8%	71.7%
22. UNIT CAPACITY FACTOR (MDC NET)	0.0%	55.2%	58.1%
23. UNIT CAPACITY FACTOR (DER NET)	0.0%	55.0%	57.8%
24. UNIT FORCED OUTAGE RATE	0.0%	0.0%	8.0%
25. FORCED OUTAGE HOURS	0.0	0.0	2996.2

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

7/17/90