

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9008170005 DOC. DATE: 90/07/31 NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L.B. Washington Public Power Supply System
 BAKER, J.W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Jul 1990 for Washington Nuclear
 Plant 2.W/900808 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	ENG, P.L.	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	IRM TECH ADV	2 2
	NRR/DLPO/LPEB10	1 1	NRR/DOEA/OEAB11	1 1
	<u>REG FILE</u> 01	1 1	RGN5	1 1
EXTERNAL:	EG&G BRYCE, J.H	3 3	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

*Cent No
 0085602813*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 29

*Monthly Rpt
 cert*

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

A B C

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

Docket No. 50-397

August 8, 1990


U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Dear Sir:

SUBJECT: NUCLEAR PLANT NO. 2
MONTHLY OPERATING REPORT
JULY 1990

Transmitted herewith is the Monthly Operating Report as required
by our Technical Specifications 6.9.1.6.

Very Truly Yours;



J. W. Baker (M/D 927M)
WNP-2 Plant Manager

JWB/lc

Enclosure

cc: Mr. J. B. Martin - NRC Region V
Mr. C. J. Bosted - NRC Resident Inspector (901A)
Ms. Dottie Sherman - ANI; Farmington CT
Mr. J. T. Wheelock - INPO
Mr. W. H. Lovelace - NRC; Washington D.C.

9008170005 900731
PDR ADOCK 05000397
R PDC

Cent No
P085602813
IE24
11

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-397

UNIT WNP-2

DATE 8/1/90

COMPLETED BY LB Hutchison

TELEPHONE (509) 377-2486

MONTH July 1990

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

1.	<u>0</u>
2.	<u>0</u>
3.	<u>0</u>
4.	<u>0</u>
5.	<u>0</u>
6.	<u>0</u>
7.	<u>0</u>
8.	<u>0</u>
9.	<u>0</u>
10.	<u>0</u>
11.	<u>0</u>
12.	<u>0</u>
13.	<u>0</u>
14.	<u>0</u>
15.	<u>0</u>
16.	<u>0</u>

DAY AVERAGE DAILY POWER LEVEL (MwE-Net)

17.	<u>0</u>
18.	<u>0</u>
19.	<u>0</u>
20.	<u>0</u>
21.	<u>0</u>
22.	<u>0</u>
23.	<u>0</u>
24.	<u>0</u>
25.	<u>0</u>
26.	<u>0</u>
27.	<u>0</u>
28.	<u>0</u>
29.	<u>0</u>
30.	<u>0</u>
31.	<u>0</u>

INSTRUCTIONS

On this form, list the average daily unit power level in MwE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO. 50-397UNIT NAME WNP-2DATE 8/1/90COMPLETED BY LB HutchisonTELEPHONE (509) 377-2486UNIT SHUTDOWNS / REDUCTIONSREPORT PERIOD July 1990
month, year

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NUMBER</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
90-02	4/21/90	S	744	C	4		RC	Fuel xx	Outage continued through the month for completion of repairs and restoration to service of a Diesel Generator.

SUMMARY

WNP-2 remained shutdown the entire month of July as described above.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

OPERATING DATA REPORT
WNP-2

01-Aug-90

1. DOCKET: 50-397

2. REPORTING PERIOD: Jul-90 OUTAGE + ON-LINE HOURS 744

3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486

4. LICENSED THERMAL POWER (MWt): 3323

5. NAMEPLATE RATING (GROSS MWe): 1200.9

6. DESIGN ELECTRICAL RATING (NET MWe): 1100

7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1140

8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1095

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:
NONE

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):

11. REASONS FOR RESTRICTIONS, IF ANY:
NONE

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	744	5087	49351.2
13. HOURS REACTOR CRITICAL	0.0	2653.8	35729.1
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	0.0	2639.5	34487.4
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	0	8233337	96577777
18. GROSS ELECTRICAL ENERGY (MWH)	0	2739380	32143330
19. NET ELECTRICAL ENERGY (MWH)	-9968	2615575	30901718
20. UNIT SERVICE FACTOR	0.0%	51.9%	69.9%
21. UNIT AVAILABILITY FACTOR	0.0%	51.9%	70.7%
22. UNIT CAPACITY FACTOR (MDC NET)	0.0%	47.0%	57.2%
23. UNIT CAPACITY FACTOR (DER NET)	0.0%	46.7%	56.9%
24. UNIT FORCED OUTAGE RATE	0.0%	0.0%	8.0%
25. FORCED OUTAGE HOURS	0.0	0.0	2996.2

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):
NONE

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:
