

CONTROLLED COPY

REACTOR COOLANT SYSTEM

JET PUMPS

LIMITING CONDITION FOR OPERATION

3.4.1.2 All jet pumps shall be OPERABLE.

APPLICABILITY: OPERATIONAL CONDITIONS 1 and 2.

ACTION:

With one or more jet pumps inoperable, be in at least HOT SHUTDOWN within 12 hours.

SURVEILLANCE REQUIREMENTS

4.4.1.2.1 Each of the above required jet pumps shall be demonstrated OPERABLE prior to THERMAL POWER exceeding 25% of RATED THERMAL POWER and at least once per 24 hours by determining recirculation loop flow, total core flow and diffuser-to-lower plenum differential pressure for each jet pump and verifying that no two of the following conditions occur when both recirculation loops are operating, ~~at the same flow control valve position.~~

- a. The indicated recirculation loop flow differs by more than 10% from the established flow control valve position-loop flow characteristics for two recirculation loop operation.
- b. The indicated total core flow differs by more than 10% from the established total core flow value derived from two recirculation loop flow measurements.
- c. The indicated diffuser-to-lower plenum differential pressure of any individual jet pump differs from established two recirculation loop operation patterns by more than 10%.

4.4.1.2.2 During single recirculation loop operation, each of the above required jet pumps shall be demonstrated OPERABLE at least once per 24 hours by verifying that no two of the following conditions occur:

- a. The indicated recirculation loop flow in the operating loop differs by more than 10% from the established single recirculation flow control valve position-loop flow characteristics.
- b. The indicated total core flow differs by more than 10% from the established total core flow value derived from single recirculation loop flow measurements.
- c. The indicated difference-to-lower plenum differential pressure of any individual jet pump differs from established single recirculation loop patterns by more than 10%.

9103060338 910225
PDR ADOCK 05000397
P PDR

2