

## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9104180095 DOC.DATE: 91/03/18 NOTARIZED: NO DOCKET #  
FACIL:50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397

AUTH.NAME AUTHOR AFFILIATION  
KWIATKOWSKI, D. Federal Emergency Management Agency  
RECIP.NAME RECIPIENT AFFILIATION  
CONGEL, F.J. Division of Radiation Protection & Emergency Preparedness R

SUBJECT: Forwards "Radiological Emergency Exercise Rept." Three I  
deficiencies & eighteen areas requiring corrective actions &  
areas recommended for improvement identified. D

DISTRIBUTION CODE: IE35D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2 + 95 S  
TITLE: Emergency Preparedness-Appraisal/Confirmatory Action Ltr/Exercise Rep

## NOTES: /

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD5 PD	1 1	ENG, P.L.	1 1	A
INTERNAL:	AEOD/DOA/IRB	1 1	NRR/DREP/PEPB9D	1 1	D
	NRR/PMAS/ILRB12	1 1	NUDOCS-ABSTRACT	1 1	D
	OC/LEMB	1 0	OE DIR	1 1	S
	REG FILE 02	1 1	RGN 2 COLLINS, D	1 1	
	RGN5 FILE 01	1 1			
EXTERNAL:	NRC PDR	1 1	NSIC	1 1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 13 ENCL 12

R  
I  
D  
S  
/  
A  
D  
D  
S



# Federal Emergency Management Agency

Washington, D.C. 20472

MAR 18 1991

DESIGNATED ORIGINAL

Certified By                     

Mr. Frank J. Congel  
Director  
Division of Radiation Protection  
and Emergency Preparedness  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Congel:

Enclosed is a copy of the final exercise report for the September 11, 1990, full-participation exercise of the offsite radiological emergency response plans site-specific to the WNP-2 Nuclear Power Plant. The State of Washington and Benton and Franklin Counties, Washington, participated in the exercise. The exercise report was prepared in December 1990 by the Region X staff of the Federal Emergency Management Agency (FEMA). A copy of this final exercise report will be provided to the State of Washington by the FEMA Region X staff.

Three Deficiencies, all for the State of Washington, were identified during the exercise. All three related to dose assessment and were for (1) inadequate information flow from the Emergency Operations Facility to the State Emergency Operations Center; (2) inadequate capabilities and expertise of the staff responsible for dose projections; and (3) inadequate dose projection systems. Eighteen Areas Requiring Corrective Action (ARCA) were also identified during this exercise. FEMA Region X has discussed all exercise Deficiencies and ARCAs with Washington State and the report reflects commitments, action plans, and milestone dates to address these issues, including a remedial drill tentatively scheduled for May 7, 1991.

Pending the outcome of the scheduled remedial drill and other pending remedial actions, FEMA is unable to find that the offsite radiological emergency response plans and preparedness for the WNP-2 Nuclear Power Plant are adequate to provide reasonable assurance that appropriate measures can be taken offsite to protect the public's health and safety in the event of a radiological emergency at the site. Once FEMA has received the results of the remedial drill and other remedial actions, it will notify the Nuclear Regulatory Commission of its findings.

**NRC FILE CENTER COPY**


FE35

9104180095 910318  
PDR ADOCK 05000397  
F PDR

111

If you should have any questions, please contact Mr. Craig S. Wingo, Chief, Technological Hazards Division, at 646-3026.

Sincerely,

  
Dennis H. Kwiatkowski  
Assistant Associate Director  
Office of Technological Hazards

Enclosure



2