

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9107220252      DOC. DATE: 91/06/30      NOTARIZED: NO      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 HUTCHISON, L.B.      Washington Public Power Supply System  
 BAKER, J.W.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for June 1991 for WPPSS-2.W/910709  
 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	ENG, P.L.	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB	1 1	<u>REG FILE</u> 01	1 1
	RGN5	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

*Cent NO*  
*118,519*

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

R  
I  
D  
S  
/  
A  
D  
D  
S  
/  
A  
D  
D  
S

*MOR*  
*CH*



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397

July 9, 1991

GO2-91-132

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Subject:       **NUCLEAR PLANT NO. 2**  
                  **MONTHLY OPERATING REPORT**  
                  **JUNE 1991**

Transmitted herewith is the Monthly Operating Report for the month of June 1991 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker  
WNP-2 Plant Manager  
(MD 927M)

bap  
Enclosure

cc:   Mr. W.H. Lovelace, NRC, Washington DC  
      Mr. J.B. Martin, NRC Region V  
      Ms. Dottie Sherman, ANI, Farmington CT  
      Mr. C. Sorensen, NRC Resident Inspector (901A)  
      Mr. J.T. Wheelock, INPO  
      Mr. F. Yost, Utility Data Institute

230008  
9107220252 910630  
PDR ADOCK 05000397  
R PDR

Cent No  
114,519  
JE24  
11

OPERATING DATA REPORT  
WNP-2

01-JUL-91

1. DOCKET: 50-397
2. REPORTING PERIOD: JUNE-91 OUTAGE + ON-LINE HOURS 720
3. UTILITY CONTACT: LEONARD B. HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe) 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1140
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1095
9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS: NONE
10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe): NONE
11. REASONS FOR RESTRICTIONS, IF ANY: NONE

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	720	4343	57367.2
13. HOURS REACTOR CRITICAL	0.0	2459	41443.2
14. RX RESERVE SHUTDOWN HOURS	0.0	0	340.4
15. HOURS GENERATOR ON LINE	0.0	2439.3	40042.2
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0	381.7
17. GROSS THERMAL ENERGY (MWh <sub>t</sub> )	0	7921510	114270535
18. GROSS ELECTRICAL ENERGY (MWh <sub>e</sub> )	0	2663880	38065520
19. NET ELECTRICAL ENERGY (MWh <sub>e</sub> )	-8080	2553573	36581743
20. UNIT SERVICE FACTOR	0.0%	56.2%	69.8%
21. UNIT AVAILABILITY FACTOR	0.0%	56.2%	70.5%
22. UNIT CAPACITY FACTOR (MDC NET)	0.0%	53.7%	58.2%
23. UNIT CAPACITY FACTOR (DER NET)	0.0%	53.5%	58.0%
24. UNIT FORCED OUTAGE RATE	100.0%	15.7%	8.8%
25. FORCED OUTAGE HOURS	456	456	3857.2

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

27. IF CURRENTLY SHUTDOWN, GIVE APPROXIMATE STARTUP DATE: 8/23/91

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397  
UNIT: WNP-2  
DATE: JUNE 1991  
COMPLETED BY: LB HUTCHISON  
TELEPHONE: (509) 377-2486

MONTH: JUNE 1991

## DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

1.	0
2.	0
3.	0
4.	0
5.	0
6.	0
7.	0
8.	0
9.	0
10.	0
11.	0
12.	0
13.	0
14.	0
15.	0
16.	0

## DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

17.	0
18.	0
19.	0
20.	0
21.	0
22.	0
23.	0
24.	0
25.	0
26.	0
27.	0
28.	0
29.	0
30.	0
31.	

### INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.



11/11/11  
11/11/11

DOCKET NO.: 50-397  
UNIT NAME: WNP-2  
DATE: JULY 1, 1991  
COMPLETED BY: LB HUTCHISON  
TELEPHONE: (509) 377-2486

### UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: JUNE 1991

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE &amp; CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
91-02	4/13/91	S	264	C	4	--	RC	FUEL XX	Concluded refueling outage June 11.
91-03	6/12/91	F	456	E	9	--	N/A	N/A	Remained shutdown to upgrade plant Emergency Operating Procedures and provide additional licensed operator training.

SUMMARY: WNP-2 concluded R-6 refueling outage on June 11. The plant then remained administratively shutdown as described above.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM &amp; COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)



11-11-11  
11-11-11



11-11-11  
11-11-11  
11-11-11  
11-11-11  
11-11-11