

RECEIVED  
NRC  
REGION V

WASHINGTON PUBLIC POWER SUPPLY SYSTEM 4 AM 10: 25

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

January 30, 1992  
GO2-92-028

Docket No. 50-397

Ray Bocanegra  
U.S. Nuclear Regulatory Commission  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368


Dear Mr. Bocanegra:

Subject: NUCLEAR PLANT NO. 2, OPERATING LICENSE NPF-21  
NRC SPLIT SAMPLE RESULTS

Reference: NRC Region V Inspection Report #50-397/91-40, Dated March 19, 1991

The results of WNP-2's analysis of the EDR-TK-4A split sample collected in conjunction with the referenced NRC Inspection Report, are attached.

Very truly yours,



J. W. Baker  
WNP-2 Plant Manager (927M)

DJP/grt  
Attachment

cc: JB Martin - NRC RV  
NS Reynolds - Winston & Strawn  
PL Eng - NRC/13E16  
DL Williams - BPA/399  
NRC Site Inspector - 901A



ATTACHMENT TO  
NRC SPLIT SAMPLE RESULTS

WNP-2's analysis of EDR-TK-4A split sample:

Sample Number: 91-9089  
Sample from: EDR-TK-4A  
Sample date: December 17, 1991, at 1020

Results

Tritium	$1.19\text{E-}3 \pm 1.87\text{E-}5$ uCi/cc
Iron-55	$2.65\text{E-}8 \pm 1.54\text{E-}8$ uCi/cc
Strontium-89	$5.64\text{E-}9 \pm 4.46\text{E-}9$ uCi/cc
Strontium-90	$\leq 3.41\text{E-}9$ uCi/cc
Gross Beta	$3.03\text{E-}9 \pm 1.01\text{E-}9$
Counted on	January 6, 1992, at 1430

