

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204270408 DOC. DATE: ~~91/12/31~~ NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 SORESENSEN, G.C. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "1991 Annual Environ Operating Rept." W/920421 ltr.

DISTRIBUTION CODE: IE25D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	DEAN, W.	1 1		
INTERNAL:	ACRS	1 1	NRR/DREP/PRPB11	2 2
	REG FILE 01	1 1	RGN5 DRSS/RPB	1 1
	RGN5 FILE 02	1 1		
EXTERNAL:	EG&G SIMPSON, F	2 2	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 14

Er-1

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352

April 21, 1992
GO2-92-102

Docket No. 50-397

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

Subject: **NUCLEAR PLANT NO. 2**
 1991 ANNUAL ENVIRONMENTAL OPERATING REPORT

This letter is submitted per reporting requirements of Section 5.4.1 of the WNP-2 Environmental Protection Plan (EPP)(Appendix B to Facility Operating License NPF-21).

A summary of the effluent data reported to the State of Washington on the monthly discharge monitoring reports is attached. One NPDES permit violation occurred in 1991. On May 21 the pH exceeded the limit of 9.0 for one hour, reaching a maximum of 10.1. The incident was reported to the Energy Facility Site Evaluation Council which subsequently issued a Notice of Violation (with \$1000 penalty) on August 26. No environmental impact was observed or alleged to have been attributable to the incident.

No design or operational changes or tests in 1991 involved an unreviewed environmental question. Also, no non-routine reports (within the context of EPP Section 5.4.2) were required for 1991.

Please contact us if you require additional information on this report.



G.C. Sorensen, Manager
Regulatory Programs (MD-280)

Attachment: Table of 1991 effluent data

cc: RC Sorensen, NRC Resident (901A)
 JJ Zeller, EFSEC
 JB Martin, NRC Region V
 WM Dean, NRC NRR

9204270408 911231
PDR ADOCK 05000397
R PDR

Handwritten: 7/25



100

100

100

100

100

100

100

100

100

100

WNP-2 COOLING WATER BLOWDOWN DISCHARGES, 1991

Month	Days of Discharge	pH		TRC (mg/l)	Discharge Volume (millions of gallons)		
		High	Low		Total	Ave*	Max**
Jan	31	8.5	8.0	≤0.1	95.76	3.09	4.34
Feb	28	8.4	8.0	≤0.1	90.02	3.21	5.51
Mar	31	8.6	8.2	≤0.1	60.20	1.94	4.10
Apr	20	8.6	7.5	≤0.1	74.52	3.73	7.24
May	27	10.1	7.0	≤0.1	40.56	1.50	1.95
Jun	15	8.3	7.6	≤0.1	17.43	1.16	1.73
Jul	13	8.0	7.5	≤0.1	14.19	1.09	1.51
Aug	21	8.6	7.9	≤0.1	30.70	1.46	2.27
Sep	21	8.3	7.5	≤0.1	29.31	1.40	2.16
Oct	31	8.8	7.9	≤0.1	92.92	3.00	5.18
Nov	26	8.6	7.7	≤0.1	78.33	3.01	5.94
Dec	22	8.6	8.1	≤0.1	82.51	3.75	6.59
Permit Limit		9.0	6.5	0.1		5.00	9.40

* Average daily discharge during the month.

** Maximum daily discharge during the month.

2000

2000