

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9204280434 DOC. DATE: ~~02/03/91~~ NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397  
 AUTH. NAME AUTHOR AFFILIATION  
 HUTCHISON, L.B. Washington Public Power Supply System  
 BAKER, J.W. Washington Public Power Supply System  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1992 for Washington Public  
 Power Supply Nuclear Plant 2. W/920408 Ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	DEAN, W.	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DLEQ/LRER10	1 1
	NRR/DOEA/OEAB	1 1	REG FILE 01	1 1
	RGN5	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

*Cont No  
 118,305  
 Rec'd 4/28/92*

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

*MR*





WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397

April 8, 1992

GO2-92-082

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Dear Sir:

Subject: NUCLEAR PLANT NO. 2  
MONTHLY OPERATING REPORT  
MARCH 1992

Transmitted herewith is the Monthly Operating Report for the month of March 1992 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker  
WNP-2 Plant Manager  
(MD 927M)

LBH:bap  
Enclosure



cc: Mr. W.H. Lovelace, NRC, Washington DC  
Mr. J.B. Martin, NRC Region V  
Ms. Dottie Sherman, ANI, Farmington CT  
Mr. C. Sorensen, NRC Resident Inspector (901A)  
Mr. J.T. Wheelock, INPO  
Mr. F. Yost, Utility Data Institute

*Out No 118, 305*

*IE24 1/1 Rec'd 4/28/92*

9204280434 920331  
PDR ADDCK 05000397  
R PDR





DOCKET NO.: 50-397  
 UNIT NAME: WNP-2  
 DATE: APRIL 1, 1992  
 COMPLETED BY: LB HUTCHISON  
 TELEPHONE: (509) 377-2486

# UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: MARCH 1992

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE &amp; CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
92-02	2/25/92	F	436.4	H	4	92-007	SE	RECOMB	Concluded outage for modificaiton of Containment Atmospheric Control (CAC) drain piping.

SUMMARY: WNP-2 returned to service on March 19 after completion of plant modifications.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM &amp; COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER  1-MANUAL 2-MANUAL SCRAM 3-AUTO SCRAM 4-CONTINUED 5-REDUCED LOAD 9-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)



OPERATING DATA REPORT  
WNP-2

DATE: 01-Apr-92

1. DOCKET: 50-397
2. REPORTING PERIOD: Mar-92 OUTAGE + ON-LINE HOURS 744
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085
9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:  
None.
- 
10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):
11. REASONS FOR RESTRICTIONS, IF ANY: None.
- 
- |                                    | MONTH  | YEAR    | CUMULATIVE |
|------------------------------------|--------|---------|------------|
| 12. REPORT PERIOD HOURS            | 744    | 2184    | 63968.2    |
| 13. HOURS REACTOR CRITICAL         | 329.9  | 1669.0  | 45059.7    |
| 14. RX RESERVE SHTDWN HRS          | 0.0    | 0.0     | 340.4      |
| 15. HRS GENERATOR ON LINE          | 307.6  | 1632.0  | 43431.9    |
| 16. UNIT RESERVE SHUTDOWN HOURS    | 0.0    | 0.0     | 381.7      |
| 17. GROSS THERMAL ENERGY (MWH)     | 950983 | 5250611 | 124866433  |
| 18. GROSS ELECTRICAL ENERGY (MWH)  | 319990 | 1781190 | 41637010   |
| 19. NET ELECTRICAL ENERGY (MWH)    | 301461 | 1705536 | 39963575   |
| 20. UNIT SERVICE FACTOR            | 41.3%  | 74.7%   | 67.9%      |
| 21. UNIT AVAILABILITY FACTOR       | 41.3%  | 74.7%   | 68.5%      |
| 22. UNIT CAPACITY FACTOR (MDC NET) | 37.3%  | 72.0%   | 57.1%      |
| 23. UNIT CAPACITY FACTOR (DER NET) | 36.8%  | 71.0%   | 56.8%      |
| 24. UNIT FORCED OUTAGE RATE        | 58.7%  | 25.3%   | 13.6%      |
| 25. FORCED OUTAGE HOURS            | 436.4  | 552.0   | 6855.8     |
26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):  
Refueling outage R-7 starting April 17, 1992 for 74 days.
- 
27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397  
UNIT: WNP-2  
DATE: MARCH 1992  
COMPLETED BY: LB HUTCHISON  
TELEPHONE: (509) 377-2486

MONTH: MARCH 1992

## DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

1.	0
2.	0
3.	0
4.	0
5.	0
6.	0
7.	0
8.	0
9.	0
10.	0
11.	0
12.	0
13.	0
14.	0
15.	0
16.	0

## DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

17.	0
18.	0
19.	160
20.	775
21.	1045
22.	1086
23.	1085
24.	1081
25.	1082
26.	1079
27.	1073
28.	1089
29.	1085
30.	1081
31.	1079

### INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.



