

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9205050080 DOC. DATE: 92/04/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397

AUTH. NAME: SORENSEN, G.C. AUTHOR AFFILIATION: Washington Public Power Supply System  
 RECIP. NAME: Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC 920430 ltr re violations noted in insp rept  
 50-397/91-16 on 910916. Corrective actions: Motor operated  
 valves w/in scope of GL 89-10 will be evaluated for  
 differential pressure conditions.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 PD	1 1	DEAN, W.	1 1
INTERNAL:	ACRS	2 2	AEOD	1 1
	AEOD/DEIIB	1 1	AEOD/DSP/TPAB	1 1
	DEDRO	1 1	NRR MORISSEAU, D	1 1
	NRR/DLPQ/LHFBPT	1 1	NRR/DLPQ/LPEB10	1 1
	NRR/DOEA/OEAB	1 1	NRR/DREP/PEPB9H	1 1
	NRR/DST/DIR 8E2	1 1	NRR/PMAS/ILRB12	1 1
	NUDOCS-ABSTRACT	1 1	OE DIR	1 1
	OGC/HDS1	1 1	REG FILE 002	1 1
	RGN5 FILE 01	1 1		
EXTERNAL:	EG&G/BRYCE, J.H.	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 23 ②





---

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

---

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

---

April 30, 1992  
G02-92-112

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Subject: WNP-2, OPERATING LICENSE NPF-21  
CLARIFICATION OF RESPONSE TO NRC INSPECTION REPORT 91-16

Reference: Letter G02-91-167, dated September 16, 1991, GD Bouchey (SS) to NRC,  
"NRC Inspection Report 91-16, Response to Notice of Violation,  
Response to Notice of Deviations"

In the reference letter, the Supply System provided responses to a Notice of Violation and a Notice of Deviation contained in the subject inspection report.

During preparation of an engineering standard for motor operated valve design basis reviews, it was determined that a clarification was needed with respect to our corrective action planned for review of the Emergency Operating Procedures (EOP).

The reference letter, (Appendix B, page 6) stated that the corrective action to be taken for item 1 is: "A review of the existing calculation (NE-02-88-06) will be performed to ensure that the scope of our Generic Letter 89-10 program includes those MOV's utilized in the Emergency Operating Procedures."

The following is the actual corrective action that is being taken with respect to review of EOP's.

9205050080 920430  
PDR ADDCK 05000397  
Q PDR

TELL 1/1




Page Two  
April 30, 1992  
CLARIFICATION OF RESPONSE TO  
NRC INSPECTION REPORT 91-16

Motor operated valves (MOV's) within the scope of GL 89-10 will be evaluated for differential pressure conditions encountered during their use in the EOP's. However, MOV's with EOP actions that are beyond design basis and that have no active design basis safety related function will be excluded from the scope of GL 89-10. This exclusion is based on the fact that the GL 89-10 recommendations are limited to those situations that are within the existing approved design basis at WNP-2.

This letter serves as a clarification of the corrective action to be taken for item 1 in Appendix B of the referenced letter.

Sincerely,



G. C. Sorensen, Manager  
Regulatory Programs (Mail Drop 280)

cc: JB Martin - NRC RV  
WM Dean - NRC  
NRC Site Inspector - 901A  
DL Williams - BPA/399