

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9205210298 DOC. DATE: ~~92/04/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Powe 05000397
 AUTH. NAME AUTHOR AFFILIATION
 HUTCHISON, L. Washington Public Power Supply System
 BAKER, J.W. Washington Public Power Supply System
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Apr 1992 for WNP-2. W/920506 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	3 3	PD5 PD	1 1
	DEAN, W.	1 1		
INTERNAL:	ACRS	10 10	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	NRR/DLPQ/LPER10	1 1
	NRR/DOEA/OEAB	1 1	<u>REG FILE 03</u>	1 1
	RGN5	1 1		
EXTERNAL:	EG&G BRYCE, J.H	1 1	NRC PDR	1 1
	NSIC	1 1		

*Rec'd
5/21/92*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

MR

R
I
D
S
/
A
D
S
/
A
D
D
S



WASHINGTON PUBLIC POWER SUPPLY SYSTEM

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

Docket No. 50-397

May 6, 1992

GO2-92-115

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Subject: **NUCLEAR PLANT NO. 2**
 MONTHLY OPERATING REPORT
 APRIL 1992

Transmitted herewith is the Monthly Operating Report for the month of April 1992 as required by our Technical Specifications 6.9.1.6.

Very truly yours,

J.W. Baker
WNP-2 Plant Manager
(MD 927M)

LBH:bap
Enclosure

cc: Mr. W.H. Lovelace, NRC, Washington DC
 Mr. J.B. Martin, NRC Region V
 Ms. Dottie Sherman, ANI, Farmington CT
 Mr. C. Sorensen, NRC Resident Inspector (901A)
 Mr. J.T. Wheelock, INPO
 Mr. F. Yost, Utility Data Institute

210080
9205210298 920430
PDR ADOCK 05000397
R PDR

Per No 118, 311
Rec'd 5/21/92
IE24

OPERATING DATA REPORT
WNP-2

DATE: 01-May-92

1. DOCKET: 50-397
2. REPORTING PERIOD: Apr-92 OUTAGE + ON-LINE HOURS 719
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:
None.
-
-
-

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):
-

11. REASONS FOR RESTRICTIONS, IF ANY:
-
-
-

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	719	2903	64687.2
13. HOURS REACTOR CRITICAL	416.0	2085.0	45475.7
14. RX RESERVE SHTDWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	410.6	2042.6	43842.5
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	1337639	6588250	126204072
18. GROSS ELECTRICAL ENERGY (MWH)	452340	2233530	42089350
19. NET ELECTRICAL ENERGY (MWH)	430411	2135947	40393986
20. UNIT SERVICE FACTOR	57.1%	70.4%	67.8%
21. UNIT AVAILABILITY FACTOR	57.1%	70.4%	68.4%
22. UNIT CAPACITY FACTOR (MDC NET)	55.2%	67.8%	57.1%
23. UNIT CAPACITY FACTOR (DER NET)	54.4%	66.9%	56.8%
24. UNIT FORCED OUTAGE RATE	0.0%	21.3%	13.5%
25. FORCED OUTAGE HOURS	0.0	552.0	6855.8

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):
None.
-
-

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

7/1/92

DOCKET NO.: 50-397
 UNIT NAME: WNP-2
 DATE: MAY 1, 1992
 COMPLETED BY: LB HUTCHISON
 TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: APRIL 1992

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
92-03	4/18/92	S	308.4	C	1	--	RC	FUEL XX	Plant was shutdown as scheduled for refueling outage R-7.

SUMMARY: WNP-2 operated routinely until April 18, 1992 when it was shutdown for refueling outage R-7.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.: 50-397
UNIT: WNP-2
DATE: APRIL 1992
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

MONTH: APRIL 1992

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

1.	1078
2.	1077
3.	1072
4.	1088
5.	1086
6.	1093
7.	1094
8.	1091
9.	1085
10.	1055
11.	1067
12.	1083
13.	1076
14.	1075
15.	1076
16.	1070

DAY AVERAGE DAILY POWER LEVEL (MWe-NET)

17.	865
18.	0
19.	0
20.	0
21.	0
22.	0
23.	0
24.	0
25.	0
26.	0
27.	0
28.	0
29.	0
30.	0
31.	

INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWe-NET FOR EACH DAY IN THE REPORTING MONTH. COMPUTE TO THE NEAREST WHOLE MEGAWATT.

THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT WHEN MAXIMUM DEPENDABLE CAPACITY IS USED FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER LEVEL EXCEEDS THE 100% LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.