

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9207200147      DOC. DATE: 92/07/16      NOTARIZED: YES      DOCKET #  
 FACIL: 50-397 WPPSS Nuclear Project, Unit 2, Washington Public Power      05000397  
 AUTH. NAME      AUTHOR AFFILIATION  
 SORENSEN, G.C.      Washington Public Power Supply System  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Revises 910404, 920406 & 0625 applications for amend to  
 License NPF-21, changing TS 4.8.2.1 re battery load  
 profiles, per discussions w/NRC.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 372  
 TITLE: OR Submittal: General Distribution

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	DEAN, W.	2 2		
INTERNAL:	ACRS	6 6	NRR/DET/ESGB	1 1
	NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
	NRR/DST/SELB 7E	1 1	NRR/DST/SICB8H7	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS1	1 0
	<u>REG FILE</u> 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 21

AA2

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



---

WASHINGTON PUBLIC POWER SUPPLY SYSTEM

---

P.O. Box 968 • 3000 George Washington Way • Richland, Washington 99352-0968 • (509) 372-5000

---

July 16, 1992  
G02-92-169

Docket No. 50-397

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: WNP-2, OPERATING LICENSE NPF-21,  
REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION 4.8.2.1,  
BATTERY LOAD PROFILES, SUPPLEMENTARY INFORMATION

- References: 1) Letter G02-91-064, dated April 4, 1991, GC Sorensen (SS) to NRC, same subject
- 2) Letter G02-92-081, dated April 6, 1992, GC Sorensen (SS) to NRC, same subject
- 3) Letter G02-92-153, dated June 25, 1992, GC Sorensen (SS) to NRC, same subject

Reference 1 requested that the battery load profiles of Surveillance Requirement 4.8.2.1.d.2 be relocated to the Final Safety Analysis Report (FSAR) and the Surveillance Requirement be modified to refer to the FSAR for the specific details of the profiles. Technical Specification page (3/4 8-13) was attached reflecting both relocation of the battery load profile table and additional wording to refer to the FSAR for details.

References 2 and 3 requested changes to Reference 1 to clarify the intent of the final specification. Two phrases were to be deleted that did not contribute to the technical adequacy of the specification. Reference 3 provided a draft of the total change including deletion of both phrases. The draft attached to Reference 3 remains appropriate.

Further discussion with the Staff has indicated that an appropriate place to reference the FSAR would be the Bases and not the text of the Specification. Accordingly, attached is a proposed insert to the WNP-2 Bases adding a change similar to that recommended by the Staff.

200117

9207200147 920716  
PDR ADDCK 05000397  
P PDR

A001  
1/1



Page 2

REQUEST FOR AMENDMENT TO TECHNICAL SPECIFICATION 4.8.2.1,  
BATTERY LOAD PROFILES

This addition to the Bases does not impact the intent of the original request nor does it affect the conclusions of Reference 1. The determination that the requested change (including the attached Bases addition) does not represent a significant hazard remains valid as does the conclusion that the change meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9) and does not require an environmental assessment.

Sincerely,



G. C. Sorensen, Manager  
Regulatory Programs (Mail Drop 280)

PLP/bk  
Attachment

cc: JB Martin - NRC RV  
NS Reynolds - Winston & Strawn  
R Assa - NRC  
DL Williams - BPA/399  
NRC Site Inspector - 901A  
RG Waldo - EFSEC



STATE OF WASHINGTON )  
COUNTY OF BENTON )

Subject: Request for Amend to Tech. Specs.  
Battery Load Profile, Suppl Info.

I, G. C. SORENSEN, being duly sworn, subscribe to and say that I am the Manager, Regulatory Programs for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have the full authority to execute this oath; that I have reviewed the foregoing; and that to the best of my knowledge, information, and belief the statements made in it are true.

DATE 16 July, 1992

G. C. Sorensen  
G. C. Sorensen, Manager  
Regulatory Programs

On this date personally appeared before me G. C. SORENSEN, to me known to be the individual who executed the foregoing instrument, and acknowledged that he signed the same as his free act and deed for the uses and purposes herein mentioned.

GIVEN under my hand and seal this 16 day of July 1992.

Bernie Korb  
Notary Public in and for the  
STATE OF WASHINGTON

Residing at Kennewick, Washington

My Commission Expires April 28, 1994

