

OPERATING DATA REPORT
WNP-2

01-Oct-91

1. DOCKET: 50-397
2. REPORTING PERIOD: Sep-91 OUTAGE + ON-LINE HOURS 720
Revision 1
3. UTILITY CONTACT: LEONARD HUTCHISON (509) 377-2486
4. LICENSED THERMAL POWER (MWt): 3323
5. NAMEPLATE RATING (GROSS MWe): 1200.9
6. DESIGN ELECTRICAL RATING (NET MWe): 1100
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWe): 1129
8. MAXIMUM DEPENDABLE CAPACITY (NET MWe): 1085

9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, GIVE REASONS:
None

10. POWER TO WHICH RESTRICTED, IF ANY (NET MWe):

11. REASONS FOR RESTRICTIONS, IF ANY: None

	MONTH	YEAR	CUMULATIVE
12. REPORT PERIOD HOURS	720	6551	59575.2
13. HOURS REACTOR CRITICAL	100.1	2559.1	41543.3
14. RX RESERVE SHUTDOWN HRS	0.0	0.0	340.4
15. HRS GENERATOR ON LINE	1.3	2440.6	40043.7
16. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	381.7
17. GROSS THERMAL ENERGY (MWH)	18824	7940334	114289359
18. GROSS ELECTRICAL ENERGY (MWH)	90	2663970	38065610
19. NET ELECTRICAL ENERGY (MWH)	-9763	2524009	36552179
20. UNIT SERVICE FACTOR	0.2%	37.3%	67.2%
21. UNIT AVAILABILITY FACTOR	0.2%	37.3%	67.9%
22. UNIT CAPACITY FACTOR (MDC NET)	0.0%	35.3%	56.1%
23. UNIT CAPACITY FACTOR (DER NET)	0.0%	35.0%	55.8%
24. UNIT FORCED OUTAGE RATE	99.8%	50.9%	12.9%
25. FORCED OUTAGE HOURS	588.0	2532.0	5933.2

26. SHUTDOWNS SCHEDULED OVER THE NEXT 6 MONTHS (TYPE, DATE, DURATION):

9207200176 920610
PDR ADDCK 05000397
R PDR

27. IF CURRENTLY SHUTDOWN ESTIMATED STARTUP DATE:

This is a copy of operating data report for September, 1991. Forced outage hours for September, were reported as 588 (see Line 25). However, it was input to the monthly NRC diskette as 718.7 hours. Attached is Revision 1 of Unit Shutdowns/Reductions Report for September, 1991 which describes the breakdown of forced and outage time. Please reduce WNP-2 yearly and cumulative forced outage time by 130.7 hours to correct the input.

[illegible]

DOCKET NO.: 50-397
UNIT NAME: WNP-2
DATE: OCTOBER 4, 1991
COMPLETED BY: LB HUTCHISON
TELEPHONE: (509) 377-2486

UNIT SHUTDOWNS / REDUCTIONS

REPORT PERIOD: SEPTEMBER 1991 - REVISION 1

<u>NO.</u>	<u>DATE</u>	<u>TYPE</u>	<u>HOURS</u>	<u>REASON</u>	<u>METHOD</u>	<u>LER NO</u>	<u>SYSTEM</u>	<u>COMPONENT</u>	<u>CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE</u>
91-03	6/12/91	F	588.0	E	4	--	N/A	N/A	Plant remained shutdown to provide additional licensed operator training and testing.
91-03A	9/25/91	S	130.7	B	4		N/A	N/A	Plant began scheduled startup activities after completion of operator training and testing.

SUMMARY: WNP-2 returned to service on September 30 as described above.

<u>TYPE</u>	<u>REASON</u>	<u>METHOD</u>	<u>SYSTEM & COMPONENT</u>
F-FORCED S-SCHED	A-EQUIP FAILURE B-MAINT OR TEST C-REFUELING D-REGULATORY RESTRICTION E-OPERATOR TRAINING & LICENSE EXAM	F-ADMIN G-OPER ERROR H-OTHER	EXHIBIT F & H INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEET LICENSEE EVENT REPORT (LER) FILE (NUREG-0161)
		1-MANUAL 2-MANUAL SCRAM 3-AUTO SCRAM 4-CONTINUED 5-REDUCED LOAD 9-OTHER	

